NRC MONTHLY OPERATING REPORT

DOCKET NO DATE 2-8-80

COMPLETED BY F. Wattson (714) 492-7700

OPERATING STATUS

	Unit Name: San Onofre Nuclear Ge January 1, 1980 to	nerating Station o January 31, 19	80					
	Reporting Period							
	Licensed I herman I ower (Street)							
4.	Nameplate Rating (Gloss Mine)							
5.	Design Electrical Rating (Net MWe): 430 Maximum Dependable Capacity (Gross MWe): 436 Maximum Dependable Capacity (Net MWe): 436							
6.								
1.	If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report, Give Reasons:							
0.	N.A.							
_	Power Level To Which Restricted, If Any (Net)	MWe): N.A.						
		A						
10.	Reasons For Restrictions, If Any:							
		This Month	Yrto-Date	Cumulative				
		744	744	110,720.3				
11.	Hours In Reporting Period	568.07	568.07	83,200.40				
	Number Of Hours Reactor Was Critical	- 0	0	0				
13.	Reactor Reserve Shutdown Hours	564.90	564.90	79,717.45				
	Hours Generator On-Line	- 0	0	0				
	Unit Reserve Shutdown Hours	750,876	750,876	102,282,375				
16.	Gross Thermal Energy Generated (MWH)	247,200	247,200	34,918,634				
17		236,191	236,191	33,083,557				
18.		75.93	75.93	75.50				
19.	Unit Service Factor	75.93	75.93	75.50				
20.		72.81	72.81	72.72				
21.	Unit Capacity Factor (Using MDC Net)	72.81	72.81	72.72				
22.		8.01	8.01	9.28				
23.	Unit Forced Outage Rate	D. I D. Internation	of Each):					
24.	Shutdowns Scheduled Over Next 6 Months (Ty Refueling April 11, 1980 -	7 to 10 weeks	or Each).					
			Fab	1080				
75	If Shut Down At End Of Report Period, Estima	February 10,						
26.	Units In Test Status (Prior to Commercial Oper	ation): N.A.	Forecast	Achieved				
	INITIAL CRITICALITY							
	INITIAL ELECTRICITY							
	COMMERCIAL OPERATION							

8211100167 800208 PDR ADDCK 05000206 R PDR

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO.	50-206		
UNIT	SONGS-1		
DATE	2-8-80		
COMPLETED BY	P. Wattson		
TELEPHONE	(714) 492-7700		

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)	DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
1	429	17	0
2	432	18	315
3	425	19	424
4	431	20	425
5	430	21	424
6	431	22	423
7	429	23	424
8	429	24	425
9	428	25	426
10	427	26	14
11	429	27	0
12	428	28	0
13	404	29	0
14	422	30	0
15	402	31	0
16	175		

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. UNIT NAME DATE

50-206 SONGS-1 2-8-80

COMPLETED BY TELEPHONE

P.Wattson (714) 492-7700

REPORT MONTH _ January

No.	Date	Typel	Duration (Hours)	Reason-	Method of Shutting Down Reactor ³	Licensee Event Report #	System Code4	Consponent Code 5	Cause & Corrective Action to Prevent Recurrence
39	1 - 3-80	S	1.3	В	5*	#A.	НВ	VALVEX	Turbine Stop Valve Test
40	1 -13-80	S	5.25	В	58	N.A.	НВ	VALVEX	Turbine Stop Valve Test
41	1 -15-80	S	8.0 37.8	В	5#	***	CA	PIPEXX CH	RCS Flow Tests Clear Condenser Water Boxes
42	1 -16-80	F	34.65	Н	3	80-002	СН	RELAYX	Accident Caused by Construction Worke
43	1 -26-80	S	141.3	Н	1	和.	ZZ	ZZZZZZ	TMI Modifications

F: Forced

S. Scheduled

Reason

A-Equipment Failure (Explain) B-Maintenance of Test

C-Refueling

D-Regulatory Restriction

F-Operator Training & License Examination

F-Administrative

G-Operational Error (Explain)

H-Other (Explain)

Method: 1-Manual

2-Manual Scram.

3-Automatic Scram.

4-Other (Explain)

Exhibit F - Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LER) File (NUREG 01611

Exhibit H- Same Source

SUMMARY OF OPERATING EXPERIENCE FOR THE MONTH

DOCKET	NO		50-	-206	
UNIT	SO	NGS-	1		
DATE	2-	8-19	80		
COMPLE	TED	ВҮ	Р.	Wattson	
TELEPH	ONE	(7	14)	492-7700	

At the beginning of the month the unit was operating at 449 MWe.

On January 3 at 0430 the unit load was reduced to 340 MWe for a turbine stop valve test. Unit was returned to full load at 0550.

On January 13 at 0600 the unit load was reduced to 360 MWe to perform a turbine stop valve test, and to heat treat the circulating water system inlet tunnel. The unit was returned to full load at 1115.

On January 15 at 2200, the unit load was reduced to 200 MWe to perform quarterly R.C.S. flow tests and to clear condenser water boxes. The unit returned to full power on January 16 at 0600.

On January 16 at 1219 the unit tripped from steam flow/feedwater flow mismatch trip caused by Bechtel construction worker who accidentally struck the closing circuit control relay to the east feedwater pump normal discharge valve (See LER 80-002). The reactor was critical on January 17 at 2255. The unit was returned to full load on January 18 at 1330.

On January 26 at 0240 the unit was brought off line to complete TMI plant modifications.

At the end of the month the unit remained off line for TMI modifications.

REFUELING INFORMATION

DOCKET NO. 50-206

UNIT SONGS 1

	DATE 2-8-80
	COMPLETED BY P. Wattson
	TELEPHONE (714) 492-7700
1.	Scheduled date for next refueling shutdown.
	April, 1980
2.	Scheduled date for restart following refueling.
	June, 1980
3.	Will refueling or resumption of operation thereafter require a Technical Specification change or other license amendment?
	No changes expected at this date.
	What will these be?
	N.A.
4.	Scheduled date for submitting proposed licensing action and supporting information.
	N.A.
5.	Important licensing considerations associated with refueling, e.g. new or different fuel design or supplier, unreviewed design or performance analysis methods, significant changes in fuel design, new operating procedures.
	None
6.	The number of fuel assemblies.
	a) In the core 157
	b) In the spent fuel storage pool. 55
7.	Licensed spent fuel storage capacity216
	Intended change in spent fuel storage capacity. None
8.	Projected date of last refueling that can be discharged to spent fuel storage pool assuming present capacity.
	April, 1983