

CONTROL BLOCK: [] [] [] [] [] [] [] [] [] [] (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

[01] [S][C][V][C][S][1] [2] [0][0]-[0][0][0][0][0]-[0][0] [3] [4][1][0][0][0] [4] [] [5]

CONT

[01] REPORT SOURCE [L] [6] [0][5][0][0][0][3][9][5] [7] [1][0][0][6][8][2] [8] [1][1][0][5][8][2] [9]

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

[02] While performing Surveillance Test Procedure 114.001, it was determined that the [03] Controlled Leakage exceeded the Tech. Spec. 3.4.6.2.(e) value of 33 gpm. There [04] were no adverse consequences as the Plant had not achieved initial criticality. [05] (The Plant was in Mode 3.) [06] [07] [08]

[09] SYSTEM CODE [C][G] [11] CAUSE CODE [A] [12] CAUSE SUBCODE [X] [13] COMPONENT CODE [V][A][L][V][E][X] [14] COMP. SUBCODE [G] [15] VALVE SUBCODE [G] [16] LER/RO REPORT NUMBER [17] [8][2] EVENT YEAR [8][2] SEQUENTIAL REPORT NO. [0][1][7] OCCURRENCE CODE [0][3] REPORT TYPE [L] REVISION NO. [0] ACTION TAKEN [E] [18] FUTURE ACTION [Z] [19] EFFECT ON PLANT [Z] [20] SHUTDOWN METHOD [Z] [21] HOURS [0][0][0][0] [22] ATTACHMENT SUBMITTED [Y] [23] NPRO-4 FORM SUB. [N] [24] PRIME COMP. SUPPLIER [N] [25] COMPONENT MANUFACTURER [C][6][3][5] [26]

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

[10] The cause was that the "needle valves" located in each Reactor Ccolant Pump Seal [11] Injection Line were not properly set. Corrective action was to position the [12] valves such that the controlled leakage was less than the Tech. Spec. limit of [13] 33 gpm and lock these valves into position. This was accomplished within the [14] four hour requirement of Tech. Spec. 3.4.6.2, Action Statement (b).

[15] FACILITY STATUS [B] [28] % POWER [0][0][0] [29] OTHER STATUS [N/A] [30] METHOD OF DISCOVERY [B] [31] DISCOVERY DESCRIPTION [Surveillance Testing] [32]

[16] ACTIVITY CONTENT RELEASED OF RELEASE [Z] [33] AMOUNT OF ACTIVITY [Z] [34] LOCATION OF RELEASE [N/A] [36]

[17] PERSONNEL EXPOSURES NUMBER [0][0][0] [37] TYPE [Z] [38] DESCRIPTION [N/A] [39]

[18] PERSONNEL INJURIES NUMBER [0][0][0] [40] DESCRIPTION [N/A] [41]

[19] LOSS OF OR DAMAGE TO FACILITY TYPE [Z] [42] DESCRIPTION [N/A] [43]

[20] PUBLICITY ISSUED DESCRIPTION [N] [44] [N/A] [45]

8211100344 821105 PDR ADOCK 05000395 S PDR

NRC USE ONLY

NAME OF PREPARER A. R. Koon, Jr.

PHONE: (803) 345-5209