

ID/1Q,1R

CORRECTIVE ACTIONS

<u>340-0</u> Corrective Actions	Rev. 9	10-01-82
<u>340-1</u> Operation During Earthquake Conditions	Rev. 4	05-18-82
<u>340-2</u> Operation During Tornado Warning	Rev. 1	06-20-80
<u>340-3</u> Lock and Dam Number 14 Failure	Rev. 2	02-19-81
<u>340-4</u> Action to be Taken in the Event of an Oil Spill to the Mississippi River	Rev. 3	12-07-81
<u>340-5</u> Station Fire Fighting	Rev. 4	02-18-82
<u>340-6</u> Chlorine Dioxide Spill	Rev. 1	10-01-82
<u>340-S1</u> Fire Drill Worksheet	Rev. 2	10-03-80

APPROVED
OCT 01 1982
Q.C.O.S.N

CHLORINE DIOXIDE SPILL

QEP 340-6
Revision 1
September 1982

ID/5H

A. PURPOSE

The purpose of this procedure is to describe actions to be taken in the event of a chlorine dioxide spill.

B. REFERENCES

1. Occupational Health Guideline for Chlorine Dioxide, September 1978.

C. PREREQUISITES

1. None.

D. PRECAUTIONS

1. None.

E. LIMITATIONS AND ACTIONS

1. Notify Radiation Protection if chlorine dioxide odor is detected.

F. PROCEDURE

1. Persons not wearing protective equipment and clothing should be restricted from areas of spills or leaks until clean-up has been completed.
2. When chlorine dioxide has spilled or is leaking the following steps should be taken:
 - a. Remove all ignition sources.
 - b. Maximize ventilation in area of spill or leak.
 - c. Stop the spill or leak.
 - d. Isolate the area until chlorine dioxide gas is not detectable.

G. CHECKLISTS

1. None.

H. TECHNICAL SPECIFICATION REFERENCES

1. None.

APPROVED
OCT 01 1982
Q.C.O.S.R

ID/2W,2X

EXERCISES AND DRILLS

<u>530-0</u> Exercises and Drills	Rev. 11	10-01-82
<u>530-1</u> Emergency Exercise	Rev. 1	12-16-80
<u>530-2</u> Emergency Drills	Rev. 6	06-07-82
<u>530-3</u> Off-Shift Augmentation Drill	Rev. 2	06-21-82
<u>530-S1</u> Monthly NARS Drill Quad-Cities Station	Rev. 4	10-01-82
<u>530-S2</u> Monthly Test of the NRC Health Physics Network	Rev. 1	01-05-82
<u>530-S3</u> Monthly Test of the NRC Emergency Notification System	Rev. 1	02-17-82

APPROVED
OCT 01 1982
Q.C.O.S.R.

MONTHLY NARS DRILL
QUAD-CITIES STATION

QEP 530-S1
Revision 4
September 1982

ID/3P

DATE: _____

DECLARATION TIME: _____

DIAL 23

MESSAGE: This is a communications test. This is Quad-Cities Nuclear Power Station. Standby for communications drill. The simulated declaration time is _____. The current time is _____. Standby to acknowledge receipt of this communications message by stating your agency and initials.

CALL ROLL:

<u>AGENCY</u>	<u>INITIALS</u>
Illinois Emergency Services and Disaster Agency	_____
Illinois Department of Nuclear Safety	_____
Rock Island Communications	_____
Rock Island E.S.D.A.	_____
Scott County Sheriff	_____
Corporate Command Center	_____
System Power Dispatch	_____
Clinton County EOC	_____
Iowa Office of Disaster Services	_____
Whiteside County EOC	_____
Whiteside County Sheriff	_____

INQUIRE: Has anyone not been called?

RESPONSE:

BACKUP CONTACTS:

<u>AGENCY</u>	<u>TIME</u>
---------------	-------------

COMMENTS:

NAME: _____

APPROVED
OCT 01 1982
Q.C.O.S.R.