



PRAIRIE ISLAND NUCLEAR GENERATING PLANT

Red Wing, Minnesota

UNITS 1 AND 2



INSERVICE INSPECTION - EXAMINATION SUMMARY

AUGUST 29, 1990 TO OCTOBER 2, 1990

REFUELING OUTAGE NUMBER 14

INSPECTION PERIOD 2

SECOND INTERVAL

NORTHERN STATES POWER COMPANY
MINNEAPOLIS, MINNESOTA

Report Date:
October 16, 1990

Commercial Service Date:
December 20, 1974



PRAIRIE ISLAND NUCLEAR GENERATING PLANT

Red Wing, Minnesota

UNITS 1 AND 2



INSERVICE INSPECTION - EXAMINATION SUMMARY

AUGUST 29, 1990 TO OCTOBER 2, 1990

REFUELING OUTAGE NUMBER 14

INSPECTION PERIOD 2

SECOND INTERVAL

NORTHERN STATES POWER COMPANY
MINNEAPOLIS, MINNESOTA

Report Date:
October 16, 1990


Commercial Service Date:
December 20, 1974



PRAIRIE ISLAND NUCLEAR GENERATING PLANT

Red Wing, Minnesota

UNITS 1 AND 2



INSERVICE INSPECTION - EXAMINATION SUMMARY

AUGUST 29, 1990 TO OCTOBER 2, 1990

REFUELING OUTAGE NUMBER 14

INSPECTION PERIOD 2

SECOND INTERVAL

NORTHERN STATES POWER COMPANY
MINNEAPOLIS, MINNESOTA

Report Date:
October 16, 1990

Commercial Service Date:
December 20, 1974

9101110319 910107
PDR ADOCK 05000282
Q PDR

NORTHERN STATES POWER COMPANY

PRAIRIE ISLAND NUCLEAR GENERATING PLANT - UNIT II

INSERVICE INSPECTION - EXAMINATION SUMMARY

AUGUST 29, 1990 TO OCTOBER 2, 1990

REFUELING OUTAGE NUMBER 14

INSPECTION PERIOD 2

SECOND INTERVAL

Report Date:
October 16, 1990

Prepared by: *L.C. Dahlman*
L.C. Dahlman
Sr. M&SP Specialist

Prepared by: *S.A. Redner*
S.A. Redner
Sr. M&SP Specialist

Reviewed by: *Richard A Deopere*
R.A. Deopere
Sr. Lab Specialist

Reviewed by: *J.L. Bridgeman*
J.L. Bridgeman
Sr. M&SP Engineer

Approved by: *J.L. Ricker*
J.L. Ricker
Superintendent,
Materials and Special
Processes

Commercial Service Date:
December 20, 1974

Inservice Inspection - Examination Summary
PRAIRIE ISLAND NUCLEAR GENERATING PLANT - UNIT II
INDEX

- 1.0 INTRODUCTION
- 2.0 SUMMARY OF RESULTS
- 3.0 ASME CLASS 1 AND 2 COMPONENTS
 - 3.1 Examination Plan
 - 3.2 Examination Methods
 - 3.3 Examination Procedures
 - 3.4 Equipment and Materials
 - 3.5 Personnel
 - 3.6 Evaluation
 - 3.7 Examination Reports and Documentation
 - 3.8 Summary of Results
- 4.0 EDDY CURRENT EXAMINATION OF STEAM GENERATOR TUBING

APPENDIX A - ASME Class 1 Examinations

| | |
|----------------------|----------------------------------|
| Inservice Inspection | - Examination Summary Tables: |
| Table S1.1 | - Reactor Vessel |
| Table S1.2 | - Pressurizer |
| Table S1.3 | - Steam Generators |
| Table S1.4.1 | - Regenerative Heat Exchangers |
| Table S1.4.2 | - Excess Letdown Heat Exchanger |
| Table S1.5 | - Piping Pressure Boundary |
| Table S1.6 | - Reactor Core Coolant Pumps |
| Table S1.7 | - Valve Pressure Boundary |
| Table S-II | - Examination Comparison Summary |
| Table III | - Isometric Summary |

APPENDIX B - ASME Class 2 Examinations

| | |
|----------------------|--|
| Inservice Inspection | - Examination Summary Tables: |
| Table S2.1.1 | - Pressure Vessels - Steam Generators |
| Table S2.1.2 | - Pressure Vessels - Accumulators |
| Table S2.1.3 | - Pressure Vessels - PHR Heat Exchangers |
| Table S2.1.4 | - Pressure Vessels - Boric Acid Tanks |
| Table S2.2 | - Piping Pressure Boundary |
| Table S2.3 | - Pumps |
| Table S-II | - Examination Comparison Summary |
| Table III | - Isometric Summary |

APPENDIX C - FSAR AUGMENTED EXAMINATIONS

| | |
|----------------------|----------------------------------|
| Inservice Inspection | - Examination Summary Tables: |
| FSAR | - Piping Pressure Boundary |
| Table S-II | - Examination Comparison Summary |
| Table III | - Isometric Summary |

APPENDIX D - COMPONENT SUPPORTS

Inservice Inspection - Examination Summary Tables:
Table SCS1.1 - ASME Class I Component Supports
Table S-II - Examination Comparison Summary
Table SCS1.2 - ASME Class II Component Supports
Table S-II - Examination Comparison Summary

APPENDIX E -

Table I - Personnel Listing
Table II - Ultrasonic Calibration Blocks
Table III - Procedure Listing
Table IV - Equipment and Materials

APPENDIX F - STEAM GENERATOR NO. 21

Eddy Current Tube Sheet Maps and Cumulative Data Reports

APPENDIX G - STEAM GENERATOR NO. 22

Eddy Current Tube Sheet Maps and Cumulative Data Reports

APPENDIX H - NIS-1 Form

Form NIS-1, Owners' Data Report for Inservice Inspections

INSERVICE INSPECTION - EXAMINATION SUMMARY
PRAIRIE ISLAND NUCLEAR GENERATING PLANT - UNIT 2
August 29, 1990 to October 2, 1990

Form 17 (4/80)

1.0 INTRODUCTION

This report is a summary of the examinations performed during the 14th inservice inspection at the Prairie Island Nuclear Generating Plant - Unit 2. This was the last inspection conducted for inspection period two of the plant's 2nd ten year interval. The examinations were performed during the plant's 14th refueling outage from August 29, 1990 to October 2, 1990. Prairie Island - Unit 2 began commercial operation on December 20, 1974.

This report identifies the components examined, the examination methods used, the examination number, and summarizes the examination results of each of the following areas:

1. Pressure retaining components and supports of the reactor coolant and associated systems classified as ASME Class 1 and ASME Class 2.
2. FSAR Augmented Examinations.
3. Eddy current examination of the Steam Generator Tubing.

2.0 SUMMARY OF RESULTS

The evaluation of all the results from the inservice examinations indicated that the integrity of these systems has been maintained. To assure continued integrity of the steam generators (S.G.), a total of 17 new tubes in S.G. 21 and 18 new tubes in S.G. 22 were mechanically plugged; in addition 6 tubes in S.G. 21 and 23 tubes in S.G. 22 were replugged based on NRC Bulletin 89-01.

3.0 ASME CLASS 1 AND 2 COMPONENTS

3.1 EXAMINATION PLAN

The examination plan focused on the pressure retaining components and their supports of the reactor coolant and associated auxiliary systems classified as ASME Class 1 and ASME Class 2.

The examination plan was based on the examination requirements of the ASME Boiler and Pressure Vessel Code, Section XI, 1980 Edition through and including the Winter 1981 Addenda, and complied with Prairie Island's Technical Specification, Section TS 4.12. The examination is in accordance with the program submitted to the United States Nuclear Regulatory Commission on October 14, 1983 titled, "ASME Code Section XI Inservice Inspection and Testing Program and Information Required for NRC Review of Requests for Relief From ASME Code Section XI Requirements". In addition, the Safety Injection Accumulator Tanks nozzles were examined as the result of Safety Evaluation 232.

3.2 EXAMINATION METHODS

Ultrasonic examination methods and techniques were used to perform the volumetric examinations. The ultrasonic test systems consisted of an ultrasonic digital/analog tester and a video cassette recorder. The video cassette recording takes the digitized signal from the ultrasonic instrument and records both the amplitude and the range information. This approach give a permanent record to the extent possible.

Liquid penetrant or magnetic particle examination methods were used to perform the surface examinations. The liquid penetrant examinations were performed using color contrast-solvent removable materials. Magnetic particle examinations were performed using either a yoke with dry powder or an AC L-10 coil with fluorescent prepared bath.

All visual examinations were aided, when necessary, with artificial lighting and verified for adequacy with an 18% neutral gray card with a 1/32 inch black line.

3.3 EXAMINATION PROCEDURES

The ultrasonic examination procedures for piping welds complied with the requirements of Appendix III of ASME Section XI that was issued in the Winter 1981 Addenda. All other procedures complied with the requirements of the 1980 Edition through and including the Winter 1981 Addenda of ASME Section XI. A listing of the procedures used for the examinations is shown in Table III of Appendix E.

3.4 EQUIPMENT AND MATERIALS

All equipment and expendable materials used in the examinations are listed either by serial number or type along with their respective calibration date or batch number in Table IV of Appendix E.

The ultrasonic calibration standards used in the examinations are listed in Table II of Appendix E. These standards are owned and maintained by NSP at the plant site.

3.5 PERSONNEL

Northern States Power Company contracted Lambert, MacGill, Thomas, Inc. to perform balance of plant examinations. Hartford Steam Boiler Inspection and Insurance Company, representing ANII, provided the Authorized Inspection.

All personnel involved in the performance or evaluation of examinations are listed along with their title, organization and ASNT Level of Certification in Table I of Appendix E.

Certifications for examination personnel are maintained on file by Northern States Power Company.

3.6 EVALUATION

Any indications disclosed in the examinations were evaluated by the examiner at the time, in accordance with the rules of the procedure and ASME Section XI.

The ultrasonic examiner(s) was aided in their evaluation by a calibration performed on a standard reference before each day's examination, checked before and after each individual examination and at intervals not exceeding four (4) hours. In addition, ultrasonic data was recorded on video tape which were made a part of the inspection report, and permitted further evaluation.

3.7 EXAMINATION REPORTS AND DOCUMENTATION

All examination reports and documentation are maintained on file by Northern States Power Company. Table I of Appendices A, B, C and D identifies the examination report number(s) for each item examined. Many of the items identify more than one examination report due to the different types of examinations performed on the item.

Table I of Appendices A, B, C and D summarizes all the examinations performed to date and identifies the amount that will be examined in the future to complete the ten year examination requirements. For retrieval purposes, the prefix of the inspection report number corresponds with the year the inspection was performed. The examination report numbers for this outage are prefixed with "90-".

Table II of Appendices A, B, C and D compares the baseline examination or previous results with the results obtained during this examination. Table III of Appendix A, B, C and D identifies the isometric drawings that were used for the examinations. The personnel, ultrasonic calibration blocks, procedures, equipment and materials that were used for the inspection are identified in the tables of Appendix E. Appendix H contains the Form NIS-1 titled, "Owner's Data Report for Inservice Inspections".

3.8 SUMMARY OF DISCREPANCIES

The following is a list of anomalies detected:

| <u>SYSTEM</u> | <u>ITEM ID</u> | <u>EXAM METHOD</u> | <u>TYPE AND NUMBER OF INDICATIONS</u> |
|-----------------------------------|---|--------------------|---------------------------------------|
| SI PUMP SUCTION | SIH-29/B | VT | NO LOAD SCALE |
| RTD TAKE OFF COLD B | 137-2RTD-2/B | VT | BOLT ENGAGEMENT |
| REATOR VESSEL | W-6 | UT | INCLUSION |
| FEEDWATER A | FWH-68/B FW-136 | MT MT | COLD LAP LINEAR |
| STEAM GENERATOR NO. 21 | COL. 2 PIN W-F | UT UT | LINEAR SLAG INCLUSION |
| STEAM GENERATOR NO. 22 | COL. 3 PIN PAD 4 UPPER RING COL. 2 | UT VT UT | LINEAR LOOSE NUT LINEAR |
| PRESSURIZER SURGE MAIN STEAM A | RCRH-50/F MS-48 MS-56 | VT VT VT | BOTTOMED OUT ARC STRIKE GOUGES |
| MAIN STEAM B | MS-82 MSH-50/A1 MSH-46/C | MT VT MT | LINEARS LOOSE NUT ARC STRIKE |
| RHR TAKE OFF HOT A | 9-2RHR-7/C | VT | FLAME CUT HOLES |
| RHR TAKE OFF HOT B | W-6 | PT | LINEARS |

All anomalies were either corrected or an engineering evaluation was performed to accept "as is" conditions. The PT, MT and VT indication for linears, cold lap, gouges and arc strikes were removed by light hand grinding and blending the area smooth; the loose nuts and bolt engagement were tightened; the hanger with no load scale and the hanger that was bottomed out were evaluated and found acceptable by an engineering evaluation; the hanger with flame cut holes was reworked to remove the HAZ by grinding; some items with linear or inclusion indications were accepted based on Section XI IWB-3514.2.

4.0 EXAMINATION OF THE STEAM GENERATOR TUBING

During the September 1990 scheduled refueling outage 100% of all accessible tubes in steam generator 21 and 22 were examined full length. The examination was conducted utilizing the multifrequency eddy current technique. The program was as follows:

1. Cold leg examinations were performed from the seventh support plate on the hot leg side through the tube end on the cold leg side on rows 2 through 46, row 1 tubes were examined from the seventh support plate on the cold leg side through the tube end on the cold leg side. These examinations were completed using magnetically biased 0.720 inch, 0.700 inch and 0.680 inch diameter bobbin probes.
2. Hot leg examinations were performed from the seventh support plate on the hot leg side through the tube end on the hot leg side. These examinations were completed using magnetically biased 0.720 inch diameter bobbin probes. All row 1 U-Bends were examined from the seventh support plate on the cold leg side through the seventh support plate on the hot leg side using Zetec dual motion MRPC U-Bend probes.

Motorized rotating pancake coil (MRPC) techniques were utilized extensively in both steam generators. The inspection strategy was to: examine all row 1 U-Bends, examine all B&W roll plugs and supplement the bobbin coil data to further characterize: indications of percent through wall, manufacturing burnish marks, undefined indications and distorted indications. The following is a summary of MRPC examinations:

- 91 U-Bends examinations in 21 hot Leg
- 92 U-Bends examinations in 22 hot leg
- 19 B&W roll plugs in 21 hot leg
- 14 B&W roll plugs in 22 cold leg
- 42 supplemental examinations in 21 hot leg
- 15 supplemental examinations in 21 cold leg
- 33 supplemental examinations in 22 hot leg
- 35 supplemental examinations in 22 cold leg

Conam Inspection was contracted to acquire and evaluate the eddy current data. Zetec was contracted to perform a completely independent evaluation of all data acquired by Conam Inspection. The scope of all the work contracted was completed using remote positioning devices and the Zetec MIZ-18 digital test equipment along with associated acquisition software. The analysis was completed using Zetec, Inc. EDDYNET ANALYSIS program revision 1.20 released 9/07/90 and RPC program revision 1.00 released 8/20/90.

Summaries of: total tubes examined, distribution of indications, tubes plugged this outage, and total tubes plugged to date can be found in Tables I through IV respectively.

Tube sheet maps and cumulative listings can be found for plugged tubes and indications by depth range in Appendices F and G.

TABLE I
Total tubes examined

| <u>PROGRAM</u> | <u>TUBE COUNT</u> | <u>PERCENT</u> |
|----------------|-------------------|----------------|
| 21 hot leg | 3326 | 100 |
| 21 cold leg | 3326 | 100 |
| 22 hot leg | *3274 | 100 |
| 22 cold leg | 3253 | 100 |

* Includes 21 tubes tested after hot leg plug removal

TABLE II
Distribution of indications

| <u>INDICATION RANGE</u> | <u>S/G 21</u> | <u>S/G 22</u> |
|-------------------------|---------------|---------------|
| 0% TO 19% | 37 | 43 |
| 20% TO 29% | 45 | 60 |
| 30% TO 39% | 27 | 39 |
| 40% TO 100% | 12 | *39 |

* Includes 21 tubes tested after hot leg plug removal

TABLE III
Tubes plugged this outage

| <u>S/G NO.</u> | <u>ROW - COLUMN</u> | | <u>%TWD</u> | <u>LOCATION</u> |
|----------------|---------------------|----|--------------------|-----------------|
| 21 | 30 | 12 | 45 | 01C - 0.2 |
| 21 | 30 | 13 | 46 | 01C + 0.0 |
| 21 | 32 | 16 | 51 | 01C + 0.0 |
| 21 | 35 | 18 | 65 | 01C + 0.0 |
| 21 | 40 | 25 | 65 | 01C + 0.0 |
| 21 | 45 | 38 | 44 | 02C + 0.0 |
| 21 | 44 | 39 | 55 | 01C - 0.1 |
| 21 | 44 | 53 | NRC Bulletin 89-01 | |
| 21 | 42 | 61 | NRC Bulletin 89-01 | |
| 21 | 37 | 72 | 42 | 01C - 0.2 |
| 21 | 39 | 73 | NRC Bulletin 89-01 | |
| 21 | 36 | 76 | 43 | 02C + 0.0 |
| 21 | 25 | 85 | 44 | 01C - 0.1 |
| 21 | 21 | 88 | NRC Bulletin 89-01 | |
| 21 | 19 | 89 | NRC Bulletin 89-01 | |
| 21 | 14 | 90 | NRC Bulletin 89-01 | |
| 21 | 10 | 91 | 44 | 01C + 0.0 |
| 22 | 29 | 12 | *56 | 01C + 0.0 |
| 22 | 28 | 13 | *49 | 01C + 0.0 |
| 22 | 30 | 14 | *56 | 01C + 0.0 |
| 22 | 31 | 15 | 48 | 01C - 0.2 |
| 22 | 30 | 16 | *56 | 01C + 0.0 |
| 22 | 32 | 16 | 70 | 02C - 0.1 |
| 22 | 33 | 17 | 43 | 01C - 0.1 |
| 22 | 35 | 17 | *63 | 01C + 0.0 |
| 22 | 37 | 22 | 40 | 02C - 0.2 |
| 22 | 39 | 23 | 47 | 01C - 0.1 |
| 22 | 38 | 24 | 54 | 02C - 0.1 |
| 22 | 39 | 24 | *48 | 02C + 0.0 |

TABLE III
CONTINUED

| <u>S/G NO.</u> | <u>ROW - COLUMN</u> | <u>%TWD</u> | <u>LOCATION</u> |
|----------------|---------------------|--------------------|-----------------|
| 22 | 39 25 | *49 | 02C + 0.0 |
| 22 | 40 25 | 45 | 01C + 0.0 |
| 22 | 41 27 | *58 | 02C + 0.0 |
| 22 | 43 36 | *62 | 02C + 0.0 |
| 22 | 43 41 | NRC Bulletin 89-01 | |
| 22 | 45 42 | *50 | 01C + 0.0 |
| 22 | 44 43 | 41 | 02C + 0.0 |
| 22 | 46 45 | *53 | 01C + 0.0 |
| 22 | 44 47 | *79 | 01C + 0.0 |
| 22 | 45 49 | 46 | 01C + 0.0 |
| 22 | 46 49 | *54 | 01C + 0.0 |
| 22 | 45 53 | *43 | 01C + 0.0 |
| 22 | 42 55 | 40 | 01C + 0.0 |
| 22 | 44 55 | 54 | 01C + 0.0 |
| 22 | 45 56 | 47 | 02C + 0.0 |
| 22 | 43 59 | 40 | 02C - 0.1 |
| 22 | 42 61 | *47 | 01C - 0.1 |
| 22 | 39 66 | *53 | 02C - 0.1 |
| 22 | 41 68 | *47 | 02C + 0.0 |
| 22 | 39 70 | 67 | 02C - 0.1 |
| 22 | 38 72 | *51 | 01C + 0.0 |
| 22 | 39 72 | *52 | 02C - 0.2 |
| 22 | 37 73 | 50 | 01C - 0.1 |
| 22 | 38 73 | NRC Bulletin 89-01 | |
| 22 | 39 73 | *48 | 02C - 0.1 |
| 22 | 37 76 | *46 | 02C + 0.1 |
| 22 | 29 83 | 60 | 02C - 0.1 |
| 22 | 23 85 | 51 | 02C + 0.0 |
| 22 | 23 87 | 46 | 01C - 0.1 |

* Tubes tested after plug removal per NRC Bulletin 89-01

TABLE IV
Total tubes plugged to date

| <u>S/G NO.</u> | <u>TUBE COUNT</u> | <u>PERCENT</u> |
|----------------|-------------------|----------------|
| 21 | 73 | 2.15 |
| 22 | 153 | 4.52 |

APPENDIX A
ASME CLASS I EXAMINATIONS

INSERVICE INSPECTION—EXAMINATION SUMMARY

MAJOR ITEM:

| SUB ITEM | EXAM CATEGORY | COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED | INSP. PER. | REQ'D AMT. | AMOUNT EXAM | ITEM IDENTIFICATION | INSPECTION REPORT NO. |
|----------|---------------|--|---------------------|-------------------|-----------------|--|--|
| B1.10 | B-A | <u>PRESSURE RETAINING WELDS IN REACTOR VESSEL</u> | | | | | |
| B1.11 | | <u>CIRCUMFERENTIAL WELD</u> | THREE | 100% | - | W-3 | |
| B1.12 | | <u>LONGITUDINAL</u> | --- | --- | - | -NONE- | |
| B1.20 | B-A | <u>HEAD WELDS</u> | | | | | |
| B1.21 | | <u>CIRCUMFERENTIAL WELD</u> | THREE | 100% | - | W-5 | |
| B1.22 | | <u>MERIDCNAL WELDS</u> | --- | --- | - | -NONE- | |
| B1.30 | B-A | <u>SHELL-TO-FLANGE WELD</u> | | | | | |
| | | <u>VESSEL-TO-FLANGE</u> | ONE THREE | 50% 50% | 50% - | W-1 W-1 | 85-W REPORT |
| B1.40 | B-A | <u>HEAD-TO-FLANGE WELD</u> | | | | | |
| | | <u>HEAD-TO-FLANGE</u> | ONE TWO THREE | 33% 33% 34% | 33% 33% - | W-6 HOLES 1-16 W-6 HOLES 16-32 W-6 | 88-219,223,235, 220,234 90-179,200,201, 202,203 |
| B1.50 | B-A | <u>REPAIR WELDS</u> | --- | --- | --- | -NONE- | |

INSERVICE INSPECTION—EXAMINATION SUMMARY

MAJOR ITEM:

| SUB ITEM | EXAM. CATEGORY | COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED | INSP. PER. | REQ'D AMT. | AMOUNT EXAM. | ITEM IDENTIFICATION | INSPECTION REPORT NO. |
|----------|----------------|---|------------|------------|--------------|---------------------|--|
| B3.90 | B-D | FULL PENETRATION WELDS OF NOZZLE IN VESSEL INSPECTION PROGRAM B | ONE | 2 | 2 | W-7, W-10 | B5-W REPORT |
| B3.100 | B-D | NOZZLE-TO-VESSEL WELD & NOZZLE INSIDE RADIUS SECTION | THREE | 2 | - | | |
| | | REACTOR CORE COOLANT OUTLET NOZZLES | ONE | 1 | - | | |
| | | INLET NOZZLES | THREE | 1 | - | | |
| | | SAFETY INJECTION NOZZLES | ONE | 1 | - | | |
| | B-E | PRESSURE RETAINING PARTIAL PENETRATION WELDS IN VESSELS | | | | | |
| B4.10 | B-E | PARTIAL PENETRATION WELDS | | | | | |
| B4.11 | B-E | VESSEL NOZZLES | | | | | |
| | | HEAD VENT | * | 1 | * | 1-2RC-36 TO 2RC-8-5 | * EACH ITEM INSPECTED BY PLANT PERSONNEL DURING EACH REACTOR VESSEL LEAKAGE TEST |
| B4.12 | B-E | CONTROL ROD DRIVE NOZZLES | ONE | 3 | * | | |
| | | CONTROL ROD DRIVE PENETRATIONS | TWO | 3 | * | | |
| | | | THREE | 4 | * | | * PLANT OPERATIONS |

INSERVICE INSPECTION—EXAMINATION SUMMARY

MAJOR ITEM:

| SUB ITEM | EXAM CATE-GORY | COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED | INSP. PER. | REQ'D AMT. | AMOUNT EXAM | ITEM IDENTIFICATION | INSPECTION REPORT NO. |
|----------|----------------|--|--------------|------------|-------------|------------------------------|--|
| B4.13 | B-E | <u>INSTRUMENTATION NOZZLES</u> | | | | | |
| | | INSTRUMENTATION PENETRATIONS | ONE | 3 | * | | * PLANT OPERATIONS |
| | | | TWO | 3 | * | | |
| | | | THREE | 3 | * | | |
| | B-F | <u>PRESSURE RETAINING DISSIMILAR METAL WELDS</u> | | | | | |
| B5.10 | B-F | <u>NOMINAL PIPE SIZE 4 INCH AND GREATER, NOZZLE-TO-SAFE END BUTT WELDS</u> | | | | | |
| | | OUTLET NOZZLE SAFE END WELDS | ONE | 2 | 2 | RCC-A-1 S.E. RCC-B-1 S.E. | B5-W REPORT/89-164,166 B5-W REPORT/88-162,165 |
| | | INLET NOZZLE SAFE END WELDS | THREE | 2 | - | | |
| | | REACTOR VESSEL SAFETY INJECTION NOZZLE SAFE END WELDS | ONE THREE | 1 1 | 1 - | W-1 S.E. (LOOP B) | B8-161,175,160 |
| B5.20 | B-F | <u>NOMINAL PIPE SIZE LESS THAN 4 INCH</u> | --- | --- | --- | -NONE- | |
| B5.30 | B-F | <u>SOCKET WELDS</u> | --- | --- | --- | -NONE- | |

INSERVICE INSPECTION—EXAMINATION SUMMARY

MAJOR ITEM:

| SUB ITEM | EXAM CATEGORY | COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED | INSP. PER. | REQ'D AMT. | AMOUNT EXAM | ITEM IDENTIFICATION | INSPECTION REPORT NO. |
|----------|---------------|--|------------|------------|-------------|---|---|
| B5.130 | B-F | NOMINAL PIPE SIZE 4 INCH AND GREATER, DISSIMILAR METAL WELDS REACTOR CORE COOLANT | ONE | 2 | 2 | RCC-A-1 S.E. RCC-B-1 S.E. | IN CONJUNCTION WITH B5.10 85-W REPORT/88-164,166 85-W REPORT/88-162,165 |
| | | | TWO | - | - | | |
| | | | THREE | 2 | - | | |
| | | | ONE | 1 | 1 | W-2 S.E. (LOOP B) | 88-163,176,167 |
| | B-G-1 | PRESSURE RETAINING BOLTING, GREATER THAN 2 INCH IN DIAMETER | TWO | - | - | | |
| | | | THREE | 1 | - | | |
| B6.10 | B-G-1 | CLOSURE HEAD NUTS | ONE | 16 | 16 | NUTS 15,18,21,24, 37-48 | 88-250,241 |
| | | | TWO | 16 | 16 | NUTS 17-32 | 90-221,223 |
| | | | THREE | 16 | - | | |
| B6.20 | B-G-1 | CLOSURE STUDS, IN PLACE | --- | --- | --- | -NONE- (SEE B6.30) | |
| B6.30 | B-G-1 | CLOSURE STUDS, WHEN REMOVED | ONE | 16 | 16 | STUDS 15,18,21, 24,37-48 | 88-254,253,257 |
| | | | TWO | 16 | 16 | STUDS 17-32 | 90-222,244,224 |
| | | | THREE | 16 | - | | |
| B6.40 | B-G-1 | THREADS IN FLANGE | ONE | 24 | 27 | 9 THRU 22, 29 THRU 37, 43 THRU 46 | 85-W REPORT |
| | | | TWO | - | - | | |
| | | | THREE | 24 | - | | |

INSERVICE INSPECTION—EXAMINATION SUMMARY

MAJOR ITEM:

| SUB ITEM | EXAM CATE-GORY | COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED | INSP. PER. | REQ'D AMT. | AMOUNT EXAM | ITEM IDENTIFICATION | INSPECTION REPORT NO. |
|----------|----------------|--|------------|------------|-------------|----------------------------|-----------------------|
| B6.50 | B-G-1 | <u>CLOSURE WASHERS, BUSHINGS</u> | | | | | |
| | | WASHERS (PAIRS) | ONE | 16 | 16 | WASHERS 15,18,21, 24,37-48 | 88-256 |
| | | | TWO | 16 | 16 | WASHERS 17-32 | 90-225 |
| | | | THREE | 16 | - | | |
| | | BUSHINGS | --- | --- | --- | -NONE- | |
| | B-G-2 | <u>PRESSURE RETAINING BOLTING, 2 INCHES AND LESS IN DIAMETER</u> | | | | | |
| B7.10 | B-G-2 | <u>BOLTS, STUDS, AND NUTS</u> | | | | | |
| | | CONOSEAL | ONE | 3 | 3 | CLAMP @ 120° | 88-224 |
| | | | TWO | 3 | 3 | CLAMP @ 240° | 90-328 |
| | | | THREE | 3 | - | | |
| B7.80 | B-G-1 | <u>BOLTS, STUDS, AND NUTS</u> | --- | --- | --- | -NONE- | |
| | B-H | <u>INTEGRAL ATTACHMENTS FOR VESSELS</u> | | | | | |
| B8.10 | B-H | <u>INTEGRALLY WELDED ATTACHMENTS</u> | THREE | 2 | - | | |

INSERVICE INSPECTION—EXAMINATION SUMMARY

| SUB ITEM | EXAM CATE-GORY | COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED | INSP. PER. | REQ'D AMT. | AMOUNT EXAM | ITEM IDENTIFICATION | INSPECTION REPORT NO. |
|----------|----------------|--|---------------------|------------|-------------|--|-----------------------|
| B13.10 | B-N-1 | <u>INTERIOR OF REACTOR VESSEL</u> | ONE TWO THREE | * | * | UPPER INTERNALS | 88-248 |
| | B-N-1 | <u>VESSEL INTERIOR</u> UPPER INTERNALS, LOWER INTERNALS, THERMAL SHIELD, FIXTURES, DRIVE RODS | | * | * | | |
| B13.20 | B-N-2 | <u>INTEGRALLY WELDED CORE SUPPORT STRUCTURES AND INTERIOR ATTACHMENTS TO REACTOR VESSEL</u> | - | - | - | * REPRESENTATIVE REGIONS OF THOSE INTERIOR SURFACES AND INTERNALS MADE ACCESSIBLE BY THE REMOVAL OF COMPONENTS DURING NORMAL REFUELING OPERATIONS. | |
| | B-N-2 | <u>INTERIOR ATTACHMENTS AND CORE SUPPORT STRUCTURES</u> | | | | | |
| B13.32 | B-N-3 | <u>REMOVABLE CORE SUPPORT STRUCTURES</u> | THREE | * | - | * 100% OF THE ACCESSIBLE ATTACHMENT WELDS AND VISUALLY ACCESSIBLE SURFACES OF THE SUPPORT STRUCTURE. | |
| | B-N-3 | <u>CORE SUPPORT STRUCTURES</u> | | | | | |

MAJOR ITEM:

| SUB ITEM | EXAM CATEGORY | COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED | INSP. PER. | REQ'D AMT. | AMOUNT EXAM | ITEM IDENTIFICATION | INSPECTION REPORT NO. |
|----------|---------------|--|------------|------------|-------------|---|--|
| B14.10 | B-0 | <u>PRESSURE RETAINING WELDS IN CONTROL ROD HOUSINGS</u> | | | | | |
| | B-0 | <u>WELDS IN CRD HOUSINGS</u> | | | | | |
| | | PERIPHERAL CRD HOUSINGS | ONE | - | 4 | (BASELINE) W-5 (BASELINE) W-2 (BASELINE) I-1743 (BASELINE) H-5708 (BASELINE) 15 UPPER | 85-107,118 85-096,097 85-003,006 85-004,005 89-043,044,C42,045 |
| | | TWO | - | 1 | | | |
| | | | THREE | 2 | - | | |
| | B-P | <u>ALL PRESSURE RETAINING COMPONENTS</u> | | | | | |
| B15.10 | B-P | <u>PRESSURE RETAINING BOUNDARY</u> | * | - | - | | * PERFORMED BY PLANT PERSONNEL IN ACCORDANCE WITH IWA-5000 DURING EACH SYSTEM LEAKAGE TEST AND EACH SYSTEM HYDROSTATIC TEST REQUIRED BY IWB-5000 |
| B15.11 | B-P | <u>PRESSURE RETAINING BOUNDARY</u> | * | - | - | | |

INSERVICE INSPECTION—EXAMINATION SUMMARY

MAJOR ITEM:

| SUB ITEM | EXAM CATEGORY | COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED | INSP. PER. | REC'D AMT. | AMOUNT EXAM | ITEM IDENTIFICATION | INSPECTION REPORT NO. |
|----------|---------------|---|------------|------------|-------------|---------------------|-----------------------|
| B2.10 | B-B | <u>PRESSURE RETAINING WELDS IN VESSELS OTHER THAN REACTOR VESSELS</u> | | | | | |
| | | <u>PRESSURIZER</u> | | | | | |
| | | <u>SHELL-TO-HEAD WELDS</u> | | | | | |
| | | WELD 3 | ONE | 33% | 33% | W-3 (0'-8') | 86-248,259,261,263 |
| | | | TWO | 34% | 33% | W-3 (6'6"-14'6") | 89-367,366,365,334 |
| | | | THREE | 33% | - | | |
| B2.11 | B-B | <u>CIRCUMFERENTIAL</u> | | | | | |
| | | WELD 4 | ONE | - | - | | |
| | | | TWO | 50% | 50% | W-4 (0'-12') | 90-175,176,177,178 |
| | | THREE | 50% | - | | | |
| B2.12 | B-B | <u>LONGITUDINAL</u> | | | | | |
| | | WELD NO 1 | ONE | 10% | 10% | W-1 @ W-5 (0'-1') | 86-247,260,262,264 |
| B2.20 | B-B | <u>HEAD WELDS</u> | | | | | |
| | | WELD NO 2 | TWO | 10% | 10% | W-1 @ W-3 (0'-1') | 89-380,381,382,333 |
| | | | --- | --- | --- | -NONE- | |

P22S -2

INSERVICE INSPECTION—EXAMINATION SUMMARY

| SUB ITEM | EXAM CATEGORY | COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED | INSP. PER. | REQ'D AMT. | AMOUNT EXAM | ITEM IDENTIFICATION | INSPECTION REPORT NO. |
|----------|---------------|--|------------|------------|-------------|---------------------|--|
| B3.110 | B-D | <u>FULL PENETRATION WELDS OF NOZZLES IN VESSELS - INSPECTION PROGRAM B</u> | --- | --- | --- | -NONE- | |
| B3.120 | B-D | <u>NOZZLE TO VESSEL WELDS</u> | --- | --- | --- | | |
| | B-D | <u>NOZZLE INSIDE RADIUS SECTION</u> | --- | --- | --- | | |
| | B-D | <u>SPRAY NOZZLE</u> | ONE | 1 | * | | * RELIEF NO 66 |
| | B-D | <u>RELIEF NOZZLE</u> | TWO | 1 | * | | |
| | B-D | <u>SAFETY NOZZLE A</u> | TWO | 1 | * | | |
| | B-D | <u>SAFETY NOZZLE B</u> | THREE | 1 | * | | |
| | B-D | <u>SURGE NOZZLE</u> | THREE | 1 | * | | |
| B4.20 | B-E | <u>PRESSURE RETAINING PARTIAL PENETRATION WELDS IN VESSEL</u> | * | 21/10 YRS | * | | * EACH ITEM INSPECTED BY PLANT PERSONNEL |
| | B-E | <u>HEATER PENETRATION WELDS</u> | * | | * | | |
| B5.40 | B-F | <u>PRESSURE RETAINING DISSIMILAR METAL WELDS</u> | | | | | |
| | B-F | <u>NOMINAL PIPE SIZE 4 INCH AND GREATER, NOZZLE-TO-SAFE END BUTT WELDS</u> | | | | | |
| | B-F | <u>SAFETY LINE</u> | ONE | 2 | 2 | W-1A S.E. (8010A) | 88-072,090,077 |
| | B-F | <u>SURGE LINE</u> | TWO | 1 | 1 | W-1A S.E. (8010B) | 88-073,089,078 |
| | B-F | <u>RELIEF LINE</u> | THREE | 1 | 1 | W-15 S.E. | 89-103,210,161 |
| | B-F | <u>SPRAY LINE</u> | THREE | 1 | 1 | | RELIEF NO. 56 |

1" SERVICE INSPECTION—EXAMINATION SUMMARY

MAJOR ITEM:

| SUB ITEM | EXAM CATEGORY | COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED | INSP. PER. | REQ'D AMT. | AMOUNT EXAM | ITEM IDENTIFICATION | INSPECTION REPORT NO. |
|----------|---------------|---|---------------------|-------------------|-----------------|-----------------------------------|----------------------------------|
| B5.50 | B-F | NOMINAL PIPE SIZE LESS THAN 4 INCH | --- | --- | --- | -NONE- | |
| B5.60 | B-F | SOCKET WELDS | --- | --- | --- | -NONE- | |
| | B-G-1 | PRESSURE RETAINING BOLTING, GREATER THAN 2 INCHES IN DIAMETER | --- | --- | --- | -NONE- | |
| | B-G-2 | PRESSURE RETAINING BOLTING, 2 INCHES AND LESS IN DIAMETER | | | | | |
| B7.20 | B-G-2 | BOLTS, STUDS, AND NUTS | | | | | |
| | | MANWAY BOLTS | ONE TWO THREE | 5 5 6 | 5 5 - | BOLTS 1-5 BOLTS 6-10 | 85-138 90-400 |
| | B-H | INTEGRAL ATTACHMENTS FOR VESSELS | | | | | |
| B8.20 | B-H | INTEGRALLY WELDED ATTACHMENTS | | | | | |
| | | SUPPORT SKIRT | ONE TWO THREE | 33% 33% 34% | 33% 33% - | W-6 (24"-120") W-6 (120"-216") | 86-249,254,265 90-330,329,187 |

P225 -2

INSERVICE INSPECTION—EXAMINATION SUMMARY

MAJOR ITEM:

| SUB ITEM | EXAM CATEGORY | COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED | INSP. PER. | REQ'D AMT. | AMOUNT EXAM | ITEM IDENTIFICATION | INSPECTION REPORT NO. |
|------------------|-------------------|--|------------|------------|-------------|---------------------|---|
| B15.20 B15.21 | B-P B-P B-P | <u>ALL PRESSURE RETAINING COMPONENTS</u> <u>PRESSURIZER RETAINING BOUNDARY</u> <u>PRESSURIZER RETAINING BOUNDARY</u> | * | | | | * PERFORMED BY PLANT PERSONNEL IN ACCORDANCE WITH IWA-5000 DURING EACH SYSTEM |

INSERVICE INSPECTION—EXAMINATION SUMMARY

MAJOR ITEM:

| SUB ITEM | EXAM CATEGORY | COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED | INSP. PER. | REQ'D AMT. | AMOUNT EXAM | ITEM IDENTIFICATION | INSPECTION REPORT NO. |
|----------|---------------|---|---------------------|-------------------|-----------------|---------------------------------|--|
| | B-B | <u>PRESSURE RETAINING WELDS IN OTHER THAN REACTOR VESSELS</u> | | | | | |
| B2.30 | B-B | <u>HEAD WELDS</u> | | | | -NONE- | |
| B2.40 | B-B | <u>TUBESHEET-TO-HEAD WELDS</u> | | | | | |
| | | STEAM GENERATOR NO. 21 W-A | ONE TWO THREE | 33% 34% 33% | 33% 33% - | W-A (0'-12') W-A (12'-23'3") | 88-209,210,211,204 90-395,396,397,399 |
| | | STEAM GENERATOR NO. 22 W-A | ONE TWO THREE | 33% 34% 33% | 33% 33% - | W-A(0'-12') W-A (12'-22'3") | 86-243,244,245,246 89-371,368,364,301 |
| | B-D | <u>FULL PENETRATION WELDS OF NOZZLE IN VESSELS - INSPECTION PROGRAM B</u> | | | | | |
| B3.130 | B-D | <u>NOZZLE TO VESSEL WELDS</u> | | | | -NONE- | |
| B3.140 | B-D | <u>NOZZLE INSIDE RADIUS SECTION</u> | | | | | |
| | | STEAM GENERATOR NO. 21 INLET NOZZLE OUTLET NOZZLE | ONE THREE | 1 1 | *- *- | | * RELIEF NO. 66 |
| | | STEAM GENERATOR NO. 22 INLET NOZZLE OUTLET NOZZLE | THREE TWO | 1 1 | *- *- | | * RELIEF NO. 66 |

P22S-3

INSERVICE INSPECTION—EXAMINATION SUMMARY

MAJOR ITEM:

| SUB ITEM | EXAM CATE-GORY | COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED | INSP. PER. | REQ'D AMT. | AMOUNT EXAM | ITEM IDENTIFICATION | INSPECTION REPORT NO. |
|----------|----------------|--|--------------|------------|-------------|------------------------------|-----------------------------------|
| B5.70 | B-F | <u>PRESSURE RETAINING DISSIMILAR METAL WELDS</u> | | | | | |
| | B-F | <u>NOMINAL PIPE SIZE 4" AND GREATER, NOZZLE-TO-SAFE END BUTT WELDS</u> | | | | | |
| | | STEAM GENERATOR NO. 21 INLET OUTLET | ONE THREE | 1 1 | 1 - | RCC-A-5 S.E. | 88-196,236,197,238 |
| | | STEAM GENERATOR NO. 22 INLET OUTLET | ONE ONE | 1 - | 1 1 | RCC-B-4 S.E. RCC-B-5 S.E. | 86-204,207,278, 86-206,209,276 |
| | | | TWO THREE | - 1 | 1 - | RCC-B-5 S.E. | 257,258 90-232,299,293 |
| B5.80 | B-F | <u>NOMINAL PIPE SIZE LESS THAN 4"</u> | - | - | - | -NONE- | |
| B5.90 | B-F | <u>SOCKET WELDS</u> | - | - | - | -NONE- | |
| | B-G-1 | <u>PRESSURE RETAINING BOLTING GREATER THAN 2" IN DIAMETER</u> | - | - | - | -NONE- | |
| | B-G-2 | <u>PRESSURE RETAINING BOLTING, 2" AND LESS IN DIAMETER</u> | | | | | |

P225 -3

| SUB ITEM | EXAM CATEGORY | COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED | INSP. PER. | REQ'D AMT. | AMOUNT EXAM | ITEM IDENTIFICATION | INSPECTION REPORT NO. | |
|----------|---------------|---|---------------|------------|-------------|---------------------|--|--|
| B7.30 | B-G-2 | BOLTS, STUDS AND NUTS STEAM GENERATOR NO. 21 INLET MANWAY | ONE | 5 | 48 | INLET MANWAY 1-16 | 85-027,030,105 86-127,131,128,162 88-105,100,113 | |
| | | | TWO | 5 | 32 | INLET MANWAY 1-16 | 89-145,198,092 90-233,261,251 | |
| | | | THREE | 6 | - | | | |
| | | | OUTLET MANWAY | ONE | 5 | 48 | OUTLET MANWAY 1-16 | 85-028,030 86-132,161,163 88-104,098,112 |
| | | | | TWO | 5 | 32 | OUTLET MANWAY 1-16 | 89-146,197,093 90-234,262,252 |
| | | | | THREE | 6 | - | | |
| | | STEAM GENERATOR NO. 22 INLET MANWAY | ONE | 5 | 48 | INLET MANWAY 1-16 | 85-026,031 86-133,164,129 88-099,115,107 | |
| | | | TWO | 5 | 32 | INLET MANWAY 1-16 | 89-147,200,094 90-235,264,253 | |
| | | | THREE | 6 | - | | | |
| | | | OUTLET MANWAY | ONE | 5 | 47 | OUTLET MANWAY 1-16 | 85-025,031 86-130,134,165 88-097,114,106 |
| | | | | TWO | 5 | 32 | OUTLET MANWAY 1-16 | 89-148,199,095 90-236,263,254 |
| | | | | THREE | 6 | - | | |

INSERVICE INSPECTION—EXAMINATION SUMMARY

MAJOR ITEM: _____

| SUB ITEM | EXAM CATEGORY | COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED | INSP. PER. | REQ'D AMT. | AMOUNT EXAM | ITEM IDENTIFICATION | INSPECTION REPORT NO. |
|----------|---------------|--|------------|------------|-------------|---------------------|--|
| | B-H | <u>INTEGRAL ATTACHMENTS FOR VESSELS</u> | - | - | - | -NONE- | |
| | B-P | <u>ALL PRESSURE RETAINING COMPONENTS</u> | | | | | |
| B15.30 | B-P | <u>PRESSURE RETAINING BOUNDARY</u> | * | - | - | | * PERFORMED BY PLANT PERSONNEL IN ACCORDANCE WITH IWA-5000 DURING EACH SYSTEM LEAKAGE TEST AND EACH SYSTEM HYDROSTATIC TEST REQUIRED BY IWB-5000 |
| B15.31 | B-P | <u>PRESSURE RETAINING BOUNDARY</u> | * | - | - | | |

P22S -3

| SUB ITEM | EXAM CATE-GORY | COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED | INSP. PER. | REQ'D AMT. | AMOUNT EXAM | ITEM IDENTIFICATION | INSPECTION REPORT NO. |
|----------|----------------|---|------------|------------|-------------|---------------------|-----------------------|
| 82.60 | B-B | PRESSURE RETAINING WELDS IN OTHER THAN REACTOR VESSELS | ONE | 100% | 1 | W-1 | RELIEF NO. 45 |
| | B-B | TUBESHEET-TO-HEAD WELDS | TWO | 100% | - | W-2 | 86-111,138 |
| | | EXCHANGER A | THREE | 100% | - | | 90-072,052 |
| | B-D | FULL PENETRATION WELDS OF NOZZLES IN VESSELS - INSPECTION PROGRAM B | - | - | - | -NONE- | |
| 83.150 | B-D | NOZZLE TO VESSEL WELDS | - | - | - | -NONE- | |
| 83.160 | B-I | NOZZLE INSIDE RADIUS SECTION | - | - | - | -NONE- | |
| | | EXCHANGER A | ONE | 2 | * | | * RELIEF NO. 66 |
| | | EXCHANGER B | TWO | 2 | * | | |
| | | EXCHANGER C | THREE | 2 | * | | |
| 86.120 | B-G-1 | PRESSURE RETAINING BOLTING, GREATER THAN 2" IN DIAMETER | - | - | - | -NONE- | |
| 87.40 | B-G-2 | PRESSURE RETAINING BOLTING, 2" AND LESS IN DIAMETER | - | - | - | -NONE- | |
| 88.40 | B-H | INTEGRAL ATTACHMENTS FOR VESSELS | - | - | - | -NONE- | |

INSERVICE INSPECTION—EXAMINATION SUMMARY

MAJOR ITEM:

| SUB ITEM | EXAM CATE- GORY | COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED | INSP. PER. | REQ'D AMT. | AMOUNT EXAM | ITEM IDENTIFICATION | INSPECTION REPORT NO. |
|-------------|-----------------------|--|---------------|---------------|----------------|------------------------|--|
| | B-P | <u>ALL PRESSURE RETAINING COMPONENTS</u> | | | | | |
| B15.40 | B-P | <u>PRESSURE RETAINING BOUNDARY</u> | * | - | - | | * PERFORMED BY PLANT PERSONNEL IN ACCORD- ANCE WITH IWA-5000 DURING EACH SYSTEM LEAKAGE TEST AND EACH SYSTEM HYRO- STATIC TEST REQUIRED BY IWB-5000 |
| B15.41 | B-P | <u>PRESSURE RETAINING BOUNDARY</u> | * | - | - | | |

P225-41

INSERVICE INSPECTION—EXAMINATION SUMMARY

| SUB ITEM | EXAM CATEGORY | COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED | INSP. PER. | REQ'D AMT. | AMOUNT EXAM | ITEM IDENTIFICATION | INSPECTION REPORT NO. |
|----------|---------------|--|---------------------|-------------|-------------|---------------------|-----------------------|
| B2.50 | B-B | <u>PRESSURE RETAINING WELDS IN VESSELS OTHER THAN REACTOR VESSELS</u> | | | | | |
| B2.51 | B-B | <u>HEAD WELDS</u> | | | | | RELIEF NO. 45 |
| | B-B | <u>CIRCUMFERENTIAL</u> | ONE TWO THREE | - 1 - | - 1 - | W-1 | 90-073,063 |
| | B-D | <u>FULL PENETRATION WELDS OF NOZZLES IN VESSELS - INSPECTION PROGRAM B</u> | | | | | |
| B3.150 | B-D | <u>NOZZLE TO VESSEL WELDS</u> | --- | --- | --- | -NONE- | RELIEF NO. 67 |
| B3.160 | B-D | <u>NOZZLE INSIDE RADIUSED SECTION</u> | --- | --- | --- | -NONE- | RELIEF NO. 66 |
| | B-F | <u>PRESSURE RETAINING DISSIMILAR METAL WELDS</u> | --- | --- | --- | -NONE- | |

P22S-42

NORTHERN STATES POWER CO. 2
 PRAIRIE ISLAND UNIT
 INSERVICE INSPECTION—EXAMINATION SUMMARY

| SUB ITEM | EXAM CATEGORY | COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED | INSP. PER. | REQ'D AMT. | AMOUNT EXAM | ITEM IDENTIFICATION | INSPECTION REPORT NO. |
|----------|---------------|--|---------------------|-------------|-------------|--------------------------------------|---|
| B7.40 | B-G-1 | <u>PRESSURE RETAINING BOLTING, GREATER THAN 2 INCH IN DIAMETER</u> | | | | | |
| | B-G-2 | <u>PRESSURE RETAINING BOLTING, 2 INCHES AND LESS IN DIAMETER</u> | | | | | |
| | B-G-2 | <u>BOLTS, STUDS AND NUTS</u> EXCESS LETDOWN | ONE TWO THREE | 4 4 4 | 4 4 - | FLANGE BOLTS 1-4 FLANGE BOLTS 5-8 | 86-112 90-108 |
| | B-H | <u>INTEGRAL ATTACHMENTS FOR VESSELS</u> | --- | --- | --- | -NONE- | |
| | B-P | <u>ALL PRESSURE RETAINING COMPONENTS</u> | | | | | |
| B15.40 | B-P | <u>PRESSURE RETAINING BOUNDARY</u> | * | - | - | | * PERFORMED BY PLANT PERSONNEL IN ACCORDANCE WITH IWA-5000 DURING EACH SYSTEM LEAKAGE TEST AND EACH SYSTEM HYDROSTATIC TEST REQUIRED BY IWB-5000. |
| B15.41 | B-P | <u>PRESSURE RETAINING BOUNDARY</u> | * | - | - | | |

| SUB ITEM | EXAM CATE-GORY | COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED | INSP. PER. | REQ'D AMT. | AMOUNT EXAM | ITEM IDENTIFICATION | INSPECTION REPORT NO. |
|----------|-----------------------------|---|------------|------------|------------------------------|--|--|
| B5.130 | B-F | <u>PRESSURE RETAINING DISSIMILAR METAL WELDS</u> | | | | | |
| | B-F | <u>NOMINAL PIPE SIZE 4 INCH AND GREATER, DISSIMILAR METAL WELDS</u> | | | | | |
| | | <u>REACTOR VESSEL</u> | | | | | |
| | | REACTOR CORE COOLANT SYSTEMS | ONE | 2 | 2 | RCC-A-1 S.E. RCC-B-1 S.E. | 85-W REPORT 88-164,166 85-W REPORT 88-162,165 |
| | | | TWO THREE | - | - | | |
| | | REACTOR VESSEL SAFETY INJECTION SYSTEMS | ONE THREE | 1 | 1 | W-2 S.E. (LOOP B) | 88-163, 176,167 |
| | | <u>STEAM GENERATORS</u> | | | | | |
| | | STEAM GENERATOR NO 21 | | | | | |
| | | REACTOR CORE COOLANT SYSTEM | ONE THREE | 1 | 1 | RCC-A-5 S.E. | 88-196,236,197,238 |
| | | STEAM GENERATOR NO 22 | | | | | |
| | REACTOR CORE COOLANT SYSTEM | ONE | - | 2 | RCC-B-4 S.E. RCC-B-5 S.E. | 86-205,208,277 86-206,209,257,258,276 | |
| | | TWO THREE | - | 1 | RCC-B-5 S.E. | 90-074,298,281 | |

P22S -5

INSERVICE INSPECTION—EXAMINATION SUMMARY

MAJOR ITEM:

| SUB ITEM | EXAM CATE-GORY | COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED | INSP. PER. | REQ'D AMT. | AMOUNT EXAM | ITEM IDENTIFICATION | INSPECTION REPORT NO. |
|----------|----------------|--|------------|------------|-------------|---------------------|-----------------------|
| | | <u>PRESSURIZER</u> | | | | | |
| | | SAFETY LINE | ONE | 2 | 2 | W-1 (8010A) | 88-071,088,075 |
| | | SURGE LINE | TWO | 1 | 1 | W-1 (8010B) | 88-074,087,079 |
| | | RELIEF LINE | THREE | 1 | - | W-15 | 89-104,211,162 |
| | | SPRAY LINE | THREE | 1 | - | | |
| 85.140 | B-F | <u>NOMINAL PIPE SIZE LESS THAN 4 INCH</u> | --- | --- | --- | -NONE- | |
| 85.150 | B-F | <u>SOCKET WELDS</u> | --- | --- | --- | -NONE- | |
| 86.150 | B-G-1 | <u>PRESSURE RETAINING BOLTING, GREATER THAN 2 INCH IN DIAMETER</u> | --- | --- | --- | -NONE- | |
| | B-G-2 | <u>PRESSURE RETAINING BOLTING, 2 INCHES AND LESS IN DIAMETER</u> | | | | | |
| 87.50 | B-G-2 | <u>BOLTS, STUDS, AND NUTS</u> | | | | | |
| | | SEAL INJECTION | ONE | 4 | 4 | ORIFICE BOLTS @W-5 | 86-238 |
| | | | TWO | 4 | 8 | ORIFICE BOLTS @W-2 | 89-181 |
| | | | THREE | 4 | - | ORIFICE BOLTS @W-4 | 90-157 |
| | | RESISTANCE TEMPERATURE DETECTOR RETURN | ONE | - | 8 | ORIFICE BOLTS @W-7 | 86-241 |
| | | | THREE | 8 | - | | |
| | | | THREE | 8 | - | | |

P225 -5

INSERVICE INSPECTION—EXAMINATION SUMMARY

MAJOR ITEM:

| SUB ITEM | EXAM CATEGORY | COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED | INSP. PER. | REQ'D AMT. | AMOUNT EXAM | ITEM IDENTIFICATION | INSPECTION REPORT NO. |
|---------------|---------------|--|---------------------|-------------|-------------|---|-----------------------|
| B7.50 | B-G-2 | (CONTINUED) | | | | | |
| | | PRESSURIZER RELIEF | ONE | 12 | 12 | FLANGE BOLTS @ 2-8010B | 86-078 |
| | | PRESSURIZER SAFETY | TWO | 12 | 12 | FLANGE BOLTS @ 2-8010A | 90-186 |
| | B-J | <u>PRESSURE RETAINING WELDS IN PIPING</u> | | | | | |
| B9.10 | B-J | <u>NOMINAL PIPE SIZE 4 INCH AND GREATER</u> | | | | | |
| B9.11 & B9.12 | B-J B-J | <u>CIRCUMFERENTIAL AND LONGITUDINAL WELDS</u> | | | | | |
| | B-J | <u>LONGITUDINAL WELDS</u> | --- | --- | --- | -NONE- | |
| | B-J | <u>CIRCUMFERENTIAL WELDS (4.0 IN. NOM. DIA. SYSTEMS)</u> | | | | | |
| | | REACTOR VESSEL SAFETY INJECTION LOW HEAD A | ONE TWO THREE | 1 - - | 1 - - | W-2 | 85-086,073 |
| | | REACTOR VESSEL SAFETY INJECTION LOW HEAD B | ONE TWO THREE | - - 1 | - - - | SOME OF THESE WELDS ARE ACCESSIBLE; OTHERS ARE LOCATED WITHIN THE CONCRETE SHIELD WALL. | |

P2251-5

MAJOR ITEM:

| SUB ITEM | EXAM CATE-GORY | COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED | INSP. PER. | REQ'D AMT. | AMOUNT EXAM | ITEM IDENTIFICATION | INSPECTION REPORT NO. |
|---------------|----------------|--|---------------------|-------------|-------------|---------------------------------|--|
| B9.11 & B9.12 | B-J | (CONTINUED) (6.0 IN. NOM. DIA. SYSTEMS) | | | | | |
| | | REACTOR VESSEL SAFETY INJECTION LOW HEAD A | ONE TWO THREE | - 1 1 | - 1 - | W-8 | 89-344,401,396 |
| | | REACTOR VESSEL SAFETY INJECTION LOW HEAD B | ONE TWO THREE | 1 - 1 | 1 - - | W-7 | 86-043,044,095 |
| | | SAFETY INJECTION HIGH HEAD LOOP A | ONE TWO THREE | - - 1 | - - - | W-2 | 85-066, 075 |
| | | SAFETY INJECTION HIGH HEAD LOOP B | ONE TWO THREE | - - - | 1 - - | W-6 | 86-071,071R,072,072R, 096 |
| | | PRESSURIZER SAFETY LINE A | ONE TWO THREE | 1 3 1 | 1 3 - | W-4 W-5 W-2 | 89-215,273,218 89-216,272,219 90-246,312,255 |
| | | PRESSURIZER SAFETY LINE B | ONE TWO THREE | 2 1 1 | 3 2 - | W-3 W-5 W-6 W-7 W-8 | 86-063,064,093 86-080,082,139 86-079,081,094 90-248,311,256 90-249,257 (NO UT) |

INSERVICE INSPECTION—EXAMINATION SUMMARY

MAJOR ITEM:

| SUB ITEM | EXAM CATEGORY | COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED | INSP. PER. | REQ'D AMT. | AMOUNT EXAM | ITEM IDENTIFICATION | INSPECTION REPORT NO. | |
|---------------|---------------|--|---------------------------------|-------------------------|-------------------------|---|--|--|
| B9.11 & B9.12 | B-J | (CONTINUED) | | | | | | |
| | | PLO-CAP LOOP A | ONE TWO THREE | - - 1 | 1 - - | W-1 | 85-103 | |
| | | PLO-CAP LOOP B | ONE TWO THREE | - 1 - | - 1 - | W-1 | 89-332,400,318 | |
| | | (8.0 IN. NOM. DIA. SYSTEMS) | | | | | | |
| | | RESIDUAL HEAT REMOVAL TAKE OFF LOOP A | ONE TWO THREE | 2 3 3 | 2 5 - | W-17, 24 W-13 W-25 W-1 W-4 W-5 | 85-017,018,048,049 89-252,336,239 89-292,337,240 90-331,407,341 90-339,408,350 90-340,409,351 | |
| | | RESIDUAL HEAT REMOVAL TAKE OFF LOOP B | ONE TWO THREE | 3 2 3 | 3 6 - | W-2 W-18 W-23 W-1 W-5 W-5A W-6 W-9 W-13 | 86-235,236,237 86-147,166,183 86-148,150,171 90-374,410,353 90-375,411,354 90-376,412,355 90-377,413,356 90-149 (PT ONLY) 90-180,185,181 | |

P22S -5

INSERVICE INSPECTION—EXAMINATION SUMMARY

MAJOR ITEM:

| SUB ITEM | EXAM CATEGORY | COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED | INSP. PER. | REQ'D AMT. | AMOUNT EXAM | ITEM IDENTIFICATION | INSPECTION REPORT NO. |
|---------------|---------------|--|------------|------------|-------------|---------------------|-----------------------|
| B9.11 & B9.12 | B-J | (CONTINUED) | | | | | |
| | | (10.0 IN. NOM. DIA. SYSTEMS) | | | | | |
| | | RESIDUAL HEAT REMOVAL RETURN LOOP B | ONE | 1 | 1 | W-4 | 86-146,149,182 |
| | | | TWO | 1 | 1 | W-2 | 89-293,393,254 |
| | | | THREE | 1 | - | | |
| | | PRESSURIZER SURGE LOOP B | ONE | 1 | 1 | W-8 | 86-212,213,221 |
| | | | TWO | 1 | 1 | W-3 | 89-137,194,173 |
| | | | | | 13 | W-14 | 89-105,212,163 |
| | | | | | | W-13 | 89-101,213,176 |
| | | | | | | W-12 | 89-098,204,164 |
| | | | | | | W-11 | 89-099,205,165 |
| | | | | | | W-10 | 89-106,206,166 |
| | | | | | | W-9 | 89-107,208,167 |
| | | | | | | W-8 | 89-108,207,168 |
| | | | | | | W-7 | 89-102,209,169 |
| | | | | | | W-6 | 89-100,191,170 |
| | | | | | | W-5 | 89-136,192,171 |
| | | | | | | W-4 | 89-139,195,172 |
| | | | | | | W-2 | 89-138,193,174 |
| | | | | | | W-1 | 89-140,196,175 |
| | | | THREE | 2 | | | |

P22S -5

INSERVICE INSPECTION—EXAMINATION SUMMARY

MAJOR ITEM:

| SUB ITEM | EXAM CATEGORY | COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED | INSP. PER. | REQ'D AMT. | AMOUNT EXAM | ITEM IDENTIFICATION | INSPECTION REPORT NO. |
|---------------|---------------|---|---|-----------------------------------|-----------------------------------|--|--|
| B9.11 & B9.12 | B-J | (CONTINUED) (31 IN. NOM. DIA. SYSTEMS) REACTOR CORE COOLANT CROSSOVER LINE A REACTOR CORE COOLANT CROSSOVER LINE B | ONE TWO THREE ONE | - 2 - 1 | - 2 - 5 | RCC-A-8 RCC-A-9 RCC-B-6 RCC-B-7 RCC-B-8 RCC-B-9 RCC-B-10 | 89-378,403,320 89-379,404,321 86-151,153 86-152,154,228,229,275 86-140,143,274 86-141,144,230,231,273 86-142,145 |
| B9.20 | B-J | NOMINAL PIPE SIZE LESS THAN 4 INCH | | | | | |
| B9.21 & B9.22 | B-J | CIRCUMFERENTIAL AND LONGITUDINAL WELDS LONGITUDINAL WELDS CIRCUMFERENTIAL WELDS (11 IN. NOM. DIA. SYSTEMS) SEAL INJECTION A | --- --- ONE TWO THREE | --- --- 1 1 1 | --- --- 1 1 - | -NONE- W-2 | 90-313,318 |

P225 -5

INSERVICE INSPECTION—EXAMINATION SUMMARY

| SUB ITEM | EXAM CATEGORY | COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED | INSP. PER. | REQ'D AMT. | AMOUNT EXAM | ITEM IDENTIFICATION | INSPECTION REPORT NO. |
|---------------|---------------|--|------------|------------|--------------------|---------------------|----------------------------|
| B9.21 & B9.22 | B-J | (CONTINUED) | | | | | |
| | | SEAL INJECTION B | ONE | 1 | 1 | W-5 | 86-255,256 |
| | | | TWO | - | 1 | W-1 | 89-179,180 |
| | | | THREE | 1 | - | | |
| | | (2.0 IN. NOM. DIA. SYSTEMS) | | | | | |
| | | SEAL INJECTION A | ONE | 3 | 3 | W-28 | 85-074 |
| | | | TWO | 3 | 3 | W-40,15 | 88-132,141,218,216 |
| | | | | | | W-30,56 | 89-059,060,061,062 |
| | | | THREE | 4 | - | W-14 | 90-314,319 |
| | | SEAL INJECTION B | ONE | 4 | 4 | W-27,53 | 85-063,145 |
| | | | TWO | 4 | 3 | W-39,46 | 86-039,041,040,042 |
| | | | | | | W-30 | 89-253,300 |
| | | | THREE | 4 | - | W-40,52 | 90-271,282,272,283 |
| | | CHARGING LINE (CVCS) | ONE | 6 | 6 | W-42,68 | 85-123,071 |
| | | | | | | W-8,17,21 | 86-104,107,105,108,106,109 |
| | TWO | 6 | 7 | W-69 | 88-177,181 | | |
| | | | | W-16,41 | 89-232,241,088,083 | | |
| | | | | W-23,29 | 89-233,242,234,243 | | |
| | | | | W-1,6 | 90-152,212,398,213 | | |
| | THREE | 6 | - | W-66 | 90-142,214 | | |

INSERVICE INSPECTION—EXAMINATION SUMMARY

MAJOR ITEM:

| SUB ITEM | EXAM CATEGORY | COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED | INSP. PER. | REQ'D AMT. | AMOUNT EXAM | ITEM IDENTIFICATION | INSPECTION REPORT NO. |
|---------------|---------------|--|---------------------|-------------|-------------|---------------------|--|
| B9.21 & B9.22 | B-J | (CONTINUED) LETDOWN LINE AND DRAIN LINE (CVCS) | ONE TWO THREE | 1 2 2 | 1 2 - | W-8 W-18 W-2 | 88-261,262 89-376,245 90-390,215 |
| | | AUXILLIARY SPRAY TO PRESSURIZER | ONE TWO THREE | 1 1 2 | 1 1 - | W-16 W-17 | 86-191,194 90-292,295 |
| | | RESIDUAL TEMPERATURE DETECTOR - TAKE OFF COLD LEG LOOP A | ONE TWO THREE | 1 1 1 | 1 1 - | W-16 W-7 | 85-108 90-115,119 |
| | | RESIDUAL TEMPERATURE DETECTOR - TAKE OFF COLD LEG LOOP B | ONE TWO THREE | 1 1 1 | 1 1 - | W-3 W-6 | 86-176,179 89-182,183 |
| | | RESIDUAL TEMPERATURE DETECTOR - TAKE OFF HOT LEG LOOP A | ONE TWO THREE | 1 1 2 | 2 1 - | W-22/W-26 W-30 | 86-210,211/88-136,137 90-133,122 |
| | | RESIDUAL TEMPERATURE DETECTOR - TAKE OFF HOT LEG LOOP B | ONE TWO THREE | 1 1 2 | 1 1 - | W-28 | 89-186,187 |
| | | SAFETY INJECTION HIGH HEAD LOOP A | ONE TWO THREE | - 1 1 | - 1 - | W-6 | 90-116,118 |

MAJOR ITEM:

| SUB ITEM | EXAM CATEGORY | COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED | INSP. PER. | REQ'D AMT. | AMOUNT EXAM | ITEM IDENTIFICATION | INSPECTION REPORT NO. | |
|---------------|---------------|--|---------------------|-------------|-------------|--|---|--|
| B9.21 & B9.22 | B-J | (CONTINUED) | | | | | | |
| | | SAFETY INJECTION HIGH HEAD LOOP B | ONE TWO THREE | 1 - 1 | 1 - - | W-4 | 85-078 | |
| | | DRAIN LINE ON CROSSOVER LOOP A | ONE TWO THREE | 1 1 1 | 1 1 - | W-10 W-1 | 88-180, 184 89-342, 313 | |
| | | REACTOR VESSEL SAFETY INJECTION LOW HEAD A | ONE TWO THREE | 1 1 1 | 1 1 - | W-6 W-11 | 86-189, 192 90-315, 320 | |
| | | REACTOR VESSEL SAFETY INJECTION LOW HEAD B | ONE TWO THREE | - 1 1 | - 1 - | W-3 | 89-235, 247 | |
| | | (3.0 IN. NOM. DIA. SYSTEMS) | | | | | | |
| | | SPRAY TO PRESSURIZER BRANCH A | ONE TWO | 3 3 | 3 2 | W-22A W-13, 32 W-1, 30 AUGMENTED W-9, 10, 11 | 85-077 88-135, 138, 133, 140 89-343, 345, 214, 217 | |
| | | | THREE | 4 | 3 | W-9, 10, 11 | 89-229, 394, 236, 230, 395, 237, 231, 402, 238 90-183, 182, 184 | |
| | | SPRAY TO PRESSURIZER BRANCH B | ONE TWO THREE | 2 2 2 | 2 2 - | W-13/W-7 W-9 W-1 | 85-065/88-134, 139 89-177, 178 90-307, 308 | |

P2251-5

INSERVICE INSPECTION—EXAMINATION SUMMARY

MAJOR ITEM:

| SUB ITEM | EXAM CATEGORY | COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED | INSP. PER. | REQ'D AMT. | AMOUNT EXAM | ITEM IDENTIFICATION | INSPECTION REPORT NO. | | |
|---------------|---------------|--|---------------------|---|---------------------|---------------------|----------------------------------|-----|----------------|
| B9.21 & B9.22 | B-J | (CONTINUED) | | | | | | | |
| | | RESIDUAL TEMPERATURE DETECTOR RETURN LOOP A | ONE TWO THREE | 1 1 1 | 1 1 - | W-2 W-1 | 85-080 90-117,120 | | |
| | | RESIDUAL TEMPERATURE DETECTOR RETURN LOOP B | ONE TWO THREE | 1 1 1 | 2 1 - | W-1,2 W-4 | 86-015,019,020,016 89-377,202 | | |
| | | PRESSURIZER RELIEF LINE A | ONE TWO THREE | - - 1 | - - - | | | | |
| | | PRESSURIZER RELIEF LINE B | ONE TWO THREE | 1 1 1 | 1 1 - | W-12A W-2 | 85-067 90-250,258 | | |
| | | B9.30 | B-J | <u>BRANCH PIPE CONNECTION WELDS</u> | | | | | |
| | | B9.31 | B-J | <u>NOMINAL PIPE SIZE 4 INCH AND GREATER</u> | | | | | |
| | | | | <u>(12.0 IN. NOM.DIA. SYSTEMS)</u> | | | | | |
| | | | | ACCUMULATOR DISCHARGE LOOP A | ONE TWO THREE | - - 1 | - - - | | |
| | | | | ACCUMULATOR DISCHARGE LOOP B | ONE TWO THREE | - 1 - | - 1 - | W-R | 90-075,393,296 |

INSERVICE INSPECTION—EXAMINATION SUMMARY

MAJOR ITEM:

| SUB ITEM | EXAM CATEGORY | COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED | IRIS. PER. | REQ'D AMT. | AMOUNT EXAM | ITEM IDENTIFICATION | INSPECTION REPORT NO. |
|----------|---------------|--|---------------------|-------------|-------------|---------------------|----------------------------------|
| B9.31 | B-J | (CONTINUED) (10.0 IN. NOM.DIA. SYSTEMS) | | | | | |
| | | PRESSURIZER SURGE LINE | ONE TWO THREE | 1 - - | 1 1 - | W-R W-R | 86-178,181,199 89-222,328,224 |
| | | (8.0 IN. NOM.DIA. SYSTEMS) | | | | | |
| | | RESIDUAL HEAT REMOVAL TAKE OFF LOOP A | ONE TWO THREE | 1 - - | 1 - - | W-R | 88-057,057R,070,159 |
| | | RESIDUAL HEAT REMOVAL TAKE OFF LOOP B | ONE TWO THREE | - - 1 | - - - | | |
| | | (5.0 IN. NOM.DIA. SYSTEMS) | | | | | |
| | | PLO-CAP LOOP A | ONE TWO THREE | 1 - - | 1 - - | W-R | 85-100,102 |
| | | PLO-CAP LOOP B | ONE TWO THREE | - 1 - | - 1 - | W-R | 89-221,274,223 |
| | | SAFETY INJECTION HIGH HEAD LOOP A | ONE TWO THREE | - 1 - | - 1 - | W-R | 90-134,392,123 |
| | | SAFETY INJECTION HIGH HEAD LOOP B | ONE TWO THREE | - - 1 | - - - | | |

P2251-5

INSERVICE INSPECTION—EXAMINATION SUMMARY

MAJOR ITEM: PIPING PRESSURE BOUNDARY

| SUB ITEM | EXAM CATEGORY | COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED | INSP. PER. | REQ'D AMT. | AMOUNT EXAM | ITEM IDENTIFICATION | INSPECTION REPORT NO. |
|----------|---------------|--|---------------------|-------------|-------------|---------------------|-----------------------|
| B9.32 | B-J | <u>NOMINAL PIPE SIZE LESS THAN 4 INCH</u> (3.0 IN. NOM. DIA. SYSTEMS) | | | | | |
| | | SPRAY TO PRESSURIZER LINE A | ONE TWO THREE | - - 1 | - - - | | |
| | | SPRAY TO PRESSURIZER LINE B | ONE TWO THREE | 1 - - | 1 - - | W-R | 90-309,310 |
| | | RESIDUAL TEMPERATURE DETECTOR RETURN LOOP A | ONE TWO THREE | - - 1 | - - - | | |
| | | RESIDUAL TEMPERATURE DETECTOR RETURN LOOP B | ONE TWO THREE | 1 - - | 1 - - | W-R | 86-021,017 |
| | | (2.0 IN. NOM. DIA. SYSTEMS) | | | | | |
| | | RESIDUAL TEMPERATURE DETECTOR - TAKE OFF COLD LEG LOOP A | ONE TWO THREE | - 1 - | - 1 - | W-R | 89-330,315 |
| | | RESIDUAL TEMPERATURE DETECTOR - TAKE OFF COLD LEG LOOP B | ONE TWO THREE | - - 1 | - - - | | |
| | | DRAIN LINE ON CROSSOVER LOOP A | ONE TWO THREE | 1 - - | 1 - - | W-R | 85-109/88-156,157 |

MAJOR ITEM:

| SUB ITEM | EXAM CATEGORY | COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED | INSP. PER. | REQ'D AMT. | AMOUNT EXAM | ITEM IDENTIFICATION | INSPECTION REPORT NO. |
|----------|---------------|--|---------------------|-------------|-------------|---|--|
| B9.32 | B-J | (CONTINUED) | | | | | |
| | | DRAIN LINE ON CROSSOVER LOOP B | ONE TWO THREE | - - 1 | - - - | | |
| | | CHARGING LINE (CVCS) | ONE TWO THREE | 1 - - | 1 - - | W-R | 86-110,136 |
| | | REACTOR VESSEL SAFETY INJECTION LOW HEAD A | ONE TWO THREE | - 1 - | - 1 - | W-1 | 90-316,321 |
| B9.40 | B-J | SOCKET WELDS | | | | | |
| | | SEAL INJECTION LOOP A | ONE TWO THREE | - 1 1 | - 1 3 | W-12 F1/12, F2/11, F3/10 (BASELINE) | 90-317,322 90-418,419,420, 423,424,425 |
| | | SEAL INJECTION LOOP B | ONE TWO THREE | 1 - 1 | 1 - 2 | W-13 13A, 13B (BASELINE) | 88-188,189 90-421,422,426,427 |
| | | | | | | | |

INSERVICE INSPECTION—EXAMINATION SUMMARY

MAJOR ITEM:

| SUB ITEM | EXAM CATEGORY | COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED | INSP. PER. | REQ'D AMT. | AMOUNT EXAM | ITEM IDENTIFICATION | INSPECTION REPORT NO. |
|----------|---------------|--|---------------------|-------------|-------------|---|--|
| B9.40 | B-J | (CONTINUED) | | | | | |
| | | CHARGING LINE CVCS | ONE TWO THREE | 1 1 3 | 1 - - | W-50 MISSED PER TWO | 88-178,182 |
| | | DRAIN LINE AND LETDOWN LINE CVCS | ONE TWO THREE | 1 1 1 | 1 1 - | W-25 W-18 W-12R (BASELINE) | 85-064 90-143,216 89-352,361 |
| | | AUXILLIARY SPRAY TO PRESSURIZER | ONE TWO THREE | 1 - - | 1 - 2 | W-7 W-4R (BASELINE) W-5R (BASELINE) | 86-190,193 89-398,398R,410 89-399,399R,411 |
| | | RESIDUAL TEMPERATURE DETECTOR - TAKE OFF COLD LEG LOOP A | ONE TWO THREE | 1 1 1 | 1 1 - | W-2 W-3 | 86-239,240 89-329,314 |
| | | RESIDUAL TEMPERATURE DETECTOR - TAKE OFF COLD LEG LOOP B | ONE TWO THREE | 1 1 1 | 1 1 - | W-7 W-7 | 88-258,259 90-153,217 |
| | | RESIDUAL TEMPERATURE DETECTOR - TAKE OFF HOT LEG LOOP A | ONE TWO THREE | - 1 1 | - 1 - | W-33 | 89-331,316 |
| | | RESIDUAL TEMPERATURE DETECTOR - TAKE OFF HOT LEG LOOP B | ONE TWO THREE | - 1 1 | - 1 - | W-30 | 90-154,218 |

P22S-5

INSERVICE INSPECTION—EXAMINATION SUMMARY

MAJOR ITEM:

| SUB ITEM | EXAM CATEGORY | COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED | INSP. PER. | REQ'D AMT. | AMOUNT EXAM | ITEM IDENTIFICATION | INSPECTION REPORT NO. |
|----------|---------------|--|---------------------|-------------|-------------|---------------------|----------------------------------|
| B9.40 | B-J | (CONTINUED) | | | | | |
| | | SAFETY INJECTION HIGH HEAD LOOP A | ONE TWO THREE | - - 1 | - - - | | |
| | | SAFETY INJECTION HIGH HEAD LOOP B | ONE TWO THREE | 1 - - | 1 - - | W-8 | 86-177,180 |
| | | DRAIN LINE ON CROSSOVER LOOP A | ONE TWO THREE | 1 - - | 1 - - | W-16 | 88-179,183 |
| | | REACTOR VESSEL SAFETY INJECTION LOW HEAD LOOP A | ONE TWO THREE | 1 - - | 1 - - | W-13 | 85-072 |
| | B-K-1 | REACTOR VESSEL SAFETY INJECTION LOW HEAD LOOP B | ONE TWO THREE | - - 1 | - - - | | |
| | B-K-1 | <u>INTEGRAL ATTACHMENTS FOR PIPING</u> | | | | | |
| B10.10 | B-K-1 | <u>INTEGRALLY WELDED ATTACHMENTS</u> | | | | | |
| | | ACCUMULATOR DISCHARGE LOOP A & B | ONE TWO THREE | 1 1 1 | 1 1 - | A1 B1 | 86-014,195,196 90-332,226,205 |
| | | | | | | | |

P22S-5

| SUB ITEM | EXAM CATEGORY | COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED | INSP. PER. | REQ'D AMT. | AMOUNT EXAM | ITEM IDENTIFICATION | INSPECTION REPORT NO. |
|----------|---------------|---|---------------------|-------------|-------------|---------------------|---|
| B10.10 | B-K-1 | (CONTINUED) RESIDUAL HEAT REMOVAL TAKE OFF LOOP A RESIDUAL TEMPERATURE DETECTOR RETURN LOOP B | ONE TWO THREE | - 1 - | - 1 - | U | 89-276,290,291 |
| | B-P | <u>ALL PRESSURE RETAINING COMPONENTS</u> | | | | | |
| B15.50 | B-P | <u>PRESSURE RETAINING BOUNDARY</u> | * | - | - | | * PERFORMED BY PLANT PERSONNEL IN ACCORDANCE WITH IWA-5000 DURING EACH SYSTEM LEAKAGE TEST AND EACH SYSTEM HYDROSTATIC TEST REQUIRED BY IWB-5000. |
| B15.51 | B-P | <u>PRESSURE RETAINING BOUNDARY</u> | * | - | - | | |

MAJOR ITEM:

| SUB ITEM | EXAM CATEGORY | COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED | INSP. PER. | REQ'D AMT. | AMOUNT EXAM | ITEM IDENTIFICATION | INSPECTION REPORT NO. |
|----------|---------------|--|---------------------|-------------|-------------|---------------------------------|---|
| B6.180 | B-G-1 | <u>PRESSURE RETAINING BOLTING, GREATER THAN 2 INCH IN DIAMETER</u> | | | | | |
| | B-G-1 | <u>BOLTS AND STUDS, IN PLACE</u> | | | | | |
| | | REACTOR CORE COOLANT PUMP NO. 21 | ONE TWO THREE | 8 8 8 | 8 8 - | FLG BOLTS 1-8 FLG BOLTS 9-16 | 86-018,266 90-360,357 |
| B6.190 | B-G-1 | <u>FLANGE SURFACE, WHEN CONNECTION DISSASSEMBLED</u> | | | | | |
| | | REACTOR CORE COOLANT PUMPS 21 & 22 | * | - | - | | * IF DISSASSEMBLED 100% OF SURFACES |
| | B-G-1 | <u>NUTS, BUSHINGS, AND WASHERS</u> | | | | | |
| B6.200 | B-G-1 | REACTOR CORE COOLANT PUMP NO. 21 & 22 | * | - | - | | * IF DISSASSEMBLED WITH B6.190 100% OF SURFACES |
| | B-G-2 | <u>PRESSURE RETAINING BOLTING, 2 INCHES AND LESS IN DIAMETER</u> | | | | | |

P225-6

MAJOR ITEM

| SUB ITEM | EXAM CATEGORY | COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED | INSP. PER. | REQ'D AMT. | AMOUNT EXAM | ITEM IDENTIFICATION | INSPECTION REPORT NO. |
|----------|---------------|--|------------|------------|-------------|--------------------------|--------------------------|
| B7.60 | B-G-2 | <u>BOLTS, STUDS, AND NUTS</u> | | | | | |
| | | REACTOR CORE COOLANT PUMPS A & B | | | | | |
| | | SEAL HOUSE BOLTING PUMP A | ONE | 4 | 36 | 12 UPPER AND 12 LOWER | 85-098,099,104,106 |
| | | | TWO | 4 | 12 | 12 LOWER | 86-159,157 |
| | | | THREE | 4 | - | 12 LOWER | 89-097,135 |
| | | SEAL HOUSE BOLTING PUMP B | ONE | 4 | 56 | 8 UPPER AND 12 LOWER | 85-021,022,023,024 |
| | | | | | | 12 LOWER | 86-158,160 |
| | | | | | | 12 LOWER AND 12 UPPER | 88-108,093,111 |
| | | | TWO | 4 | * | | 88-110,109 |
| | | | THREE | 4 | - | | * PUMPS NOT DISASSEMBLED |
| | B-K-1 | <u>INTEGRAL ATTACHMENTS FOR PUMPS</u> | | | | | |
| B10.20 | B-K-1 | <u>INTEGRALLY WELDED ATTACHMENTS</u> | | | | | |
| | | REACTOR CORE COOLANT PUMP 21 | ONE | 1 | 1 | SUPPORT A | 86-029,030,186 |
| | | | TWO | 1 | 1 | SUPPORT B | 90-333,352,342 |
| | | | THREE | 1 | - | | |
| | | REACTOR CORE COOLANT PUMP 22 | ONE | 1 | 1 | SUPPORT A | 88-290,291,292 |
| | | | TWO | 1 | 1 | SUPPORT B | 89-141,144,121 |
| | | | THREE | 1 | - | | |

INSERVICE INSPECTION—EXAMINATION SUMMARY

MAJOR ITEM:

| SUB ITEM | EXAM CATEGORY | COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED | INSP. PER. | REQ'D AMT. | AMOUNT EXAM | ITEM IDENTIFICATION | INSPECTION REPORT NO. |
|----------|---------------|--|------------|------------|-------------|---------------------|---|
| B12.10 | B-L-1 | <u>PRESSURE RETAINING WELDS IN PUMP CASINGS</u> | | | | | |
| | B-L-1 | <u>PUMP CASING WELDS</u> | | | | | |
| | | REACTOR CORE COOLANT PUMP 21 | * | - | - | | * RELIEF NO. 63 |
| | | REACTOR CORE COOLANT PUMP 22 | * | - | - | | * RELIEF NO. 63 |
| B12.20 | B-L-2 | <u>PUMP CASINGS BODIES</u> | | | | | |
| | B-L-2 | <u>PUMP CASINGS INTERIORS</u> | | | | | |
| | | REACTOR CORE COOLANT PUMPS 21 & 22 | * | - | - | | * RELIEF NO. 63 |
| | B-P | <u>ALL PRESSURE RETAINING COMPONENTS</u> | | | | | |
| B15.60 | B-P | <u>PRESSURE RETAINING BOUNDARY</u> | * | - | - | | * PERFORMED BY PLANT PERSONNEL IN ACCORDANCE WITH IWA-5000 DURING EACH SYSTEM LEAKAGE TEST AND EACH SYSTEM HYDROSTATIC TEST REQUIRED BY IWB-5000. |
| B15.61 | B-P | <u>PRESSURE RETAINING BOUNDARY</u> | * | - | - | | |

INSERVICE INSPECTION—EXAMINATION SUMMARY

MAJOR ITEM:

| SUB ITEM | EXAM CATEGORY | COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED | INSP. PER. | REQ'D AMT. | AMOUNT EXAM | ITEM IDENTIFICATION | INSPECTION REPORT NO. |
|----------|---------------|--|------------|------------|-------------|-----------------------------|---|
| - | - | <u>PUMP FLYWHEELS</u> | | | | | |
| | * | PUMP 21 | ONE | 1 | 1 | PERIPHERY BODY | 88-150,213 88-154 |
| | | | TWO | 1 | 1 | KEYWAY PERIPHERY BODY | 88-152 90-306 90-302,343 |
| | | | THREE | 1 | - | KEYWAY | 90-301 |
| | * | PUMP 22 | ONE | 1 | 1 | PERIPHERY BODY | 88-127,214 88-153 |
| | | | TWO | 1 | 1 | KEYWAY PERIPHERY BODY | 88-151 90-303 90-305,344 |
| | | | THREE | 1 | - | KEYWAY | 90-304 |
| | | | | | | | * AN INPLACE ULTRA-SONIC EXAMINATION OF AREAS OF HIGHER CONCENTRATION AT THE BASE AND KEYWAY SHALL BE PERFORMED. IF REACTOR CORE COOLANT PUMP IS DISMANTLED, THEN A COMPLETE VOLUMETRIC EXAMINATION OF ALL EXPOSED SURFACES SHALL BE PERFORMED. |

P225 -6

INSERVICE INSPECTION—EXAMINATION SUMMARY

MAJOR ITEM:

| SUB ITEM | EXAM CATEGORY | COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED | INSP. PER. | REQ'D AMT. | AMOUNT EXAM | ITEM IDENTIFICATION | INSPECTION REPORT NO. |
|----------|---------------|---|-------------------------|------------------|------------------|----------------------------|-------------------------|
| B7.70 | B-G-1 | PRESSURE RETAINING BOLTING, GREATER THAN 2 INCHES IN DIAMETER | - | - | - | -NONE- | |
| | B-G-2 | PRESSURE RETAINING BOLTING, 2 INCHES AND LESS IN DIAMETER | | | | | |
| | B-G-2 | BOLTS, STUDS, AND NUTS | | | | | |
| | | ACCUMULATOR DISCHARGE LOOP A | ONE TWO THREE | 16 - 16 | 16 - - | 2-8841A(REPEAT) | 85-130/88-037 |
| | | ACCUMULATOR DISCHARGE | ONE TWO THREE | - 16 16 | - 16 - | 2-8841B | 89-203 |
| | | RESIDUAL HEAT REMOVAL RETURN LOOP B | ONE TWO THREE | 16 - - | 16 - - | 2-8703 | 86-168 |
| | | RESIDUAL HEAT REMOVAL TAKE OFF LOOP A | ONE TWO THREE | - 16 16 | - 16 - | 2-8701A | 90-230 |
| | | RESIDUAL HEAT REMOVAL TAKE OFF LOOP B | ONE TWO THREE | 16 - - | 48 - - | 2-8701B 2-8702B(REPEAT) | 86-242 86-031/88-240 |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |

P225 -7

INSERVICE INSPECTION—EXAMINATION SUMMARY

MAJOR ITEM:

| SUB ITEM | EXAM CATEGORY | COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED | INSP. PER. | REQ'D AMT. | AMOUNT EXAM | ITEM IDENTIFICATION | INSPECTION REPORT NO. |
|--|---------------|--|------------|-----------------|-------------|---------------------|-----------------------|
| 87.70 | B-G-2 | (CONTINUED) | | | | | |
| | | SAFETY INJECTION HIGH HEAD LOOP A | ONE | - | - | | |
| | | | TWO | 12 | 12 | 2-8842A | 89-317 |
| | | | THREE | - | - | | |
| | | SAFETY INJECTION HIGH HEAD LOOP B | ONE | - | - | | |
| | | | TWO | - | - | | |
| | | | THREE | 12 | - | | |
| | | PRESSURIZER SPRAY LOOP A | ONE | - | - | | |
| | | | TWO | - | - | | |
| | | | THREE | 8 | - | | |
| | | PRESSURIZER SPRAY LOOP B | ONE | - | - | | |
| | | | TWO | - | - | | |
| | | | THREE | 8 | - | | |
| | | RESISTANCE TEMPERATURE DETECTOR - RETURN LOOP A | ONE | - | - | | |
| | TWO | 12 | 12 | 2-8001A | 90-158 | | |
| | THREE | - | - | | | | |
| RESISTANCE TEMPERATURE DETECTOR - RETURN LOOP B | ONE | - | - | | | | |
| | TWO | 12 | 12 | 2-8001B | 89-201 | | |
| | THREE | - | - | | | | |
| RESISTANCE TEMPERATURE DETECTOR - TAKE OFF LOOP A (COLD LEG) | ONE | 2 | 2 | 2RC-1-6 (T-58) | 88-038 | | |
| | TWO | 2 | 2 | 2RC-1-7 (T-58) | 90-165 | | |
| | THREE | 2 | - | | | | |
| RESISTANCE TEMPERATURE DETECTOR - TAKE OFF LOOP B (COLD LEG) | ONE | - | - | | | | |
| | TWO | 4 | 4 | 2RC-1-15 (T-58) | 89-185 | | |
| | THREE | 2 | - | 2RC-1-16 (T-58) | 89-184 | | |

P22S-7

INSERVICE INSPECTION—EXAMINATION SUMMARY

MAJOR ITEM:

| SUB ITEM | EXAM CATEGORY | COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED | INSP. PER. | REQ'D AMT. | AMOUNT EXAM | ITEM IDENTIFICATION | INSPECTION REPORT NO. |
|----------|---------------|---|---------------------|---------------|---------------|--|-----------------------------------|
| B7.70 | B-G-2 | (CONTINUED) | | | | | |
| | | RESISTANCE TEMPERATURE DETECTOR - TAKE OFF LOOP A (HOT LEG) | ONE TWO THREE | 2 2 2 | 2 4 - | 2RC-1-12 (T-58) 2RC-1-9 (T-58) 2RC-1-10 (T-58) | 88-149 90-159 90-160 |
| | | RESISTANCE TEMPERATURE DETECTOR - TAKE OFF LOOP B (HOT LEG) | ONE TWO THREE | 2 2 2 | 2 2 - | 2RC-1-13 (T-58) | 89-188 |
| | | PRESSURE RELIEF LINE | ONE TWO THREE | 18 6 12 | 18 6 - | 2-8000B(REPEAT) 2-PCV-431C 2-PCV-430 | 85-139/88-066 88-067 89-319 |
| | | REACTOR VESSEL SAFETY INJECTION LOW HEAD LOOP A | ONE TWO THREE | 12 12 - | 12 12 - | 2-8843A 2-8843A | 88-171 90-144 |
| | | REACTOR VESSEL SAFETY INJECTION LOW HEAD LOOP B | ONE TWO THREE | 12 - 12 | 12 - - | 2-8843B | 86-045 |
| | | AUXILLIARY SPRAY CVCS | ONE TWO THREE | - - 6 | - - - | | |
| | | DRAIN LINE ON CROSSOVER LOOP A | ONE TWO THREE | 2 - 2 | 2 - - | 2-RC-1-2 (T-58) (REPEAT) | 85-129 88-168 |

P225-7

NORTHERN STATES POWER CO.
 PRAIRIE ISLAND UNIT 2
 INSERVICE INSPECTION—EXAMINATION SUMMARY

TABLE SI.7
 PAGE 4 OF 5
 VALVE PRESSURE BOUNDARY

MAJOR ITEM: _____

| SUB ITEM | EXAM CATEGORY | COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED | INSP. PER. | REQ'D AMT. | AMOUNT EXAM | ITEM IDENTIFICATION | INSPECTION REPORT NO. |
|----------|---------------|--|---------------------|-------------|-------------|------------------------------|-----------------------|
| B7.70 | B-G-2 | (CONTINUED) | | | | | |
| | | DRAIN LINE ON CROSSOVER LOOP B | ONE TWO THREE | 2 - 2 | 2 - - | 2-RC-1-3 (T-58) | 86-167 |
| | | LETDOWN LINE CVCS | ONE TWO THREE | 8 2 8 | 8 2 - | 2-LCV-427 2RC-1-5 | 88-170 89-246 |
| | | CHARGING LINE LOOP B | ONE TWO THREE | - 6 2 | - 6 - | 2-8142 | 89-244 |
| | | SEAL INJECTION LOOP A | ONE TWO THREE | 2 - - | 2 - - | 2-VC-7-18 (T-58) | 88-076 |
| | | SEAL INJECTION LOOP B | ONE TWO THREE | 2 - - | 2 - - | 2-VC-7-19 (T-58) (REPEAT) | 85-140 88-169 |
| | B-K-1 | <u>INTEGRAL ATTACHMENTS FOR VALVES</u> | - | - | - | -NONE- | |
| | B-M-1 | <u>PRESSURE RETAINING WELDS IN VALVE BODIES</u> | - | - | - | -NONE- | |

P22S-7

MAJOR ITEM:

| SUB ITEM | EXAM CATEGORY | COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED | INSP. PER. | REQ'D AMT. | AMOUNT EXAM | ITEM IDENTIFICATION | INSPECTION REPORT NO. |
|----------|---------------|--|------------|------------|-------------|--------------------------------------|---|
| B12.50 | B-M-2 | <u>VALVE BODIES</u> | | | | | |
| | B-M-2 | <u>VALVE BODIES, EXCEEDING 4 INCH NOMINAL PIPE SIZE</u> | | | | | |
| | | VELAN CHECK VALVES | * | 1 | - | | * SPECIFIC VALVE SUBJECT TO PLANT MAINTENANCE SCHEDULES. |
| | | DARLING GATE VALVES | * | 1 | - | | |
| | | DARLING CHECK VALVE | TWO | 1 | 4 | 2-8840A, 2-8841A 2-8840B, 2-8841B | 89-142,143 89-091,096 |
| | | VELAN GATE VALVES | * | 1 | - | | |
| | | CROSBY SAFETY VALVES | * | 1 | - | | |
| | B-P | <u>ALL PRESSURE RETAINING COMPONENTS</u> | | | | | |
| B15.70 | B-P | <u>PRESSURE RETAINING BOUNDARY</u> | * | - | - | | * PERFORMED BY PLANT PERSONNEL IN ACCORDANCE WITH IWA-5000 DURING EACH SYSTEM LEAKAGE TEST AND EACH SYSTEM HYDROSTATIC TEST REQUIRED BY IWB-5000. |
| B15.71 | B-P | <u>PRESSURE RETAINING BOUNDARY</u> | * | - | - | | |

NORTHERN STATES POWER COMPANY
PRAIRIE ISLAND UNIT II

TABLE S-II

Examination Comparison Summary

| SUB-ITEM | SYSTEM | CLASS | ISO | METH | ITEM | REPORT | PREVIOUS RESULTS | SCAN | CURRENT RESULTS | LIMITATIONS |
|----------|----------------|-------|----------|------|------------|--------|------------------|------|------------------|-----------------------------|
| | RCC PUMP 21 | I | 2-ISI-45 | UT0 | BODY | 90-302 | Results:NONE | 1 | Results:NONE | NONE |
| | RCC PUMP 21 | I | 2-ISI-45 | UT0 | BODY | 90-302 | Results:NONE | 1L | Results:NONE | NONE |
| | RCC PUMP 21 | I | 2-ISI-45 | VT1 | BODY | 90-343 | Results:NONE | | Results:NONE | NONE |
| | RCC PUMP 21 | I | 2-ISI-45 | UT0 | KEYWAY | 90-301 | Results:NONE | 1 | Results:NONE | NONE |
| | RCC PUMP 21 | I | 2-ISI-45 | UT0 | PERIPHERY | 90-306 | Results:NONE | 1 | Results:NONE | NONE |
| | RCC PUMP 21 | I | 2-ISI-45 | UT0 | PERIPHERY | 90-306 | Results:NONE | 1L | Results:NONE | NONE |
| | RCC PUMP 22 | I | 2-ISI-45 | UT0 | BODY | 90-305 | Results:NONE | 1 | Results:NONE | NONE |
| | RCC PUMP 22 | I | 2-ISI-45 | UT0 | BODY | 90-305 | Results:NONE | 1L | Results:NONE | NONE |
| | RCC PUMP 22 | I | 2-ISI-45 | VT1 | BODY | 90-344 | Results:NONE | | Results:NONE | NONE |
| | RCC PUMP 22 | I | 2-ISI-45 | UT0 | KEYWAY | 90-304 | Results:NONE | 1 | Results:NONE | NONE |
| | RCC PUMP 22 | I | 2-ISI-45 | UT0 | PERIPHERY | 90-303 | Results:NONE | 1 | Results:NONE | NONE |
| | RCC PUMP 22 | I | 2-ISI-45 | UT0 | PERIPHERY | 90-303 | Results:NONE | 1L | Results:NONE | NONE |
| B 1. 40 | REACTOR VESSEL | I | 2-ISI-41 | MT1 | W-6 16-32 | 90-179 | Results:N/A | | Results:NONE | NONE |
| B 1. 40 | REACTOR VESSEL | I | 2-ISI-41 | UT0 | W-6 16-32 | 90-201 | Results:NONE | 1L | Results:NONE | LIMITED FLANGE, LIFTING LUG |
| B 1. 40 | REACTOR VESSEL | I | 2-ISI-41 | UT45 | W-6 16-32 | 90-202 | Results:NONE | 1 | Results:NONE | LIMITED FLANGE, LIFTING LUG |
| B 1. 40 | REACTOR VESSEL | I | 2-ISI-41 | UT45 | W-6 16-32 | 90-202 | Results:NONE | 2 | Results:NONE | NONE |
| B 1. 40 | REACTOR VESSEL | I | 2-ISI-41 | UT45 | W-6 16-32 | 90-202 | Results:NONE | 3 | Results:NONE | NONE |
| B 1. 40 | REACTOR VESSEL | I | 2-ISI-41 | UT45 | W-6 16-32 | 90-202 | Results:NONE | 4 | Results:NONE | NONE |
| B 1. 40 | REACTOR VESSEL | I | 2-ISI-41 | UT60 | W-6 16-32 | 90-203 | Results:NONE | 1 | Results:NONE | LIMITED FLANGE, LIFTING LUG |
| B 1. 40 | REACTOR VESSEL | I | 2-ISI-41 | UT60 | W-6 16-32 | 90-203 | Results:IND | 2 | Results:IND | NONE |
| | | | | | | | Scan:2 | | Scan: 2 | |
| | | | | | | | Type:SPOT | | Type:SPOT | |
| | | | | | | | Amplitude:45 | | Amplitude:30 | |
| | | | | | | | Ax Loc: | | Ax Loc:- 0.65" | |
| | | | | | | | Circ Loc: | | Circ Loc:STJD 31 | |
| | | | | | | | Length: | | Length:1.0' | |
| B 1. 40 | REACTOR VESSEL | I | ISI-41 | UT60 | W-6 16-32 | 90-203 | Results:NONE | 3 | Results:NONE | NONE |
| B 1. 40 | REACTOR VESSEL | I | ISI-41 | UT60 | W-6 16-32 | 90-203 | Results:NONE | 4 | Results:NONE | NONE |
| B 1. 40 | REACTOR VESSEL | I | 2-ISI-41 | VT1 | W-6 16-32 | 90-200 | Results:NONE | | Results:NONE | NONE |
| B 2. 11 | PRESSURIZER | I | 2-ISI-36 | UT0 | W-4 0'-12" | 90-175 | Results:NONE | 1L | Results:NONE | NONE |
| B 2. 11 | PRESSURIZER | I | 2-ISI-36 | UT45 | W-4 0'-12" | 90-176 | Results:NONE | 1 | Results:NONE | NONE |
| B 2. 11 | PRESSURIZER | I | 2-ISI-36 | UT45 | W-4 0'-12" | 90-176 | Results:NONE | 2 | Results:NONE | NONE |
| B 2. 11 | PRESSURIZER | I | 2-ISI-36 | UT45 | W-4 0'-12" | 90-176 | Results:NONE | 3 | Results:NONE | NONE |
| B 2. 11 | PRESSURIZER | I | 2-ISI-36 | UT45 | W-4 0'-12" | 90-176 | Results:NONE | 4 | Results:NONE | NONE |
| B 2. 11 | PRESSURIZER | I | 2-ISI-36 | UT60 | W-4 0'-12" | 90-177 | Results:NONE | 1 | Results:NONE | NONE |

TABLE S-II

NORTHERN STATES POWER COMPANY
PRAIRIE ISLAND UNIT II

Examination Comparison Summary

| SUB-ITEM | SYSTEM | CLASS | ISO | METH | ITEM | REPORT | PREVIOUS RESULTS | SCAN | CURRENT RESULTS | LIMITATIONS |
|----------|----------------------|-------|----------|------|---------------|--------|--|------|---|--------------------------------|
| B 2. 11 | PRESSURIZER | I | 2-1S1-36 | UT60 | W-4 0'-12' | 90-177 | Results:NONE | 2 | Results:NONE | NONE |
| B 2. 11 | PRESSURIZER | I | 2-1S1-36 | UT60 | W-4 0'-12' | 90-177 | Results:NONE | 3 | Results:NONE | NONE |
| B 2. 11 | PRESSURIZER | I | 2-1S1-36 | UT60 | W-4 0'-12' | 90-177 | Results:NONE | 4 | Results:NONE | NONE |
| B 2. 11 | PRESSURIZER | I | 2-1S1-36 | VT1 | W-4 0'-12' | 90-178 | Results:NONE | | Results:NONE | NONE |
| B 2. 40 | STEAM GENERATOR 21 | I | 2-1S1-37 | UT0 | W-A 12'-23'3" | 90-395 | Results:NONE | 1L | Results:NONE | 2.5"x2.5" INSULATION PADS |
| B 2. 40 | STEAM GENERATOR 21 | I | 2-1S1-37 | UT45 | W-A 12'-23'3" | 90-396 | Results:GEO Scan:1 Type:GEOMETRY Amplitude:100 Ax Loc: Circ Loc:35"-35.5" Length:.5" | 1 | Results:NONE | 2.5"x2.5" INSULATION PADS |
| B 2. 40 | STEAM GENERATOR 21 | I | 2-1S1-37 | UT45 | W-A 12'-23'3" | 90-396 | Results:NONE | 2 | Results:GEO Scan: 2 Type:00 Amplitude:80 Ax Loc: Circ Loc: Length:11'-23'3" | NONE |
| B 2. 40 | STEAM GENERATOR 21 | I | 2-1S1-37 | UT45 | W-A 12'-23'3" | 90-396 | Results:NONE | 3 | Results:NONE | NGIE |
| B 2. 40 | STEAM GENERATOR 21 | I | 2-1S1-37 | UT45 | W-A 12'-23'3" | 90-396 | Results:NONE | 4 | Results:NONE | NONE |
| B 2. 40 | STEAM GENERATOR 21 | I | 2-1S1-37 | UT60 | W-A 12'-23'3" | 90-397 | Results:NONE | 1 | Results:NONE | 2.5"x2.5" INSULATION PADS |
| B 2. 40 | STEAM GENERATOR 21 | I | 2-1S1-37 | UT60 | W-A 12'-23'3" | 90-397 | Results:NONE | 2 | Results:NONE | NONE |
| B 2. 40 | STEAM GENERATOR 21 | I | 2-1S1-37 | UT60 | W-A 12'-23'3" | 90-397 | Results:NONE | 3 | Results:NONE | NONE |
| B 2. 40 | STEAM GENERATOR 21 | I | 2-1S1-37 | UT60 | W-A 12'-23'3" | 90-397 | Results:NONE | 4 | Results:NONE | NONE |
| B 2. 40 | STEAM GENERATOR 21 | I | 2-1S1-37 | VT1 | W-A 12'-23'3" | 90-399 | Results:NONE | | Results:NONE | NONE |
| B 2. 51 | LETDOWN HT EXCHANGER | I | 2-1S1-46 | UT45 | W-1 | 90-073 | Results:NONE | 1 | Results:NONE | SCANS 1,3,4,1s & 2s OBSTRUCTED |
| B 2. 51 | LETDOWN HT EXCHANGER | I | 2-1S1-46 | UT45 | W-1 | 90-073 | Results:NONE | 2 | Results:NONE | @ 11:-12:00, 12:-1:30, |
| B 2. 51 | LETDOWN HT EXCHANGER | I | 2-1S1-46 | UT45 | W-1 | 90-073 | Results:NONE | 3 | Results:NONE | 4:30-6:00, 6:-7:00 DUE TO |
| B 2. 51 | LETDOWN HT EXCHANGER | I | 2-1S1-46 | UT45 | W-1 | 90-073 | Results:NONE | 4 | Results:NONE | WELD-O-LETS |
| B 2. 51 | LETDOWN HT EXCHANGER | I | 2-1S1-46 | UT45 | W-1 | 90-073 | Results:N/A | 1s | Results:NONE | NONE |
| B 2. 51 | LETDOWN HT EXCHANGER | I | 2-1S1-46 | UT45 | W-1 | 90-073 | Results:N/A | 2s | Results:NONE | NONE |
| B 2. 51 | LETDOWN HT EXCHANGER | I | 2-1S1-46 | UT45 | W-1 | 90-073 | Results:N/A | 3s | Results:NONE | NONE |
| B 2. 51 | LETDOWN HT EXCHANGER | I | 2-1S1-46 | UT45 | W-1 | 90-073 | Results:N/A | 4s | Results:NONE | NONE |
| B 2. 51 | LETDOWN HT EXCHANGER | I | 2-1S1-46 | VT1 | W-1 | 90-063 | Results:NONE | | Results:NONE | NONE |

NORTHERN STATES POWER COMPANY
PRAIRIE ISLAND UNIT II

TABLE S-II

Examination Comparison Summary

| SUB-ITEM | SYSTEM | CLASS | ISO | METH | ITEM | REPORT | PREVIOUS RESULTS | SCAN | CURRENT RESULTS | LIMITATIONS |
|----------|--------------------|-------|----------|------|---------------|--------|------------------|------|-----------------|--------------------------------|
| B 2. 60 | REGEN HT EXCH B | 1 | 2-1SI-34 | UT45 | W-2 | 90-072 | Results:NONE | 1 | Results:NONE | SCANS 1,2,3,4,1s & 2s OBSTRUCT |
| B 2. 60 | REGEN HT EXCH B | 1 | 2-1SI-34 | UT45 | W-2 | 90-072 | Results:NONE | 2 | Results:NONE | @ 11-12:00, 12:-1:00, 5:-6:00, |
| B 2. 60 | REGEN HT EXCH B | 1 | 2-1SI-34 | UT45 | W-2 | 90-072 | Results:NONE | 3 | Results:NONE | 6:-7:00 DUE TO WELD-O-LETS |
| B 2. 60 | REGEN HT EXCH B | 1 | 2-1SI-34 | UT45 | W-2 | 90-072 | Results:NONE | 4 | Results:NONE | NONE |
| B 2. 60 | REGEN HT EXCH B | 1 | 2-1SI-34 | UT45 | W-2 | 90-072 | Results:N/A | 1s | Results:NONE | NONE |
| B 2. 60 | REGEN HT EXCH B | 1 | 2-1SI-34 | UT45 | W-2 | 90-072 | Results:N/A | 2s | Results:NONE | NONE |
| B 2. 60 | REGEN HT EXCH B | 1 | 2-1SI-34 | UT45 | W-2 | 90-072 | Results:N/A | 3s | Results:NONE | NONE |
| B 2. 60 | REGEN HT EXCH B | 1 | 2-1SI-34 | UT45 | W-2 | 90-072 | Results:N/A | 4s | Results:NONE | NONE |
| B 2. 60 | REGEN HT EXCH B | 1 | 2-1SI-34 | VT1 | W-2 | 90-062 | Results:NONE | | Results:NONE | NONE |
| B 5. 70 | STEAM GENERATOR 22 | 1 | 2-1SI-33 | PT | RCC-B-5 S.E. | 90-232 | Results:NONE | | Results:NONE | NONE |
| B 5. 70 | STEAM GENERATOR 22 | 1 | 2-1SI-33 | UT45 | RCC-B-5 S.E. | 90-299 | Results:NONE | 2 | Results:NONE | NO SCAN 1 CONFIGURATION |
| B 5. 70 | STEAM GENERATOR 22 | 1 | 2-1SI-33 | UT45 | RCC-B-5 S.E. | 90-299 | Results:NONE | 3 | Results:NONE | NONE |
| B 5. 70 | STEAM GENERATOR 22 | 1 | 2-1SI-33 | UT45 | RCC-B-5 S.E. | 90-299 | Results:NONE | 4 | Results:NONE | NONE |
| B 5. 70 | STEAM GENERATOR 22 | 1 | 2-1SI-33 | VT1 | RCC-B-5 S.E. | 90-293 | Results:NONE | | Results:NONE | NONE |
| B 5. 130 | STEAM GENERATOR 22 | 1 | 2-1SI-33 | PT | RCC-B-5 S.E. | 90-074 | Results:NONE | | Results:NONE | NONE |
| B 5. 130 | STEAM GENERATOR 22 | 1 | 2-1SI-33 | UT45 | RCC-B-5 S.E. | 90-298 | Results:NONE | 2 | Results:NONE | NO SCAN 1 CONFIGURATION |
| B 5. 130 | STEAM GENERATOR 22 | 1 | 2-1SI-33 | UT45 | RCC-B-5 S.E. | 90-298 | Results:NONE | 3 | Results:NONE | NONE |
| B 5. 130 | STEAM GENERATOR 22 | 1 | 2-1SI-33 | UT45 | RCC-B-5 S.E. | 90-298 | Results:NONE | 4 | Results:NONE | NONE |
| B 5. 130 | STEAM GENERATOR 22 | 1 | 2-1SI-33 | VT1 | RCC-B-5 S.E. | 90-281 | Results:NONE | | Results:NONE | NONE |
| B 6. 10 | REACTOR VESSEL | 1 | 2-1SI-39 | MT1 | NUTS 17-32 | 90-221 | Results:NONE | | Results:NONE | NONE |
| B 6. 10 | REACTOR VESSEL | 1 | 2-1SI-39 | VT1 | NUTS 17-32 | 90-223 | Results:NONE | | Results:NONE | NONE |
| B 6. 30 | REACTOR VESSEL | 1 | 2-1SI-39 | MT1 | STUDS 17-32 | 90-222 | Results:NONE | | Results:NONE | NONE |
| B 6. 30 | REACTOR VESSEL | 1 | 2-1SI-39 | UT0 | STUDS 17-32 | 90-244 | Results:NONE | 1L | Results:NONE | NONE |
| B 6. 30 | REACTOR VESSEL | 1 | 2-1SI-39 | UT0 | STUDS 17-32 | 90-244 | Results:NONE | 2L | Results:NONE | NONE |
| B 6. 30 | REACTOR VESSEL | 1 | 2-1SI-39 | VT1 | STUDS 17-32 | 90-224 | Results:NONE | | Results:NONE | NONE |
| B 6. 50 | REACTOR VESSEL | 1 | 2-1SI-39 | VT1 | WASHERS 17-32 | 90-225 | Results:NONE | | Results:NONE | NONE |
| B 6. 180 | RCC PUMP 21 | 1 | 2-1SI-44 | UT0 | FLG BLTS 9-16 | 90-360 | Results:NONE | 9 | Results:NONE | NONE |
| B 6. 180 | RCC PUMP 21 | 1 | 2-1SI-44 | UT0 | FLG BLTS 9-16 | 90-360 | Results:NONE | 10 | Results:NONE | NONE |
| B 6. 180 | RCC PUMP 21 | 1 | 2-1SI-44 | UT0 | FLG BLTS 9-16 | 90-360 | Results:NONE | 11 | Results:NONE | NONE |
| B 6. 180 | RCC PUMP 21 | 1 | 2-1SI-44 | UT0 | FLG BLTS 9-16 | 90-360 | Results:NONE | 12 | Results:NONE | NONE |
| B 6. 180 | RCC PUMP 21 | 1 | 2-1SI-44 | UT0 | FLG BLTS 9-16 | 90-360 | Results:NONE | 13 | Results:NONE | NONE |
| B 6. 180 | RCC PUMP 21 | 1 | 2-1SI-44 | UT0 | FLG BLTS 9-16 | 90-360 | Results:NONE | 14 | Results:NONE | NONE |
| B 6. 180 | RCC PUMP 21 | 1 | 2-1SI-44 | UT0 | FLG BLTS 9-16 | 90-360 | Results:NONE | 15 | Results:NONE | NONE |
| B 6. 180 | RCC PUMP 21 | 1 | 2-1SI-44 | UT0 | FLG BLTS 9-16 | 90-360 | Results:NONE | 16 | Results:NONE | NONE |
| B 6. 180 | RCC PUMP 21 | 1 | 2-1SI-44 | VT1 | FLG BLTS 9-16 | 90-357 | Results:NONE | | Results:NONE | NONE |

NORTHERN STATES POWER COMPANY
PRAIRIE ISLAND UNIT II

TABLE S-II

Examination Comparison Summary

| SUB-ITEM | SYSTEM | CLASS | ISO | METH | ITEM | REPORT | PREVIOUS RESULTS | SCAN | CURRENT RESULTS | LIMITATIONS |
|----------|----------------------|-------|-----------|------|-----------------|--------|------------------|------|-----------------|--------------------------------|
| B 6.180 | RCC PUMP 22 | I | 2-ISI-44 | UTO | FLG BLTS 9-16 | 90-359 | Results:NONE | 9 | Results:NONE | NONE |
| B 6.180 | RCC PUMP 22 | I | 2-ISI-44 | UTO | FLG BLTS 9-16 | 90-359 | Results:NONE | 10 | Results:NONE | NONE |
| B 6.180 | RCC PUMP 22 | I | 2-ISI-44 | UTO | FLG BLTS 9-16 | 90-359 | Results:NONE | 11 | Results:NONE | NONE |
| B 6.180 | RCC PUMP 22 | I | 2-ISI-44 | UTO | FLG BLTS 9-16 | 90-359 | Results:NONE | 12 | Results:NONE | NONE |
| B 6.180 | RCC PUMP 22 | I | 2-ISI-44 | UTO | FLG BLTS 9-16 | 90-359 | Results:NONE | 13 | Results:NONE | NONE |
| B 6.180 | RCC PUMP 22 | I | 2-ISI-44 | UTO | FLG BLTS 9-16 | 90-359 | Results:NONE | 14 | Results:NONE | NONE |
| B 6.180 | RCC PUMP 22 | I | 2-ISI-44 | UTO | FLG BLTS 9-16 | 90-359 | Results:NONE | 15 | Results:NONE | NONE |
| B 6.180 | RCC PUMP 22 | I | 2-ISI-44 | UTO | FLG BLTS 9-16 | 90-359 | Results:NONE | 16 | Results:NONE | NONE |
| B 6.180 | RCC PUMP 22 | I | 2-ISI-44 | VT1 | FLG BLTS 9-16 | 90-358 | Results:NONE | | Results:NONE | NONE |
| B 7.10 | REACTOR VESSEL | I | 2-ISI-38 | VT1 | CLAMP @ 240° | 90-328 | Results:NONE | | Results:NONE | NONE |
| B 7.20 | PRESSURIZER | I | 2-ISI-35 | VT1 | MANWAY 6-10 | 90-400 | Results:NONE | | Results:NONE | NONE |
| B 7.30 | STEAM GENERATOR 21 | I | 2-ISI-37 | MT1 | 1-16 INLET MAN | 90-233 | Results:NONE | | Results:NONE | NONE |
| B 7.30 | STEAM GENERATOR 21 | I | 2-ISI-37 | UTO | 1-16 INLET MAN | 90-261 | Results:NONE | 1L | Results:NONE | NONE |
| B 7.30 | STEAM GENERATOR 21 | I | 2-ISI-37 | VT1 | 1-16 INLET MAN | 90-251 | Results:NONE | | Results:NONE | NONE |
| B 7.30 | STEAM GENERATOR 21 | I | 2-ISI-37 | MT1 | 1-16 OUTLET MAN | 90-234 | Results:NONE | | Results:NONE | NONE |
| B 7.30 | STEAM GENERATOR 21 | I | 2-ISI-37 | UTO | 1-16 OUTLET MAN | 90-262 | Results:NONE | 1L | Results:NONE | NONE |
| B 7.30 | STEAM GENERATOR 21 | I | 2-ISI-37 | VT1 | 1-16 OUTLET MAN | 90-252 | Results:NONE | | Results:NONE | NONE |
| B 7.30 | STEAM GENERATOR 22 | I | 2-ISI-37 | MT1 | 1-16 INLET MAN | 90-235 | Results:NONE | | Results:NONE | NONE |
| B 7.30 | STEAM GENERATOR 22 | I | 2-ISI-37 | UTO | 1-16 INLET MAN | 90-264 | Results:NONE | 1L | Results:NONE | NONE |
| B 7.30 | STEAM GENERATOR 22 | I | 2-ISI-37 | VT1 | 1-16 INLET MAN | 90-253 | Results:NONE | | Results:NONE | NONE |
| B 7.30 | STEAM GENERATOR 22 | I | 2-ISI-37 | MT1 | 1-16 OUTLET MAN | 90-236 | Results:NONE | | Results:NONE | NONE |
| B 7.30 | STEAM GENERATOR 22 | I | 2-ISI-37 | UTO | 1-16 OUTLET MAN | 90-263 | Results:NONE | 1L | Results:NONE | NONE |
| B 7.30 | STEAM GENERATOR 22 | I | 2-ISI-37 | VT1 | 1-16 OUTLET MAN | 90-254 | Results:NONE | | Results:NONE | NONE |
| B 7.40 | LETDOWN HT EXCHANGER | I | 2-ISI-46 | VT1 | FLG BLTS 5-8 | 90-108 | Results:NONE | | Results:NONE | NONE |
| B 7.50 | PRESSURIZER SAFETY A | I | 2-ISI-30 | VT1 | FLG @ 2-8010A | 90-186 | Results:NONE | | Results:NONE | NONE |
| B 7.50 | SEAL INJECTION A | I | 2-ISI-1A | VT1 | FLG @ W-4 | 90-157 | Results:NONE | | Results:NONE | NONE |
| B 7.70 | RHR TAKE OFF HOT A | I | 2-ISI-10C | VT1 | 2-8701A | 90-230 | Results:N/A | | Results:NONE | NONE |
| B 7.70 | RTD RETURN A | I | 2-ISI-6 | VT1 | 2-8001A | 90-158 | Results:NONE | | Results:NONE | NONE |
| B 7.70 | RTD TAKE OFF COLD A | I | 2-ISI-3 | VT1 | 2-2RC-1-7(T-58) | 90-165 | Results:NONE | | Results:NONE | NONE |
| B 7.70 | RTD TAKE OFF HOT A | I | 2-ISI-4 | VT1 | 2-2RC-1-10 T-58 | 90-160 | Results:NONE | | Results:NONE | NONE |
| B 7.70 | RTD TAKE OFF HOT A | I | 2-ISI-4 | VT1 | 2-2RC-1-9(T-58) | 90-159 | Results:NONE | | Results:NONE | NONE |
| B 7.70 | RX SI LOW HEAD A | I | 2-ISI-29 | VT1 | 2-8843A | 90-144 | Results:NONE | | Results:NONE | NONE |
| B 8.20 | PRESSURIZER | I | 2-ISI-36 | UT45 | W-6 120"-216" | 90-330 | Results:NONE | 1 | Results:NONE | NO SCAN 2 DUE TO JOINT CONFIG. |
| B 8.20 | PRESSURIZER | I | 2-ISI-36 | UT45 | W-6 120"-216" | 90-330 | Results:NONE | 3 | Results:NONE | NONE |
| B 8.20 | PRESSURIZER | I | 2-ISI-36 | UT45 | W-6 120"-216" | 90-330 | Results:NONE | 4 | Results:NONE | NONE |

NORTHERN STATES POWER COMPANY
PRAIRIE ISLAND UNIT II

TABLE S-II

Examination Comparison Summary

| SUB-ITEM | SYSTEM | CLASS | ISO | METH | ITEM | REPORT | PREVIOUS RESULTS | SCAN | CURRENT RESULTS | LIMITATIONS |
|----------|----------------------|-------|----------|------|---------------|--------|------------------|------|-----------------|--------------------------------|
| B 8. 20 | PRESSURIZER | I | 2-1S1-36 | VT1 | W-6 120"-216" | 90-329 | Results:NONE | | Results:NONE | NONE |
| B 9. 11 | ACCUMULATOR DISCH A | I | 2-1S1-11 | UT45 | W-1 | 90-394 | Results:NONE | 1 | Results:NONE | NO SCAN 2 CONFIGURATION |
| B 9. 11 | ACCUMULATOR DISCH A | I | 2-1S1-11 | UT45 | W-1 | 90-394 | Results:NONE | 3 | Results:NONE | NONE |
| B 9. 11 | ACCUMULATOR DISCH A | I | 2-1S1-11 | UT45 | W-1 | 90-394 | Results:NONE | 4 | Results:NONE | NONE |
| B 9. 11 | ACCUMULATOR DISCH A | I | 2-1S1-11 | UT45 | W-1 | 90-394 | Results:N/A | 1s | Results:NONE | NO SCANS 3s OR 4s CONFIG. |
| B 9. 11 | ACCUMULATOR DISCH A | I | 2-1S1-11 | UT45 | W-1 | 90-394 | Results:NONE | 2s | Results:NONE | NONE |
| B 9. 11 | ACCUMULATOR DISCH A | I | 2-1S1-11 | VT1 | W-1 | 90-121 | Results:NONE | | Results:NONE | NONE |
| B 9. 11 | PRESSURIZER SAFETY A | I | 2-1S1-30 | PT | W-2 | 90-246 | Results:N/A | | Results:NONE | NONE |
| B 9. 11 | PRESSURIZER SAFETY A | I | 2-1S1-30 | UT45 | W-2 | 90-312 | Results:NONE | 1 | Results:GEO | NONE |
| | | | | | | | | | Scan: 1 | |
| | | | | | | | | | Type:00 | |
| | | | | | | | | | Amplitude:50 | |
| | | | | | | | | | Ax Loc: | |
| | | | | | | | | | Circ Loc: | |
| | | | | | | | | | Length:360° | |
| B 9. 11 | PRESSURIZER SAFETY A | I | 2-1S1-30 | UT45 | W-2 | 90-312 | Results:NONE | 2 | Results:NONE | NONE |
| B 9. 11 | PRESSURIZER SAFETY A | I | 2-1S1-30 | UT45 | W-2 | 90-312 | Results:NONE | 3 | Results:NONE | NONE |
| B 9. 11 | PRESSURIZER SAFETY A | I | 2-1S1-30 | UT45 | W-2 | 90-312 | Results:NONE | 4 | Results:NONE | NONE |
| B 9. 11 | PRESSURIZER SAFETY A | I | 2-1S1-30 | UT45 | W-2 | 90-312 | Results:N/A | 1s | Results:NONE | NONE |
| B 9. 11 | PRESSURIZER SAFETY A | I | 2-1S1-30 | UT45 | W-2 | 90-312 | Results:N/A | 2s | Results:NONE | NONE |
| B 9. 11 | PRESSURIZER SAFETY A | I | 2-1S1-30 | UT45 | W-2 | 90-312 | Results:N/A | 3s | Results:NONE | NONE |
| B 9. 11 | PRESSURIZER SAFETY A | I | 2-1S1-30 | UT45 | W-2 | 90-312 | Results:N/A | 4s | Results:NONE | NONE |
| B 9. 11 | PRESSURIZER SAFETY A | I | 2-1S1-30 | VT1 | W-2 | 90-255 | Results:NONE | | Results:NONE | NONE |
| B 9. 11 | PRESSURIZER SAFETY B | I | 2-1S1-30 | PT | W-7 | 90-248 | Results:N/A | | Results:NONE | NONE |
| B 9. 11 | PRESSURIZER SAFETY B | I | 2-1S1-30 | UT45 | W-7 | 90-311 | Results:NONE | 1 | Results:NONE | BEST EFFORT ELBOW INNER RADIUS |
| B 9. 11 | PRESSURIZER SAFETY B | I | 2-1S1-30 | UT45 | W-7 | 90-311 | Results:NONE | 2 | Results:NONE | LMT'D 6:00 DRAIN LINE |
| B 9. 11 | PRESSURIZER SAFETY B | I | 2-1S1-30 | UT45 | W-7 | 90-311 | Results:NONE | 3 | Results:NONE | NONE |
| B 9. 11 | PRESSURIZER SAFETY B | I | 2-1S1-30 | UT45 | W-7 | 90-311 | Results:NONE | 4 | Results:NONE | NONE |
| B 9. 11 | PRESSURIZER SAFETY B | I | 2-1S1-30 | UT45 | W-7 | 90-311 | Results:N/A | 1s | Results:NONE | NONE |
| B 9. 11 | PRESSURIZER SAFETY B | I | 2-1S1-30 | UT45 | W-7 | 90-311 | Results:N/A | 2s | Results:NONE | NONE |
| B 9. 11 | PRESSURIZER SAFETY B | I | 2-1S1-30 | UT45 | W-7 | 90-311 | Results:N/A | 3s | Results:NONE | NONE |
| B 9. 11 | PRESSURIZER SAFETY B | I | 2-1S1-30 | UT45 | W-7 | 90-311 | Results:N/A | 4s | Results:NONE | NONE |
| B 9. 11 | PRESSURIZER SAFETY B | I | 2-1S1-30 | VT1 | W-7 | 90-256 | Results:NONE | | Results:NONE | NONE |
| B 9. 11 | PRESSURIZER SAFETY B | I | 2-1S1-30 | PT | W-8 | 90-249 | Results:N/A | | Results:NONE | NONE |
| B 9. 11 | PRESSURIZER SAFETY B | I | 2-1S1-30 | VT1 | W-8 | 90-257 | Results:NONE | | Results:NONE | NONE |

NORTHERN STATES POWER COMPANY
PRAIRIE ISLAND UNIT II

TABLE S-II

Examination Comparison Summary

| SUB-ITEM | SYSTEM | CLASS | ISO | METH | ITEM | REPORT | PREVIOUS RESULTS | SCAN | CURRENT RESULTS | LIMITATIONS |
|----------|--------------------|-------|-----------|------|----------|--------|------------------|------|-------------------|--------------------------------|
| B 9. 11 | RCC COLD LEG B | I | 2-1S1-33 | PT | RCC-B-11 | 90-291 | Results:NONE | | Results:NONE | NONE |
| B 9. 11 | RCC COLD LEG B | I | 2-1S1-33 | UT45 | RCC-B-11 | 90-300 | Results:NONE | 2 | Results:NONE | NO SCAN 1 CONFIGURATION |
| B 9. 11 | RCC COLD LEG B | I | 2-1S1-33 | UT45 | RCC-B-11 | 90-300 | Results:NONE | 3 | Results:NONE | NONE |
| B 9. 11 | RCC COLD LEG B | I | 2-1S1-33 | UT45 | RCC-B-11 | 90-300 | Results:NONE | 4 | Results:NONE | NONE |
| B 9. 11 | RCC COLD LEG B | I | 2-1S1-33 | VT1 | RCC-B-11 | 90-294 | Results:NONE | | Results:NONE | NONE |
| B 9. 11 | RHR TAKE OFF HOT A | I | 2-1S1-10A | PT | W-1 | 90-331 | Results:NONE | | Results:NONE | NONE |
| B 9. 11 | RHR TAKE OFF HOT A | I | 2-1S1-10A | UT45 | W-1 | 90-407 | Results:NONE | 2 | Results:NONE | NO SCAN 1 CONFIGURATION |
| B 9. 11 | RHR TAKE OFF HOT A | I | 2-1S1-10A | UT45 | W-1 | 90-407 | Results:NONE | 3 | Results:NONE | NONE |
| B 9. 11 | RHR TAKE OFF HOT A | I | 2-1S1-10A | UT45 | W-1 | 90-407 | Results:NONE | 4 | Results:NONE | NONE |
| B 9. 11 | RHR TAKE OFF HOT A | I | 2-1S1-10A | UT45 | W-1 | 90-407 | Results:N/A | 3s | Results:NONE | NO SCAN 1s OR 2s CONFIGURATION |
| B 9. 11 | RHR TAKE OFF HOT A | I | 2-1S1-10A | UT45 | W-1 | 90-407 | Results:N/A | 4s | Results:NONE | NONE |
| B 9. 11 | RHR TAKE OFF HOT A | I | 2-1S1-10A | VT1 | W-1 | 90-341 | Results:NONE | | Results:NONE | NONE |
| B 9. 11 | RHR TAKE OFF HOT A | I | 2-1S1-10A | PT | W-4 | 90-339 | Results:N/A | | Results:NONE | NONE |
| B 9. 11 | RHR TAKE OFF HOT A | I | 2-1S1-10A | UT45 | W-4 | 90-408 | Results:NONE | 1 | Results:GEO | NONE |
| | | | | | | | | | Scan: 1 | |
| | | | | | | | | | Type:00 | |
| | | | | | | | | | Amplitude:50 | |
| | | | | | | | | | Ax Loc: | |
| | | | | | | | | | Circ Loc: | |
| | | | | | | | | | Length:5" 2 AREAS | |
| B 9. 11 | RHR TAKE OFF HOT A | I | 2-1S1-10A | UT45 | W-4 | 90-408 | Results:NONE | 2 | Results:NONE | NONE |
| B 9. 11 | RHR TAKE OFF HOT A | I | 2-1S1-10A | UT45 | W-4 | 90-408 | Results:NONE | 3 | Results:NONE | NONE |
| B 9. 11 | RHR TAKE OFF HOT A | I | 2-1S1-10A | UT45 | W-4 | 90-408 | Results:NONE | 4 | Results:NONE | NONE |
| B 9. 11 | RHR TAKE OFF HOT A | I | 2-1S1-10A | UT45 | W-4 | 90-408 | Results:N/A | | Results:NONE | NONE |
| B 9. 11 | RHR TAKE OFF HOT A | I | 2-1S1-10A | UT45 | W-4 | 90-408 | Results:N/A | 2s | Results:NONE | NONE |
| B 9. 11 | RHR TAKE OFF HOT A | I | 2-1S1-10A | UT45 | W-4 | 90-408 | Results:N/A | 3s | Results:NONE | NONE |
| B 9. 11 | RHR TAKE OFF HOT A | I | 2-1S1-10A | UT45 | W-4 | 90-408 | Results:N/A | 4s | Results:NONE | NONE |
| B 9. 11 | RHR TAKE OFF HOT A | I | 2-1S1-10A | VT1 | W-4 | 90-350 | Results:NONE | | Results:NONE | NONE |
| B 9. 11 | RHR TAKE OFF HOT A | I | 2-1S1-10A | PT | W-5 | 90-340 | Results:N/A | | Results:NONE | NONE |
| B 9. 11 | RHR TAKE OFF HOT A | I | 2-1S1-10A | UT45 | W-5 | 90-409 | Results:NONE | 1 | Results:NONE | NONE |
| B 9. 11 | RHR TAKE OFF HOT A | I | 2-1S1-10A | UT45 | W-5 | 90-409 | Results:NONE | 2 | Results:GEO | NONE |
| | | | | | | | | | Scan: 2 | |
| | | | | | | | | | Type:10 CB | |
| | | | | | | | | | Amplitude:30 | |
| | | | | | | | | | Ax Loc: | |
| | | | | | | | | | Circ Loc: | |
| | | | | | | | | | Length:360° INTER | |

NORTHERN STATES POWER COMPANY
PRAIRIE ISLAND UNIT II

TABLE S-II

Examination Comparison Summary

| SUB-ITEM | SYSTEM | CLASS | ISO | METH | ITEM | REPORT | PREVIOUS RESULTS | SCAN | CURRENT RESULTS | LIMITATIONS |
|----------|--------------------|-------|-----------|------|------|--------|------------------|------|---|--------------------------------|
| B 9. 11 | RHR TAKE OFF HOT A | I | 2-ISI-10A | UT45 | W-5 | 90-409 | Results:NONE | 2 | Results:GEO Scan: 2 Type:00 Amplitude:100 Ax Loc: Circ Loc: Length:9.0" - 18" | NONE |
| B 9. 11 | RHR TAKE OFF HOT A | I | 2-ISI-10A | UT45 | W-5 | 90-409 | Results:NONE | 3 | Results:NONE | NONE |
| B 9. 11 | RHR TAKE OFF HOT A | I | 2-ISI-10A | UT45 | W-5 | 90-409 | Results:NONE | 4 | Results:NONE | NONE |
| B 9. 11 | RHR TAKE OFF HOT A | I | 2-ISI-10A | UT45 | W-5 | 90-409 | Results:N/A | 1s | Results:NONE | NONE |
| B 9. 11 | RHR TAKE OFF HOT A | I | 2-ISI-10A | UT45 | W-5 | 90-409 | Results:N/A | 2s | Results:NONE | NONE |
| B 9. 11 | RHR TAKE OFF HOT A | I | 2-ISI-10A | UT45 | W-5 | 90-409 | Results:N/A | 3s | Results:NONE | NONE |
| B 9. 11 | RHR TAKE OFF HOT A | I | 2-ISI-10A | UT45 | W-5 | 90-409 | Results:N/A | 4s | Results:NONE | NONE |
| B 9. 11 | RHR TAKE OFF HOT A | I | 2-ISI-10A | VT1 | W-5 | 90-351 | Results:NONE | | Results:NONE | NONE |
| B 9. 11 | RHR TAKE OFF HOT B | I | 2-ISI-20A | PT | W-1 | 90-374 | Results:N/A | | Results:NONE | NONE |
| B 9. 11 | RHR TAKE OFF HOT B | I | 2-ISI-20A | UT45 | W-1 | 90-410 | Results:NONE | 2 | Results:GEO Scan: ? Type:ID Amplitude:30 Ax Loc: Circ Loc: Length:360" | NO SCAN 1 CONFIGURATION |
| B 9. 11 | RHR TAKE OFF HOT B | I | 2-ISI-20A | UT45 | W-1 | 90-410 | Results:NONE | 3 | Results:NONE | NONE |
| B 9. 11 | RHR TAKE OFF HOT B | I | 2-ISI-20A | UT45 | W-1 | 90-410 | Results:NONE | 4 | Results:NONE | NONE |
| B 9. 11 | RHR TAKE OFF HOT B | I | 2-ISI-20A | UT45 | W-1 | 90-410 | Results:NONE | 3s | Results:NONE | NO SCANS 1s OR 2s CONFIG. |
| B 9. 11 | RHR TAKE OFF HOT B | I | 2-ISI-20A | UT45 | W-1 | 90-410 | Results:N/A | 4s | Results:NONE | NONE |
| B 9. 11 | RHR TAKE OFF HOT B | I | 2-ISI-20A | VT1 | W-1 | 90-353 | Results:NONE | | Results:NONE | NONE |
| B 9. 11 | RHR TAKE OFF HOT B | I | 2-ISI-20A | PT | W-5 | 90-375 | Results:N/A | | Results:NONE | NONE |
| B 9. 11 | RHR TAKE OFF HOT B | I | 2-ISI-20A | UT45 | W-5 | 90-411 | Results:NONE | 1 | Results:NONE | NO SCAN 2,3,3s & 4s DOWNSTREAM |
| B 9. 11 | RHR TAKE OFF HOT B | I | 2-ISI-20A | UT45 | W-5 | 90-411 | Results:NONE | 2 | Results:NONE | OBSTRUCTED @ 10:-12:00, |
| B 9. 11 | RHR TAKE OFF HOT B | I | 2-ISI-20A | UT45 | W-5 | 90-411 | Results:NONE | 3 | Results:NONE | 12:-4:00 DUE TO RESTRAINT |
| B 9. 11 | RHR TAKE OFF HOT B | I | 2-ISI-20A | UT45 | W-5 | 90-411 | Results:NONE | 4 | Results:NONE | NONE |
| B 9. 11 | RHR TAKE OFF HOT B | I | 2-ISI-20A | UT45 | W-5 | 90-411 | Results:N/A | 1s | Results:NONE | NONE |
| B 9. 11 | RHR TAKE OFF HOT B | I | 2-ISI-20A | UT45 | W-5 | 90-411 | Results:N/A | 2s | Results:NONE | NONE |
| B 9. 11 | RHR TAKE OFF HOT B | I | 2-ISI-20A | UT45 | W-5 | 90-411 | Results:N/A | 3s | Results:NONE | NONE |

NORTHERN STATES POWER COMPANY
PRAIRIE ISLAND UNIT II

TABLE S-II

Examination Comparison Summary

| SUB-ITEM | SYSTEM | CLASS | ISO | METH | ITEM | REPORT | PREVIOUS RESULTS | SCAN | CURRENT RESULTS | LIMITATIONS |
|----------|--------------------|-------|-----------|------|------|--------|------------------|------|---|-------------|
| B 9. 11 | RHR TAKE OFF HOT B | I | 2-1S1-20A | UT45 | W-5 | 90-411 | Results:N/A | 4s | Results:NONE | NONE |
| B 9. 11 | RHR TAKE OFF HOT B | I | 2-1S1-20A | VT1 | W-5 | 90-354 | Results:NONE | | Results:NONE | NONE |
| B 9. 11 | RHR TAKE OFF HOT B | I | 2-1S1-20A | PT | W-5A | 90-376 | Results:N/A | | Results:NONE | NONE |
| B 9. 11 | RHR TAKE OFF HOT B | I | 2-1S1-20A | UT45 | W-5A | 90-412 | Results:NONE | 1 | Results:GEO Scan: 1 Type:ID ROOT Amplitude:55 Ax Loc: Circ Loc: Length:360" INTER | NONE |
| B 9. 11 | RHR TAKE OFF HOT B | I | 2-1S1-20A | UT45 | W-5A | 90-412 | Results:NONE | 2 | Results:GEO Scan: 2 Type:ID ROOT Amplitude:40 Ax Loc: Circ Loc: Length:750" INTER | NONE |
| B 9. 11 | RHR TAKE OFF HOT B | I | 2-1S1-20A | UT45 | W-5A | 90-412 | Results:NONE | 3 | Results:NONE | NONE |
| B 9. 11 | RHR TAKE OFF HOT B | I | 2-1S1-20A | UT45 | W-5A | 90-412 | Results:NONE | 4 | Results:NONE | NONE |
| B 9. 11 | RHR TAKE OFF HOT B | I | 2-1S1-20A | UT45 | W-5A | 90-412 | Results:N/A | 1s | Results:NONE | NONE |
| B 9. 11 | RHR TAKE OFF HOT B | I | 2-1S1-20A | UT45 | W-5A | 90-412 | Results:N/A | 2s | Results:NONE | NONE |
| B 9. 11 | RHR TAKE OFF HOT B | I | 2-1S1-20A | UT45 | W-5A | 90-412 | Results:N/A | 3s | Results:NONE | NONE |
| B 9. 11 | RHR TAKE OFF HOT B | I | 2-1S1-20A | UT45 | W-5A | 90-412 | Results:N/A | 4s | Results:NONE | NONE |
| B 9. 11 | RHR TAKE OFF HOT B | I | 2-1S1-20A | VT1 | W-5A | 90-355 | Results:NONE | | Results:NONE | NONE |
| B 9. 11 | RHR TAKE OFF HOT B | I | 2-1S1-20A | PT | W-6 | 90-377 | Results:N/A | | Results:IND Type:LINEAR Ax Loc:- 0.25" Circ Loc:0.0" Length:3/16" | NONE |
| B 9. 11 | RHR TAKE OFF HOT B | I | 2-1S1-20A | PT | W-6 | 90-377 | Results:N/A | | Results:IND Type:LINEAR Ax Loc:+ 0.25" Circ Loc:2.0" CCW Length:3/16" | NONE |
| B 9. 11 | RHR TAKE OFF HOT B | I | 2-1S1-20A | PT | W-6 | 90-377 | Results:N/A | | Results:IND Type:LINEAR Ax Loc:WELD CL Circ Loc:2.5" CCW Length:1/4" | NONE |

TABLE S-II

NORTHERN STATES POWER COMPANY
PRAIRIE ISLAND UNIT II

Examination Comparison Summary

| SUB-ITEM | SYSTEM | CLASS | ISO | METH | ITEM | REPORT | PREVIOUS RESULTS | SCAN | CURRENT RESULTS | LIMITATIONS |
|----------|--------------------|-------|-----------|------|------|--------|--|------|--|-------------|
| B 9. 11 | RHR TAKE OFF HOT B | I | 2-1S1-20A | UT45 | W-6 | 90-413 | Results:NONE | 1 | Results:NONE | NONE |
| B 9. 11 | RHR TAKE OFF HOT B | I | 2-1S1-20A | UT45 | W-6 | 90-413 | Results:GEO Scan:2 Type:00 Amplitude:50% Ax Loc: Circ Loc: Length: | 2 | Results:NONE | NONE |
| B 9. 11 | RHR TAKE OFF HOT B | I | 2-1S1-20A | UT45 | W-6 | 90-413 | Results:NONE | 3 | Results:NONE | NONE |
| B 9. 11 | RHR TAKE OFF HOT B | I | 2-1S1-20A | UT45 | W-6 | 90-413 | Results:NONE | 4 | Results:NONE | NONE |
| B 9. 11 | RHR TAKE OFF HOT B | I | 2-1S1-20A | UT45 | W-6 | 90-413 | Results:N/A | 1s | Results:NONE | NONE |
| B 9. 11 | RHR TAKE OFF HOT B | I | 2-1S1-20A | UT45 | W-6 | 90-413 | Results:N/A | 2s | Results:NONE | NONE |
| B 9. 11 | RHR TAKE OFF HOT B | I | 2-1S1-20A | UT45 | W-6 | 90-413 | Results:N/A | 3s | Results:NONE | NONE |
| B 9. 11 | RHR TAKE OFF HOT B | I | 2-1S1-20A | UT45 | W-6 | 90-413 | Results:N/A | 4s | Results:NONE | NONE |
| B 9. 11 | RHR TAKE OFF HOT B | I | 2-1S1-20A | VT1 | W-6 | 90-356 | Results:NONE | | Results:NONE | NONE |
| B 9. 11 | RHR TAKE OFF HOT B | I | 2-1S1-20A | PT | W-9 | 90-149 | Results:N/A | | Results:NONE | NONE |
| B 9. 11 | RHR TAKE OFF HOT B | I | 2-1S1-20B | PT | W-13 | 90-180 | Results:N/A | | Results:NONE | NONE |
| B 9. 11 | RHR TAKE OFF HOT B | I | 2-1S1-20B | UT45 | W-13 | 90-185 | Results:N/A | 1 | Results:GEO Scan: 1 Type:10 Amplitude:25 Ax Loc: Circ Loc: Length:360° INTER | NONE |
| B 9. 11 | RHR TAKE OFF HOT B | I | 2-1S1-20B | UT45 | W-13 | 90-185 | Results:N/A | 1 | Results:GEO Scan: 1 Type:00 Amplitude:40 Ax Loc: Circ Loc: Length:360° INTER | NONE |
| B 9. 11 | RHR TAKE OFF HOT B | I | 2-1S1-20B | UT45 | W-13 | 90-185 | Results:N/A | 2 | Results:NONE | NONE |
| B 9. 11 | RHR TAKE OFF HOT B | I | 2-1S1-20B | UT45 | W-13 | 90-185 | Results:N/A | 3 | Results:NONE | NONE |
| B 9. 11 | RHR TAKE OFF HOT B | I | 2-1S1-20B | UT45 | W-13 | 90-185 | Results:N/A | 4 | Results:NONE | NONE |
| B 9. 11 | RHR TAKE OFF HOT B | I | 2-1S1-20B | UT45 | W-13 | 90-185 | Results:N/A | 1s | Results:NONE | NONE |

NORTHERN STATES POWER COMPANY
PRAIRIE ISLAND UNIT II

TABLE S-II

Examination Comparison Summary

| SUB-ITEM | SYSTEM | CLASS | ISO | METH | ITEM | REPORT | PREVIOUS RESULTS | SCAN | CURRENT RESULTS | LIMITATIONS |
|----------|--------------------|-------|-----------|------|------|--------|------------------|------|-----------------|--------------------------------|
| B 9. 11 | RHR TAKE OFF HOT B | I | 2-1S1-20B | UT45 | W-13 | 90-185 | Results:N/A | 2s | Results:NONE | NONE |
| B 9. 11 | RHR TAKE OFF HOT B | I | 2-1S1-20B | UT45 | W-13 | 90-185 | Results:N/A | 3s | Results:NONE | NONE |
| B 9. 11 | RHR TAKE OFF HOT B | I | 2-1S1-20B | UT45 | W-13 | 90-185 | Results:N/A | 4s | Results:NONE | NONE |
| B 9. 11 | RHR TAKE OFF HOT B | I | 2-1S1-20B | VT1 | W-13 | 90-181 | Results:N/A | | Results:NONE | NONE |
| B 9. 11 | SPRAY TO PZR BR A | I | 2-1S1- 7A | UT45 | W-10 | 90-182 | Results:NONE | 1 | Results:NONE | ALL SCAN LMT'D 7:-11:00 DUE TO |
| B 9. 11 | SPRAY TO PZR BR A | I | 2-1S1- 7A | UT45 | W-10 | 90-182 | Results:NONE | 2 | Results:NONE | WELDED SUPPORT |
| B 9. 11 | SPRAY TO PZR BR A | I | 2-1S1- 7A | UT45 | W-10 | 90-182 | Results:NONE | 3 | Results:NONE | NONE |
| B 9. 11 | SPRAY TO PZR BR A | I | 2-1S1- 7A | UT45 | W-10 | 90-182 | Results:NONE | 4 | Results:NONE | NONE |
| B 9. 11 | SPRAY TO PZR BR A | I | 2-1S1- 7A | UT45 | W-10 | 90-182 | Results:NONE | 1s | Results:NONE | NONE |
| B 9. 11 | SPRAY TO PZR BR A | I | 2-1S1- 7A | UT45 | W-10 | 90-182 | Results:NONE | 2s | Results:NONE | NONE |
| B 9. 11 | SPRAY TO PZR BR A | I | 2-1S1- 7A | UT45 | W-10 | 90-182 | Results:NONE | 3s | Results:NONE | NONE |
| B 9. 11 | SPRAY TO PZR BR A | I | 2-1S1- 7A | UT45 | W-10 | 90-182 | Results:NONE | 4s | Results:NONE | NONE |
| B 9. 11 | SPRAY TO PZR BR A | I | 2-1S1- 7A | UT45 | W-11 | 90-184 | Results:NONE | 1 | Results:NONE | SCANS 1,3,4,1s & 2s OBSTRUCT |
| B 9. 11 | SPRAY TO PZR BR A | I | 2-1S1- 7A | UT45 | W-11 | 90-184 | Results:NONE | 2 | Results:NONE | @ 8:-10:00 DUE TO WELDED |
| B 9. 11 | SPRAY TO PZR BR A | I | 2-1S1- 7A | UT45 | W-11 | 90-184 | Results:NONE | 3 | Results:NONE | SUPPORT |
| B 9. 11 | SPRAY TO PZR BR A | I | 2-1S1- 7A | UT45 | W-11 | 90-184 | Results:NONE | 4 | Results:NONE | NONE |
| B 9. 11 | SPRAY TO PZR BR A | I | 2-1S1- 7A | UT45 | W-11 | 90-184 | Results:NONE | 1s | Results:NONE | NONE |
| B 9. 11 | SPRAY TO PZR BR A | I | 2-1S1- 7A | UT45 | W-11 | 90-184 | Results:NONE | 2s | Results:NONE | NONE |
| B 9. 11 | SPRAY TO PZR BR A | I | 2-1S1- 7A | UT45 | W-11 | 90-184 | Results:NONE | 3s | Results:NONE | NONE |
| B 9. 11 | SPRAY TO PZR BR A | I | 2-1S1- 7A | UT45 | W-11 | 90-184 | Results:NONE | 4s | Results:NONE | NONE |
| B 9. 11 | SPRAY TO PZR BR A | I | 2-1S1- 7A | UT45 | W-9 | 90-183 | Results:NONE | 1 | Results:NONE | SCANS 2,3,4,3s, & 4s OBSTRUCT |
| B 9. 11 | SPRAY TO PZR BR A | I | 2-1S1- 7A | UT45 | W-9 | 90-183 | Results:NONE | 2 | Results:NONE | @ 7:-8:00 DUE TO WELDED |
| B 9. 11 | SPRAY TO PZR BR A | I | 2-1S1- 7A | UT45 | W-9 | 90-183 | Results:NONE | 3 | Results:NONE | SUPPORT |
| B 9. 11 | SPRAY TO PZR BR A | I | 2-1S1- 7A | UT45 | W-9 | 90-183 | Results:NONE | 4 | Results:NONE | NONE |
| B 9. 11 | SPRAY TO PZR BR A | I | 2-1S1- 7A | UT45 | W-9 | 90-183 | Results:NONE | 1s | Results:NONE | NONE |
| B 9. 11 | SPRAY TO PZR BR A | I | 2-1S1- 7A | UT45 | W-9 | 90-183 | Results:NONE | 2s | Results:NONE | NONE |
| B 9. 11 | SPRAY TO PZR BR A | I | 2-1S1- 7A | UT45 | W-9 | 90-183 | Results:NONE | 3s | Results:NONE | NONE |
| B 9. 11 | SPRAY TO PZR BR A | I | 2-1S1- 7A | UT45 | W-9 | 90-183 | Results:NONE | 4s | Results:NONE | NONE |
| B 9. 21 | AUX SPRAY TO PZR | I | 2-1S1-24 | PT | W-17 | 90-292 | Results:N/A | | Results:NONE | NONE |
| B 9. 21 | AUX SPRAY TO PZR | I | 2-1S1-24 | VT1 | W-17 | 90-295 | Results:NONE | | Results:NONE | NONE |
| B 9. 21 | CHARGING LINE B | I | 2-1S1-13A | PT | W-1 | 90-152 | Results:NONE | | Results:NONE | NONE |
| B 9. 21 | CHARGING LINE B | I | 2-1S1-13A | VT1 | W-1 | 90-212 | Results:NONE | | Results:NONE | NONE |
| B 9. 21 | CHARGING LINE B | I | 2-1S1-13A | PT | W-6 | 90-328 | Results:N/A | | Results:NONE | NONE |
| B 9. 21 | CHARGING LINE B | I | 2-1S1-13A | VT1 | W-6 | 90-213 | Results:NONE | | Results:NONE | NONE |
| B 9. 21 | CHARGING LINE B | I | 2-1S1-13C | PT | W-66 | 90-142 | Results:N/A | | Results:NONE | NONE |

NORTHERN STATES POWER COMPANY
PRAIRIE ISLAND UNIT II

TABLE S-II

Examination Comparison Summary

| SUB-ITEM | SYSTEM | CLASS | ISO | METH | ITEM | REPORT | PREVIOUS RESULTS | SCAN | CURRENT RESULTS | LIMITATIONS |
|----------|----------------------|-------|-----------|------|------|--------|------------------|------|-----------------|-------------------------|
| B 9. 21 | CHARGING LINE B | I | 2-ISI-13C | VT1 | W-66 | 90-214 | Results:NONE | | Results:NONE | NONE |
| B 9. 21 | LETDOWN LINE B | I | 2-ISI-16 | PT | W-2 | 90-390 | Results:N/A | | Results:NONE | NONE |
| B 9. 21 | LETDOWN LINE B | I | 2-ISI-16 | VT1 | W-2 | 90-215 | Results:NONE | | Results:NONE | NONE |
| B 9. 21 | PRESSURIZER RELIEF B | I | 2-ISI-27 | PT | W-2 | 90-250 | Results:N/A | | Results:NONE | NONE |
| B 9. 21 | PRESSURIZER RELIEF B | I | 2-ISI-27 | VT1 | W-2 | 90-258 | Results:NONE | | Results:NONE | NONE |
| B 9. 21 | RTD RETURN A | I | 2-ISI- 6 | PT | W-1 | 90-117 | Results:N/A | | Results:NONE | NONE |
| B 9. 21 | RTD RETURN A | I | 2-ISI- 6 | VT1 | W-1 | 90-120 | Results:NONE | | Results:NONE | NONE |
| B 9. 21 | RTD TAKE OFF COLD A | I | 2-ISI- 3 | PT | W-7 | 90-115 | Results:N/A | | Results:NONE | NONE |
| B 9. 21 | RTD TAKE OFF COLD A | I | 2-ISI- 3 | VT1 | W-7 | 90-119 | Results:NONE | | Results:NONE | NONE |
| B 9. 21 | RTD TAKE OFF HOT A | I | 2-ISI- 4 | PT | W-30 | 90-133 | Results:N/A | | Results:NONE | NONE |
| B 9. 21 | RTD TAKE OFF HOT A | I | 2-ISI- 4 | VT1 | W-30 | 90-122 | Results:N/A | | Results:NONE | NONE |
| B 9. 21 | RX SI LOW HEAD A | I | 2-ISI-25 | PT | W-11 | 90-315 | Results:N/A | | Results:NONE | NONE |
| B 9. 21 | RX SI LOW HEAD A | I | 2-ISI-25 | VT1 | W-11 | 90-320 | Results:NONE | | Results:NONE | NONE |
| B 9. 21 | SEAL INJECTION A | I | 2-ISI- 1A | PT | W-14 | 90-314 | Results:N/A | | Results:NONE | NONE |
| B 9. 21 | SEAL INJECTION A | I | 2-ISI- 1A | VT1 | W-14 | 90-319 | Results:NONE | | Results:NONE | NONE |
| B 9. 21 | SEAL INJECTION A | I | 2-ISI- 1A | PT | W-2 | 90-313 | Results:N/A | | Results:NONE | NONE |
| B 9. 21 | SEAL INJECTION A | I | 2-ISI- 1A | VT1 | W-2 | 90-318 | Results:NONE | | Results:NONE | NONE |
| B 9. 21 | SEAL INJECTION B | I | 2-ISI-12A | PT | W-40 | 90-271 | Results:N/A | | Results:NONE | NONE |
| B 9. 21 | SEAL INJECTION B | I | 2-ISI-12A | VT1 | W-40 | 90-282 | Results:NONE | | Results:NONE | NONE |
| B 9. 21 | SEAL INJECTION B | I | 2-ISI-12A | PT | W-52 | 90-272 | Results:N/A | | Results:NONE | NONE |
| B 9. 21 | SEAL INJECTION B | I | 2-ISI-12A | VT1 | W-52 | 90-283 | Results:NONE | | Results:NONE | NONE |
| B 9. 21 | SI HIGH HEAD A | I | 2-ISI- 5 | PT | W-6 | 90-116 | Results:N/A | | Results:NONE | NONE |
| B 9. 21 | SI HIGH HEAD A | I | 2-ISI- 5 | VT1 | W-6 | 90-118 | Results:NONE | | Results:NONE | NONE |
| B 9. 21 | SPRAY TO PZR BR B | I | 2-ISI- 7D | PT | W-1 | 90-307 | Results:N/A | | Results:NONE | NONE |
| B 9. 21 | SPRAY TO PZR BR B | I | 2-ISI- 7D | VT1 | W-1 | 90-308 | Results:NONE | | Results:NONE | NONE |
| B 9. 31 | ACCUMULATOR DISCH B | I | 2-ISI-22 | PT | W-R | 90-075 | Results:N/A | | Results:NONE | NONE |
| B 9. 31 | ACCUMULATOR DISCH B | I | 2-ISI-22 | UT45 | W-R | 90-393 | Results:NONE | 1 | Results:NONE | NO SCAN 2 NOZZLE |
| B 9. 31 | ACCUMULATOR DISCH B | I | 2-ISI-22 | UT45 | W-R | 90-393 | Results:NONE | 3 | Results:NONE | NONE |
| B 9. 31 | ACCUMULATOR DISCH B | I | 2-ISI-22 | UT45 | W-R | 90-393 | Results:NONE | 4 | Results:NONE | NONE |
| B 9. 31 | ACCUMULATOR DISCH B | I | 2-ISI-22 | UT45 | W-R | 90-393 | Results:N/A | 1s | Results:NONE | NO SCAN 3s OR 4s NOZZLE |
| B 9. 31 | ACCUMULATOR DISCH B | I | 2-ISI-22 | UT45 | W-R | 90-393 | Results:N/A | 2s | Results:NONE | NONE |
| B 9. 31 | ACCUMULATOR DISCH B | I | 2-ISI-22 | VT1 | W-R | 90-296 | Results:NONE | | Results:NONE | NONE |
| B 9. 31 | SI HIGH HEAD A | I | 2-ISI- 8 | PT | W-R | 90-134 | Results:NONE | | Results:NONE | NONE |
| B 9. 31 | SI HIGH HEAD A | I | 2-ISI- 8 | UT45 | W-R | 90-392 | Results:NONE | 1 | Results:NONE | NO SCAN 2 NOZZLE |
| B 9. 31 | SI HIGH HEAD A | I | 2-ISI- 8 | UT45 | W-R | 90-392 | Results:NONE | 3 | Results:NONE | NONE |

NORTHERN STATES POWER COMPANY
PRAIRIE ISLAND UNIT II

TABLE S-II

Examination Comparison Summary

| SUB-ITEM | SYSTEM | CLASS | ISO | METH | ITEM | REPORT | PREVIOUS RESULTS | SCAN | CURRENT RESULTS | LIMITATIONS |
|----------|---------------------|-------|-----------|------|-------------|--------|------------------|------|-----------------|-------------------------|
| B 9. 31 | SI HIGH HEAD A | I | 2-1S1- 8 | UT45 | W-R | 90-392 | Results:NONE | 4 | Results:NONE | NONE |
| B 9. 31 | SI HIGH HEAD A | I | 2-1S1- 8 | UT45 | W-R | 90-392 | Results:N/A | 1s | Results:NONE | NO SCAN 3s OR 4s NOZZLE |
| B 9. 31 | SI HIGH HEAD A | I | 2-1S1- 8 | UT45 | W-R | 90-392 | Results:N/A | 2s | Results:NONE | NONE |
| B 9. 31 | SI HIGH HEAD A | I | 2-1S1- 8 | VT1 | W-R | 90-123 | Results:N/A | | Results:NONE | NONE |
| B 9. 32 | RX SI LOW HEAD A | I | 2-1S1-25 | PT | W-1 | 90-316 | Results:NONE | | Results:NONE | NONE |
| B 9. 32 | RX SI LOW HEAD A | I | 2-1S1-25 | VT1 | W-1 | 90-321 | Results:NONE | | Results:NONE | NONE |
| B 9. 32 | SPRAY TO PZR BR B | I | 2-1S1- 7D | PT | W-R | 90-309 | Results:NONE | | Results:NONE | NONE |
| B 9. 32 | SPRAY TO PZR BR B | I | 2-1S1- 7D | VT1 | W-R | 90-310 | Results:NONE | | Results:NONE | NONE |
| B 9. 40 | ACCUMULATOR DISCH A | I | 2-1S1-11 | PT | W-1 | 90-132 | Results:N/A | | Results:NONE | NONE |
| B 9. 40 | LETDOWN LINE B | I | 2-1S1-16 | PT | W-18 | 90-143 | Results:NONE | | Results:NONE | NONE |
| B 9. 40 | LETDOWN LINE B | I | 2-1S1-16 | VT1 | W-18 | 90-216 | Results:NONE | | Results:NONE | NONE |
| B 9. 40 | RTD TAKE OFF COLD B | I | 2-1S1-14 | PT | W-7 | 90-153 | Results:NONE | | Results:NONE | NONE |
| B 9. 40 | RTD TAKE OFF COLD B | I | 2-1S1-14 | VT1 | W-7 | 90-217 | Results:NONE | | Results:NONE | NONE |
| B 9. 40 | RTD TAKE OFF HOT B | I | 2-1S1-15 | PT | W-30 | 90-154 | Results:NONE | | Results:NONE | NONE |
| B 9. 40 | RTD TAK OFF HOT B | I | 2-1S1-15 | VT1 | W-30 | 90-218 | Results:NONE | | Results:NONE | NONE |
| B 9. 40 | SEAL INJECTION A | I | 2-1S1- 1A | PT | 10/F3 | 90-420 | Results:N/A | | Results:NONE | BASELINE |
| B 9. 40 | SEAL INJECTION A | I | 2-1S1- 1A | VT1 | 10/F3 | 90-425 | Results:N/A | | Results:NONE | BASELINE |
| B 9. 40 | SEAL INJECTION A | I | 2-1S1- 1A | PT | 11/F2 | 90-419 | Results:N/A | | Results:NONE | BASELINE |
| B 9. 40 | SEAL INJECTION A | I | 2-1S1- 1A | VT1 | 11/F2 | 90-424 | Results:N/A | | Results:NONE | BASELINE |
| B 9. 40 | SEAL INJECTION A | I | 2-1S1- 1A | PT | 12/F1 | 90-418 | Results:N/A | | Results:NONE | BASELINE |
| B 9. 40 | SEAL INJECTION A | I | 2-1S1- 1A | VT1 | 12/F1 | 90-423 | Results:N/A | | Results:NONE | BASELINE |
| B 9. 40 | SEAL INJECTION A | I | 2-1S1- 1A | PT | W-12 | 90-317 | Results:NONE | | Results:NONE | NONE |
| B 9. 40 | SEAL INJECTION A | I | 2-1S1- 1A | VT1 | W-12 | 90-322 | Results:NONE | | Results:NONE | NONE |
| B 9. 40 | SEAL INJECTION B | I | 2-1S0-12C | VT1 | 13B | 90-427 | Results:N/A | | Results:NONE | BASELINE |
| B 9. 40 | SEAL INJECTION B | I | 2-1S1-12C | PT | 13A | 90-421 | Results:N/A | | Results:NONE | BASELINE |
| B 9. 40 | SEAL INJECTION B | I | 2-1S1-12C | VT1 | 13A | 90-426 | Results:N/A | | Results:NONE | BASELINE |
| B 9. 40 | SEAL INJECTION B | I | 2-1S1-12C | PT | 13B | 90-422 | Results:N/A | | Results:NONE | BASELINE |
| B10. 10 | ACCUMULATOR DISCH B | I | 2-1S1-22 | PT | RHRRH-36/B1 | 90-332 | Results:NONE | | Results:NONE | NONE |
| B10. 10 | ACCUMULATOR DISCH B | I | 2-1S1-22 | VT1 | RHRRH-36/B1 | 90-226 | Results:NONE | | Results:NONE | NONE |
| B10. 20 | RCC PUMP 21 | I | 2-1S1-84 | PT | SUPPORT B | 90-333 | Results:N/A | | Results:NONE | NONE |
| B10. 20 | RCC PUMP 21 | I | 2-1S1-84 | VT-3 | SUPPORT B | 90-352 | Results:N/A | | Results:NONE | NONE |
| B10. 20 | RCC PUMP 21 | I | 2-1S1-84 | VT1 | SUPPORT B | 90-342 | Results:N/A | | Results:NONE | NONE |

NORTHERN STATES POWER COMPANY
 PRAIRIE ISLAND UNIT II
 ISOMETRIC SUMMARY

CLASS I

TABLE III
 PAGE 1 OF 6

| NSP ISO NUMBER | REVISION NUMBER | COMPONENT OR SYSTEM | LOOP DESIG | LINE NUMBER | LINE SIZE | WALL THICK | UT-CAL STD | MAT'L TYPE |
|----------------|-----------------|--------------------------------|------------|-------------|-----------|------------|------------|------------|
| 2-ISI-1 | 1 | SEAL INJECTION (GENERAL) | A | - | - | - | - | - |
| 2-ISI-1A | 1 | | A | 1½-2VC-21A | 1½" | .281" | 1 | S/S |
| 2-ISI-1B | 1 | | A | 2-2VC-21A | 2" | .344" | 3 | S/S |
| 2-ISI-1C | 1 | | A | 2-2VC-21A | 2" | .344" | 3 | S/S |
| 2-ISI-2 | 1 | CROSSOVER DRAIN | A | 2-2RC-10A | 2" | .344" | 3 | S/S |
| | | | A | 2-2RC-11A | 2" | .344" | 3 | S/S |
| 2-ISI-3 | 1 | RTD TAKEOFF COLD LEG | A | 2-2RC-8A | 2" | .344" | 3 | S/S |
| 2-ISI-4 | 1 | RTD TAKEOFF HOT LEG | A | 2-2RC-7A | 2" | .344" | 3 | S/S |
| 2-ISI-5 | 2 | SAFETY INJECTION HIGH HEAD | A | 2-2SI-35A | 2" | .344" | 3 | S/S |
| 2-ISI-6 | 1 | RTD RETURN | A | 3-2RC-6A | 3" | .438" | 4 | S/S |
| 2-ISI-7 | 1 | SPRAY TO PRESSURIZER (GENERAL) | A&B | - | - | - | - | - |
| 2-ISI-7A | 1 | | A | 3-2RC-5 | 3" | .438" | 4 | S/S |
| 2-ISI-7B | 1 | | A | 3-2RC-5 | 3" | .438" | 4 | S/S |
| 2-ISI-7C | 2 | | A | 3-2RC-5 | 3" | .438" | 4 | S/S |
| 2-ISI-7D | 2 | | B | 3-2RC-5 | 3" | .438" | 4 | S/S |
| 2-ISI-8 | 2 | SAFETY INJECTION HIGH HEAD | A | 6-2RC-13B | 6" | .719" | 6 | S/S |
| 2-ISI-9 | 1 | PLO-CAP | A | 6-2RC-13A | 6" | .719" | 6 | S/S |
| 2-ISI-10 | 1 | RHR TAKEOFF (GENERAL) | - | - | - | - | - | - |
| 2-ISI-10A | 2 | | A | 8-2RC-15A | 8" | .812" | 8 | S/S |
| 2-ISI-10B | 1 | | A | 8-2RH-1A | 8" | .812" | 8 | S/S |
| 2-ISI-10C | 2 | | A | 8-2RH-1A | 8" | .812" | 8 | S/S |

NORTHERN STATES POWER COMPANY
 PRAIRIE ISLAND UNIT II
 ISOMETRIC SUMMARY

CLASS I

TABLE III
 PAGE 2 OF 6

| NSP ISO NUMBER | REVISION NUMBER | COMPONENT OR SYSTEM | LOOP DESIG | LINE NUMBER | LINE SIZE | WALL THICK | UT-CAL STD | MAT'L TYPE |
|----------------|-----------------|-----------------------------|-------------------------|-------------|-----------|------------|------------|------------|
| 2-ISI-11 | 2 | ACCUMULATOR DISCHARGE | A | 12-2RC-16A | 12" | 1.312" | 11 | S/S |
| | | | A | 12-2SI-27A | 12" | 1.312" | 11 | S/S |
| 2-ISI-12 | 1 | SEAL INJECTION (GENERAL) | - | - | - | - | - | - |
| 2-ISI-12A | 1 | SEAL INJECTION (GENERAL) | B | 2-2VC-21B | 2" | .344" | 3 | S/S |
| 2-ISI-12B | 1 | | B | 2-2VC-21B | 2" | .344" | 3 | S/S |
| 2-ISI-12C | 1 | | B | 1½-2VC-21B | 1½" | .281" | 1 | S/S |
| 2-ISI-13 | 2 | | CHARGING LINE (GENERAL) | - | - | - | - | - |
| 2-ISI-13A | 1 | CHARGING LINE (GENERAL) | B | 2-2RC-17 | 2" | .344" | 3 | S/S |
| 2-ISI-13B | 2 | | B | 2-2VC-5 | 2" | .344" | 3 | S/S |
| 2-ISI-13C | 1 | | B | 2-2VC-6 | 2" | .344" | 3 | S/S |
| 2-ISI-13D | 1 | | B | 2-2VC-6 | 2" | .344" | 3 | S/S |
| 2-ISI-14 | 1 | | RTD TAKEOFF COLD LEG | B | 2-2RC-8B | 2" | .344" | 3 |
| 2-ISI-15 | 1 | RTD TAKEOFF HOT LEG | B | 2-2RC-7B | 2" | .344" | 3 | S/S |
| 2-ISI-16 | 1 | CROSSOVER DRAIN AND LETDOWN | B | 2-2RC-10B | 2" | .344" | 3 | S/S |
| | | | B | 2-2RC-11B | 2" | .344" | 3 | S/S |
| | | | B | 2-2RC-12 | 2" | .344" | 3 | S/S |
| 2-ISI-17 | 1 | RTD RETURN | B | 3-2RC-6B | 3" | .438" | 4 | S/S |
| 2-ISI-18 | 2 | SAFETY INJECTION HIGH HEAD | B | 6-2RC-13D | 6" | .719" | 6 | S/S |
| 2-ISI-19 | 1 | PLO-CAP | B | 6-2RC-13C | 6" | .719" | 6 | S/S |
| 2-ISI-20 | 2 | RHR TAKE OFF (GENERAL) | B | - | - | - | - | - |
| 2-ISI-20A | 2 | RHR TAKE OFF (GENERAL) | B | 8-2RC-15B | 8" | .812" | 8 | S/S |
| 2-ISI-20B | 1 | | B | 8-2RH-1B | 8" | .812" | 8 | S/S |
| 2-ISI-20C | 2 | | B | 8-2RH-1B | 8" | .812" | 8 | S/S |

NORTHERN STATES POWER COMPANY
 PRAIRIE ISLAND UNIT II
 ISOMETRIC SUMMARY

CLASS I

TABLE III
 PAGE 3 OF 6

| NSP ISO NUMBER | REVISION NUMBER | COMPONENT OR SYSTEM | LOOP DESIG | LINE NUMBER | LINE SIZE | WALL THICK | UT-CAL STD | MAT'L TYPE |
|----------------|-----------------|---------------------------------|------------|-------------|-----------|------------|------------|------------|
| 2-ISI-21 | 2 | RHR RETURN | B | 10-2SI-26 | 10" | 1.000" | 10 | S/S |
| 2-ISI-22 | 2 | ACCUMULATOR DISCHARGE | B | 12-2RC-16B | 12" | 1.312" | 11 | S/S |
| | | | B | 12-2SI-27B | 12" | 1.312" | 11 | S/S |
| 2-ISI-23 | 1 | SAFETY INJECTION HIGH HEAD | B | 2-2SI-35B | 2" | .344" | 3 | S/S |
| 2-ISI-24 | 1 | AUXILIARY SPRAY | - | 2-2RC-19 | 2" | .344" | 3 | S/S |
| | | | - | 2-2RC-4 | 2" | .344" | 3 | S/S |
| 2-ISI-25 | 1 | REACTOR VESSEL SAFETY INJECTION | A | 2-2SI-24A | 2" | .344" | 3 | S/S |
| 2-ISI-26 | 2 | REACTOR VESSEL SAFETY INJECTION | B | 2-2SI-24B | 2" | .344" | 3 | S/S |
| 2-ISI-27 | 1 | PRESSURIZER RELIEF | A&B | 3-2RC-21 | 3" | .438" | 4 | S/S |
| 2-ISI-28 | 2 | REACTOR VESSEL SAFETY INJECTION | B | 4-2RC-14B | 4" | .531" | 5 | S/S |
| | | | B | 6-2RC-14B | 6" | .719" | 6 | S/S |
| | | | B | 6-2SI-25B | 6" | .719" | 6 | S/S |
| 2-ISI-29 | 2 | REACTOR VESSEL SAFETY INJECTION | A | 4-2RC-14A | 4" | .531" | 5 | S/S |
| | | | A | 6-2RC-14A | 6" | .719" | 6 | S/S |
| | | | A | 6-2SI-25A | 6" | .719" | 6 | S/S |
| 2-ISI-30 | 2 | PRESSURIZER SAFETY | A | 6-2RC-20A | 6" | .719" | 6 | S/S |
| | | | B | 6-2RC-20B | 6" | .719" | 6 | S/S |
| 2-ISI-31 | 1 | PRESSURIZER SURGE | B | 10-2RC-4 | 10" | 1.000" | 10 | S/S |

NORTHERN STATES POWER COMPANY
 PRAIRIE ISLAND UNIT II
 ISOMETRIC SUMMARY

CLASS I

TABLE III
 PAGE 4 OF 6

| NSP ISO NUMBER | REVISION NUMBER | COMPONENT OR SYSTEM | LOOP DESIG | LINE NUMBER | LINE SIZE | WALL THICK | UT-CAL STD | MAT'L TYPE |
|----------------|-----------------|---|------------|-------------------|-----------|------------------|------------|------------|
| 2-ISI-32 | 3 | REACTOR COOLANT | A | 29-2RC-1A | 29" | 2.71" | 15 | CAST |
| | | | A | 31-2RC-2A | 31" | 2.89" | 15 | CAST |
| | | | A | 27½-2RC-3A | 27½" | 2.57" | 15 | CAST |
| 2-ISI-33 | 3 | REACTOR COOLANT | B | 29-2RC-1B | 29" | 2.71" | 15 | CAST |
| | | | B | 31-2RC-2B | 31" | 2.89" | 15 | CAST |
| | | | B | 27½-2RC-3B | 27½" | 2.57" | 15 | CAST |
| 2-ISI-34 | 1 | REGENATIVE HEAT EXCHANGER | - | TUBESHEET-TO-HEAD | .719" | 6 | S/S | |
| 2-ISI-35 | 1 | PRESSURIZER SAFETY & RELIEF NOZZLES | - | - | - | - | - | |
| 2-ISI-36 | 1 | PRESSURIZER | - | WELDS | - | 4.400" | 25A | CLAD |
| | | | - | SKIRT WELD | - | 1.500" | 16 | C/S |
| 2-ISI-37 | 1 | STEAM GENERATORS | A&B | TUBESHEET-TO-HEAD | 5.16" | 25A | CLAD | |
| 2-ISI-38 | 2 | REACTOR VESSEL CONOSEAL BLT | - | - | - | - | - | |
| 2-ISI-39 | 1 | REACTOR VESSEL STUDS, NUTS, AND WASHERS | - | - | - | - | Y50 | C/S |
| 2-ISI-40 | 2 | REACTOR VESSEL NOZZLES | - | - | - | - | - | |
| 2-ISI-41 | 2 | REACTOR VESSEL HEAD WELDS | - | - | - | 5.512" 6.299" | 25A | CLAD |
| 2-ISI-42 | 1 | REACTOR VESSEL SHELL WELDS | - | - | - | - | - | |

NORTHERN STATES POWER COMPANY
 PRAIRIE ISLAND UNIT II
 ISOMETRIC SUMMARY

CLASS I

TABLE III
 PAGE 5 OF 6

| NSP ISO NUMBER | REVISION NUMBER | COMPONENT OR SYSTEM | LOOP DESIG | LINE NUMBER | LINE SIZE | WALL THICK | UT-CAL STD | MAT'L TYPE |
|---------------------|-----------------|---------------------------------|------------|----------------|-----------|------------|------------|------------|
| 2-ISI-43 | 1 | RC PUMP SEAL HOUSE BOLTS | A&B | - | - | - | - | |
| 2-ISI-44 | 1 | RC PUMP FLANGE BOLTS | A&B | - | - | - | - | |
| 2-ISI-45 | 1 | RC PUMP FLYWHEELS | A&B | - | - | - | - | |
| 2-ISI-46 CLASS I | 1 | EXCESS LETDOWN HEAT EXCHANGER | - | HEAD-TO-FLANGE | | .718" | 6 | S/S |
| | | <u>COMPONENT SUPPORTS</u> | | | | | | |
| 2-ISI-77A | 0 | STEAM GENERATORS (GENERAL) | - | - | - | - | - | |
| 2-ISI-77 | 1 | S/G SUPPORT BASE | A&B | - | - | - | - | |
| 2-ISI-77B | 1 | S G COLUMN PINS | A&B | 8/GEN. | - | - | - | |
| | | R C PUMP TIE BACK PINS | A&B | 3/PUMP | - | - | - | |
| | | R C PUMP COLUMN PINS | A&B | 6/PUMP | - | - | - | |
| 2-ISI-77C | 1 | R C PUMP TIE BACK BOLTS | A&B | 3/PUMP | - | - | - | |
| 2-ISI-77D | 1 | S G HELICOIL SCREWS | A&B | 24/GEN. | - | - | - | |
| 2-ISI-78 | 1 | S/G SUPPORT TOP | A&B | - | - | - | - | |
| 2-ISI-79A | 0 | REACTOR COOLANT PUMPS (GENERAL) | A&B | - | - | - | - | |
| 2-ISI-79 | 1 | RC PUMP SUPPORT BASE | A&B | - | - | - | - | |
| 2-ISI-80 | 1 | RC PUMP SUPPORT TOP | A&B | - | - | - | - | |
| 2-ISI-81 | 1 | RCP 22 LOWER LATERAL SUPPORT | B | - | - | - | - | |
| 2-ISI-84 | 1 | RCP 21 LOWER LATERAL SUPPORT | A | - | - | - | - | |
| 2-ISI-85 | 2 | STEAM GENERATOR UPPER SUPPORT | A&B | - | - | - | - | |

NORTHERN STATES POWER COMPANY
 PRAIRIE ISLAND UNIT II
 ISOMETRIC SUMMARY

CLASS I

TABLE III
 PAGE 6 OF 6

| NSP ISO NUMBER | REVISION NUMBER | COMPONENT OR SYSTEM | LOOP DESIG | LINE NUMBER | LINE SIZE | WALL THICK | UT-CAL STD | MAT'L TYPE |
|----------------|-----------------|----------------------------|------------|-------------|-----------|------------|------------|------------|
| 2-ISI-86 | 1 | S/G UPPER SUPPORT SNUBBERS | A&B | - | - | - | - | |
| 2-ISI-87 | 1 | S/G SUPPORT PAD TOP | A&B | - | - | - | - | |
| 2-ISI-88 | 1 | PRESSURIZER BASE | - | - | - | - | - | |
| 2-ISI-89 | 1 | ACCUMULATOR BASE | A&B | - | - | - | - | |

APPENDIX B

ASME CLASS II EXAMINATIONS

INSERVICE INSPECTION—EXAMINATION SUMMARY

MAJOR ITEM: PRESSURE VESSEL - STEAM GENERATOR

| SUB ITEM | EXAM CATEGORY | COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED | INSP. PER. | REQ'D AMT. | AMOUNT EXAM | ITEM IDENTIFICATION | INSPECTION REPORT NO. |
|----------|---------------|--|------------|------------|-------------|---------------------|-----------------------|
| C1.10 | C-A | <u>PRESSURE RETAINING WELDS IN PRESSURE VESSELS</u> | | | | | |
| | C-A | <u>SHELL CIRCUMFERENTIAL WELDS</u> | | | | | |
| | | STEAM GENERATOR NO 21 | | | | | |
| | | WELD C | ONE | 424" | 424" | W-C (100%) | 88-242,244,246,243 |
| C1.20 | | WELD E | TWO | 424" | 424" | W-E (100%) | 90-228,227,229,204 |
| | | WELD F | | - | 552" | W-F (100%) | 90-136,156,145,155 |
| | | STEAM GENERATOR NO 22 | | | | | |
| | | WELD F | THREE | 522" | - | | |
| C1.30 | C-A | <u>HEAD CIRCUMFERENTIAL WELDS</u> | | | | | |
| | | STEAM GENERATOR NO 22 | | | | | |
| | | WELD H | THREE | 100% | - | | |
| C1.30 | C-A | <u>TUBESHEET TO SHELL WELD</u> | | | | | |
| | | STEAM GENERATOR NO 22 | | | | | |
| | | WELD B | THREE | 100% | - | | |

P22521-1

NORTHERN STATES POWER CO.
 PRAIRIE ISLAND UNIT
 INSERVICE INSPECTION—EXAMINATION SUMMARY

TABLE S2.1.1
 PAGE 2 OF 3
 MAJOR ITEM: PRESSURE VESSEL - STEAM GENERATOR

| SUB ITEM | EXAM CATEGORY | COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED | INSP. PER. | REQ'D AMT. | AMOUNT EXAM | ITEM IDENTIFICATION | INSPECTION REPORT NO. |
|----------|---------------|---|------------|------------|-------------|---------------------|-----------------------|
| C2.10 | C-B | <u>PRESSURE RETAINING NOZZLE WELDS IN VESSELS</u> | - | - | - | NONE | |
| C2.20 | C-B | <u>NOZZLE IN VESSELS 1/2 INCH AND LESS NOMINAL THICKNESS</u> | - | - | - | | |
| C2.21 | C-B | <u>NOZZLE WITHOUT REINFORCING PLATE IN VESSEL GREATER THAN 1/2 INCH NOMINAL THICKNESS</u> <u>NOZZLE TO-SHELL (OR HEAD) WELDS</u> STEAM GENERATOR NO. 21 | TWO | 1 | 1 | N-4 | 89-373,374,375,294 |
| C2.22 | C-B | <u>NOZZLE INSIDE RADIUS SECTION</u> STEAM GENERATOR NO. 21 MAIN STEAM NOZZLE FEEDWATER NOZZLE STEAM GENERATOR NO. 22 MAIN STEAM NOZZLE FEEDWATER NOZZLE | THREE | 1 | - | | * RELIEF NO. 66 |
| | | STEAM GENERATOR NO. 22 MAIN STEAM NOZZLE FEEDWATER NOZZLE | TWO | *1 | - | | * RELIEF NO. 66 |
| | | STEAM GENERATOR NO. 21 MAIN STEAM NOZZLE FEEDWATER NOZZLE | THREE | *1 | - | | * RELIEF NO. 66 |

P22521-1

NORTHERN STATES POWER CO.
 PRAIRIE ISLAND UNIT 2
 INSERVICE INSPECTION—EXAMINATION SUMMARY

TABLE S2.1.1
 PAGE 3 OF 3

MAJOR ITEM: PRESSURE VESSEL - STEAM GENERATOR

| SUB ITEM | EXAM CATEGORY | COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED | INSP. PER. | REQ'D AMT. | AMOUNT EXAM | ITEM IDENTIFICATION | INSPECTION REPORT NO. |
|----------|---------------|--|------------|------------|-------------|---------------------|---|
| C2.30 | C-B | <u>NOZZLE WITH REINFORCING PLATE IN VESSEL GREATER THAN 1/2 INCH NOMINAL THICKNESS</u> | - | - | - | -NONE- | * PERFORMED BY PLANT PERSONNEL IN ACCORDANCE WITH IWA-5000 DURING EACH SYSTEM LEAKAGE TEST AND EACH SYSTEM HYDROSTATIC TEST REQUIRED BY IWB-5000. |
| | C-C | <u>INTEGRAL ATTACHMENTS FOR VESSELS</u> | - | - | - | -NONE- | |
| C3.10 | C-C | <u>INTEGRALLY WELDED ATTACHMENTS</u> | - | - | - | -NONE- | |
| | C-D | <u>PRESSURE RETAINING BOLTING, GREATER THAN 2 INCH IN DIAMETER</u> | - | - | - | -NONE- | |
| C4.10 | C-D | <u>BOLTS AND STUDS</u> | - | - | - | -NONE- | |
| | C-H | <u>ALL PRESSURE RETAINING COMPONENTS</u> | - | - | - | -NONE- | |
| C7.10 | C-H | <u>PRESSURE RETAINING BOUNDARY</u> | * | - | - | -NONE- | |
| C7.20 | C-H | <u>PRESSURE RETAINING BOUNDARY</u> | * | - | - | -NONE- | |

P22S1-1

| SJB ITEM | EXAM CATEGORY | COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED | INSP. PER. | REQ'D AMT. | AMOUNT EXAM | ITEM IDENTIFICATION | INSPECTION REPORT NO. |
|----------|---------------|--|------------|------------|-------------|---------------------|-----------------------------|
| | C-A | <u>PRESSURE RETAINING WELDS IN PRESSURE VESSELS</u> | | | | | |
| C1.10 | C-A | <u>SHELL CIRCUMFERENTIAL WELDS</u> | - | - | - | -NONE- | |
| C1.20 | C-A | <u>HEAD CIRCUMFERENTIAL WELDS</u> | | | | | |
| | | ACCUMULATOR NO. 21 | | | | | |
| | | WELD 2 | TWO | 1 | * | MISSED PERIOD TWO | RESCHEDULE FOR PERIOD THREE |
| | | WELD 5 | THREE | 2 | - | | |
| | | ACCUMULATOR NO. 22 | | | | | |
| | | WELD 2 | - | - | - | | |
| | | WELD 5 | THREE | 1 | - | | |

P22S21-2

INSERVICE INSPECTION—EXAMINATION SUMMARY

| SUB ITEM | EXAM CATEGORY | COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED | INSP. PER. | REQ'D AMT. | AMOUNT EXAM | ITEM IDENTIFICATION | INSPECTION REPORT NO. |
|----------|---------------|---|------------|------------|-------------|---------------------|-----------------------|
| | C-B | PRESSURE RETAINING NOZZLE WELDS IN VESSELS | | | | | |
| C2.10 | C-B | NOZZLE IN VESSELS 1/2 INCH AND LESS NOMINAL THICKNESS | - | - | - | -NONE- | |
| C2.20 | C-B | NOZZLE WITHOUT REINFORCING PLATE IN VESSELS GREATER THAN 1/2 INCH NOMINAL THICKNESS | | | | | |
| C2.21 | C-B | NOZZLE TO SHELL (OR HEAD) WELDS | | | | | |
| | | ACCUMULATOR NO. 21 | - | - | - | | |
| | | ACCUMULATOR NO. 22 | THREE | 1 | - | | |
| C2.22 | C-B | NOZZLE INSIDE RADIUS SECTION | | | | | |
| | | ACCUMULATOR NO. 21 | * | - | - | | * RELIEF NO. 66 |
| | | ACCUMULATOR NO. 22 | THREE | *1 | - | | |
| C2.30 | C-B | NOZZLE WITH REINFORCING PLATE IN VESSELS GREATER THAN 1/2 INCH NOMINAL THICKNESS | | | | | |
| | C-C | INTEGRAL ATTACHMENT FOR VESSELS | | | | | |
| C3.10 | C-C | INTEGRALLY WELDED ATTACHMENTS | - | - | - | -NONE- | |

INSERVICE INSPECTION—EXAMINATION SUMMARY

| SUB ITEM | EXAM CATEGORY | COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED | INSP. PER. | REQ'D AMT. | AMOUNT EXAM | ITEM IDENTIFICATION | INSPECTION REPORT NO. |
|----------|---------------|---|------------|------------|-------------|---------------------|-----------------------|
| C4.10 | C-D | PRESSURE RETAINING BOLTING, GREATER THAN 2 INCH IN DIAMETER | | | | | |
| | C-D | BOLTS AND STUDS | - | - | - | -NONE- | |
| | C-H | ALL PRESSURE RETAINING COMPONENTS | | | | | |
| C7.10 | C-H | PRESSURE RETAINING BOUNDARY | * | - | - | | |
| C7.20 | C-H | PRESSURE RETAINING BOUNDARY | * | - | - | | |

* PERFORMED BY PLANT PERSONNEL IN ACCORDANCE WITH IWA-5000 DURING EACH SYSTEM LEAKAGE TEST AND EACH SYSTEM HYDROSTATIC TEST REQUIRED BY IWB-5000.

P22S21-2

INSERVICE INSPECTION—EXAMINATION SUMMARY
 MAJOR ITEM: RHR HEAT EXCHANGERS

| SUB ITEM | EXAM CATEGORY | COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED | INSP. PER. | REQ'D AMT. | AMOUNT EXAM | ITEM IDENTIFICATION | INSPECTION REPORT NO. |
|----------|---------------|---|------------|------------|-------------|---------------------|-----------------------|
| C1.10 | C-A | <u>PRESSURE RETAINING WELDS IN PRESSURE VESSELS</u> | THREE | *1 | - | | * RELIEF NO. 45 |
| | C-A | <u>SHELL CIRCUMFERENTIAL WELDS</u> | - | - | - | | |
| | | RHR HEAT EXCHANGER NO 21 | | | | | |
| | | RHR HEAT EXCHANGER NO 22 | | | | | |
| C1.20 | C-A | <u>HEAD CIRCUMFERENTIAL WELDS</u> | - | - | - | | |
| | | RHR HEAT EXCHANGER NO 21 | | | | | |
| | | RHR HEAT EXCHANGER NO 22 | | | | | * RELIEF NO. 45 |
| C2.10 | C-B | <u>PRESSURE RETAINING NOZZLE WELDS IN VESSELS</u> | THREE | *1 | - | | |
| | C-B | <u>NOZZLE IN VESSELS 1/2 INCH AND LESS NOMINAL THICKNESS</u> | - | - | - | -NONE- | |
| C2.11 | | RHR HEAT EXCHANGER NO 21 | | | | | |
| | | WELD 3 | TWO | 1 | 1 | W-3 | 90-047,049 |
| C2.11 | | RHR HEAT EXCHANGER NO 22 | | | | | |
| | | WELD 4 | THREE | 1 | - | | |
| C2.30 | C-B | <u>NOZZLE WITH REINFORCING PLATE IN VESSELS GREATER THAN 1/2 INCH NOMINAL THICKNESS</u> | - | - | - | -NONE- | |

P22SP1-3

MAJOR ITEM:

| IB LM | EXAM CATE- GORY | COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED | INSP. PER. | REQ'D AMT. | AMOUNT EXAM | ITEM IDENTIFICATION | INSPECTION REPORT NO. |
|----------|--------------------------|--|---------------|---------------|----------------|------------------------|--|
| C3.10 | C-C | <u>INTEGRAL ATTACHMENT FOR VESSELS</u> | | | | | |
| | C-C | <u>INTEGRALLY WELDED ATTACHMENTS</u> | | | | | |
| | | RHR HEAT EXCHANGER NO 21 | TWO | 1 | 1 | SUPPORT A | 90-048,050,013 |
| | RHR HEAT EXCHANGER NO 22 | THREE | 1 | - | | | |
| C4.10 | C-D | <u>PRESSURE RETAINING BOLTING, GREATER THAN 2 INCH IN DIAMETER</u> | | | | | |
| | C-D | <u>BOLTS AND STUDS</u> | - | - | - | -NONE- | |
| | C-H | <u>ALL PRESSURE RETAINING COMPONENTS</u> | | | | | |
| C7.10 | C-H | <u>PRESSURE RETAINING BOUNDARY</u> | * | - | - | | * PERFORMED BY PLANT PERSONNEL IN ACCORD- ANCE WITH IWA-5000 DURING EACH SYSTEM LEAKAGE TEST AND EACH SYSTEM HYDRO- STATIC TEST REQUIRED BY IWB-5000. |
| C7.20 | C-H | <u>PRESSURE RETAINING BOUNDARY</u> | * | - | - | | |

P2251-3

MAJOR ITEM:

| SUB ITEM | EXAM CATEGORY | COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED | INSP. PER. | REQ'D AMT. | AMOUNT EXAM | ITEM IDENTIFICATION | INSPECTION REPORT NO. |
|----------|---------------|--|------------|------------|-------------|---------------------|-----------------------|
| | C-A | <u>PRESSURE RETAINING WELDS IN PRESSURE VESSELS</u> | | | | | |
| C1.10 | C-A | <u>SHELL CIRCUMFERENTIAL WELDS</u> | - | - | - | -NONE- | |
| C1.20 | C-A | <u>HEAD CIRCUMFERENTIAL WELDS</u> | | | | | |
| | | BORIC ACID TANK 21 | THREE | - | - | | |
| | C-B | <u>PRESSURE RETAINING NOZZLE WELDS IN VESSELS</u> | | | | | |
| C2.10 | C-B | <u>NOZZLE IN VESSELS 1/2 INCH AND LESS NOMINAL THICKNESS</u> | | | | | |
| C2.11 | | BORIC ACID TANK 21 | THREE | - | - | | |
| | C-C | <u>INTEGRAL ATTACHMENT FOR VESSELS</u> | - | - | - | -NONE- | |
| | C-D | <u>PRESSURE RETAINING BOLTING, GREATER THAN 2 INCH IN DIAMETER</u> | - | - | - | -NONE- | |

INSERVICE INSPECTION—EXAMINATION SUMMARY

MAJOR ITEM:

| SUB ITEM | EXAM CATE-GORY | COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED | INSP. PER. | REQ'D AMT. | AMOUNT EXAM | ITEM IDENTIFICATION | INSPECTION REPORT NO. |
|----------|----------------|--|------------|------------|-------------|---------------------|-----------------------|
| C7.10 | C-H | <u>ALL PRESSURE RETAINING COMPONENTS</u> | | | | | |
| C7.20 | C-H | <u>PRESSURE RETAINING BOUNDARY</u> | * | - | - | | |
| | C-H | <u>PRESSURE RETAINING BOUNDARY</u> | * | - | - | | |

* PERFORMED BY PLANT PERSONNEL IN ACCORDANCE WITH IWA-5000 DURING EACH SYSTEM LEAKAGE TEST AND EACH SYSTEM HYDROSTATIC TEST REQUIRED BY IWB-5000.

P22S21-4

INSERVICE INSPECTION—EXAMINATION SUMMARY

MAJOR ITEM:

| SUB ITEM | EXAM CATEGORY | COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED | INSP. PER. | REQ'D AMT. | AMOUNT EXAM | ITEM IDENTIFICATION | INSPECTION REPORT NO. |
|----------|---------------|--|------------|------------|-------------|----------------------|--|
| C3.20 | C-C | <u>INTEGRAL ATTACHMENTS FOR PIPING</u> | | | | | |
| | C-C | <u>INTEGRALLY WELDED ATTACHMENTS</u> | | | | | |
| | | MAIN STEAM A | ONE | 4 | 4 | I, AI, C | 85-036/86-024, 048, 051, 038, 251, 253 |
| | | | TWO | 5 | 6 | J A, D | 88-086, 116, 081 89-079, 080, 081 149, 109 |
| | | | THREE | 5 | - | H, P K, M | 89-150, 152, 282, 283 90-239, 259, 076, 273, 260, 137 |
| | | MAIN STEAM B | ONE | 4 | 4 | D A, J | 85-037/86-073 86-023, 049, 052, 022, 250, 250R, 252, 252R |
| | | | TWO | 5 | 5 | I, D L, K H, C | 88-247, 255, 082, 263, 264 89-284, 285, 286, 287 90-135, 097, 240 096, 095 |
| | | | THREE | 5 | - | AI | 90-055, 058, 061, 061R |
| | | MAIN STEAM A & B RELIEF HEADER | ONE | - | - | | |
| | | | TWO | 1 | 1 | P | 89-282, 283, 353 |
| | | | THREE | 1 | - | | |

P22S2-2

MAJOR ITEM:

| SUB ITEM | EXAM CATEGORY | COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED | INSP. PER. | REQ'D AMT. | AMOUNT EXAM | ITEM IDENTIFICATION | INSPECTION REPORT NO. |
|----------|---------------|--|---------------------|-------------|-------------|--------------------------------------|---|
| C3.20 | C-C | (CONTINUED) | | | | | |
| | | FEEDWATER A | ONE | 3 | 3 | A H K, A | 85-116, 117/86-035 86-036, 267, 270 88-083, 065, 069, 084, 068 |
| | | | TWO | 3 | 3 | L B F | 89-151, 153 90-237, 237R, 265, 078 90-238, 266, 080 |
| | | | THREE | 3 | - | | |
| | | FEEDWATER B | - | - | - | | ALL ENCAPSULATED |
| | | RHR PUMP SUCTION | ONE TWO THREE | - 1 1 | - 1 - | C | 90-269, 219, 161 |
| | | RHR PUMP DISCHARGE | ONE TWO THREE | - 1 - | - 1 - | MISSED PERIOD ONE L L (REPEAT) | 89-277, 248 90-270, 220, 171 |
| | | REACTOR VESSEL SAFETY INJECTION | ONE TWO THREE | 1 - - | 1 - - | A | 86-060, 203, 203R, 222 |
| | | CONTAINMENT SUMP B DISCHARGE | - | - | - | | EMBEDDED |

P22S-2

INSERVICE INSPECTION—EXAMINATION SUMMARY

MAJOR ITEM:

| SUB ITEM | EXAM CATEGORY | COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED | INSP. PER. | REQ'D AMT. | AMOUNT EXAM | ITEM IDENTIFICATION | INSPECTION REPORT NO. |
|----------|---------------|---|------------|------------|-------------|---------------------|-----------------------|
| C4.20 | C-D | PRESSURE RETAINING BOLTING, GREATER THAN 2 INCH IN DIAMETER | | | | | |
| | C-D | BOLTS AND STUDS | --- | --- | --- | -NONE- | |
| C5.10 | C-F | PRESSURE RETAINING WELDS IN PIPING | | | | | |
| | C-F | PIPING WELDS 1/2 INCH AND LESS NOMINAL WALL THICKNESS | | | | | |
| C5.11 | C-F | CIRCUMFERENTIAL WELDS AND LONGITUDINAL WELDS (75 CATEGORY C-F) RHR PUMP SUCTION 12-2RH-5A 12-2RH-5B 10-2HR-3 8-2RH-4A 8-2RH-4B 8-2RH-5A 8-2RH-5B | ONE | 2 | 2 | W-109 | 86-215,218 |
| C5.12 | C-F | | TWO | - | 1 | W-146 | 88-230,231 |
| | C-F | | THREE | 2 | - | W-149 | 89-040,041 |
| | | | ONE | 2 | 2 | 208 (REPEAT) | 85-051/88-288,269 |
| | | | TWO | - | - | 260 | 88-128,129 |
| | | | THREE | 4 | - | | |
| | | | ONE | 1 | 1 | W-130 | 86-216,219 |
| | | | TWO | 1 | 1 | W-102 | 90-021,023 |
| | | | THREE | - | - | | |
| | | | ONE | - | - | | |
| | | TWO | 1 | 1 | W-135 | 90-028,030 | |
| | | THREE | - | - | | | |

P225-2

MAJOR ITEM:

| SUB ITEM | EXAM CATEGORY | COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED | INSP. PER. | REQ'D AMT. | AMOUNT EXAM | ITEM IDENTIFICATION | INSPECTION REPORT NO. |
|---------------|---------------|--|---------------------|-------------|-------------|------------------------------|--|
| C5.11 & C5.12 | C-F | (CONTINUED) | | | | | |
| | | RHR PUMP DISCHARGE | | | | | |
| | | 6-2RH-12 | ONE TWO THREE | - - 1 | - - - | | |
| | | 10-2RH-11 | ONE TWO THREE | 2 3 - | 2 3 - | W-171/W-166 W-172,169,165 | 85-126/86-202,220 89-007,008,009,010 004,004R,005,005R |
| | | SAFETY INJECTION | | | | | |
| | | 6-2SI-10B | ONE TWO THREE | 1 2 - | 2 2 - | W-131/W-23 W-29,33 | 86-001,002/88-102,103 90-032,035,033,036 |
| | | SAFETY INJECTION PUMPS SUCTION | | | | | |
| | | 6-2SI-13A 6-2SI-13B | ONE TWO THREE | 2 - 1 | 3 - - | W-164 W-123,155 | 85-127 88-289,273,293,266 |

P22S2-2

INSERVICE INSPECTION—EXAMINATION SUMMARY

MAJOR ITEM:

| SUB ITEM | EXAM CATEGORY | COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED | INSP. PER. | REQ'D AMT. | AMOUNT EXAM | ITEM IDENTIFICATION | INSPECTION REPORT NO. |
|---------------|---------------|--|------------|------------|-------------|---------------------|---------------------------------------|
| C5.11 & C5.12 | C-F | (CONTINUED) | | | | | |
| | | BORIC ACID SUPPLY TO SAFETY INJECTION | | | | | |
| | | 12-2SI-11 | ONE | 1 | 1 | W-46 | 86-126,137 |
| | | | TWO | 1 | 1 | W-38 | 90-039,042 |
| | | | THREE | 1 | - | | |
| | | 8-2SI-17* | ONE | 3 | 19 | W-20,21,23,24,25 | * SAME LINE 85-052,059,060,061,062 |
| | | 8-2SI-18* | | | | W-26,27,28,45,34 | 85-119,120,121,122,124 |
| | | | | | | W-46,47,48,52,62 | 85-125,132,133,134,135 |
| | | | | | | W-55 | 85-136,137 |
| | | | | | | W-19,10,53 | 85-143,144,145 |
| | | | | | 3 | W-58,54F,45 | 88-286,272,284, 271,287,270 |
| | | | TWO | 4 | 4 | W-69,61 | 89-021,022,023,024 |
| | | | THREE | 6 | - | W-48,55F | 90-040,043,041,044 |
| | | SAFETY INJECTION PUMP SUCTION | | | | | |
| | | 6-2RH-10B | ONE | 3 | 3 | W-155/W-115R2 | 85-128,86-097,099 |
| | | 6-2RH-10A | | | | W-164 | 88-229,265 |
| | | | TWO | 3 | 3 | W-154 | 89-013,014 |
| | | | THREE | 2 | - | W-143,78 | 90-018,019,029,031 |

P2252-2

INSERVICE INSPECTION—EXAMINATION SUMMARY

MAJOR ITEM:

| SUB ITEM | EXAM CATE-GORY | COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED | INSP. PER. | REQ'D AMT. | AMOUNT EXAM | ITEM IDENTIFICATION | INSPECTION REPORT NO. |
|---------------|----------------|--|------------|----------------|-------------|---------------------|-----------------------|
| C5.11 & C5.12 | C-F | (CONTINUED) | | | | | |
| | | BORIC ACID SUPPLY | | | | | |
| | | 8-2SI-18* | ONE | - | - | | |
| | | 8-VC-71C* | TWO | 3 | 3 | W-9,10 | * SAME LINE |
| | | | THREE | 1 | - | W-18 | 89-036,037,038,039 |
| | | | | | | | 90-045,046 |
| | | MAIN STEAM A & B | | | | | |
| | | 6-2MS-1 | ONE | 1 | 1 | MS-114 | |
| | | 6-2MS-2 | TWO | - | - | | 86-084,087 |
| | | | THREE | 1 | - | | |
| | | REFUELING WATER STORAGE TANK DISCHARGE | | | | | |
| | | 14-2SI-1 | ONE | 1 | 1 | W-53W | 86-098,100 |
| | | | TWO | 1 | 1 | W-50W | 89-015,016 |
| | | | THREE | 1 | - | | |
| 12-2SI-3A | ONE | - | - | | | | |
| 12-2SI-3B | TWO | 1 | - | MISSED PER TWO | | | |
| | THREE | - | - | | | | |
| 12-2SI-4 | ONE | 1 | 1 | W-67 | 86-214,217 | | |
| | TWO | - | - | | | | |
| | THREE | 1 | - | | | | |
| 12-2SI-11 | ONE | 1 | 1 | W-41 | 88-283,226 | | |
| | TWO | - | 1 | W-47 | 89-018,017 | | |
| | THREE | - | - | | | | |

P2257-2

INSERVICE INSPECTION—EXAMINATION SUMMARY

MAJOR ITEM:

| SUB ITEM | EXAM CATEGORY | COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED | INSP. PER. | REQ'D AMT. | AMOUNT EXAM | ITEM IDENTIFICATION | INSPECTION REPORT NO. |
|----------------|---------------|---|---------------------|-------------|-------------|------------------------------------|---|
| C5.11 & C5.12 | C-F | (CONTINUED) 10-2SI-8 | ONE TWO THREE | 1 1 1 | 1 1 - | W-73 (REPEAT) W-71W | 85-131/88-294,225 90-034,037 |
| C5.20 | C-F | PIPING WELDS GREATER THAN 1/2 INCH NOMINAL WALL THICKNESS | | | | | |
| C5.21 C5.22 | C-F C-F | CIRCUMFERENTIAL WELDS AND LONGITUDINAL WELDS (75 CATEGORY C-F) MAIN STEAM A & B | | | | | |
| | | 32-2MS-1 32-2MS-2 | ONE TWO THREE | - - 1 | - - - | | |
| | | 31-2MS-1 31-2MS-2 | ONE TWO THREE | 1 1 1 | 1 1 - | MS-4 MS-1 | 88-212,222,193 90-056,247,059 |
| | | 30-2MS-1 30-2MS-2 | ONE TWO THREE | 1 1 1 | 1 1 - | MS-85+LONG SEAM MS-82+LONG SEAM | 86-047,050,059,092 90-057,057R,323,060 |

P2257-2

INSERVICE INSPECTION—EXAMINATION SUMMARY

MAJOR ITEM:

| SUB ITEM | EXAM CATEGORY | COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED | INSP. PER. | REQ'D AMT. | AMOUNT EXAM | ITEM IDENTIFICATION | INSPECTION REPORT NO. |
|---------------|---------------|--|------------|------------|-------------|---------------------|-----------------------|
| C5.21 & C5.22 | C-F | (CONTINUED) | | | | | |
| | | MAIN STEAM A & B RELIEF HEADER | | | | | |
| | | 30-2MS-1 | ONE | - | - | | |
| | | 30-MS-2 | TWO | 1 | 1 | MS-23 | 90-274,297,284 |
| | | | THREE | 1 | - | | |
| | | FEEDWATER A & B | | | | | |
| | | 16-2FW-13* | ONE | 2 | 4 | FW-133,177 | * SAME LINE |
| | | 16-2FW-12* | | | | | ** SAME LINE |
| | | 16-2FW-11* | | | | | 85-001,001R,002,002R |
| | | 16-2FW-16** | | | | | 007,008,009,010 |
| | | 16-2FW-15** | | | | | 86-032,026,028,033, |
| | | | | | | | 025,027 |
| | | | | | | | 88-008,035,005,033 |
| | | | | | | | 034,007,036,006 |
| | | | TWO | 1 | 1 | FW-201 | 86-269,279,280 |
| | | | | | | FW-169 | 88-245,221,251,085 |
| | | | | | | FW-158 | 89-288,405,289 |
| | | | | | | FW-133,177 | 89-049,078,048,076 |
| | | | | | | | 89-046,046R,077 |
| | | | | | | | 047,075 |
| | | | THREE | 2 | - | FW-133,177 | 90-099,051,101,053, |
| | | | | | | | 098,052,100,054 |

P22S2-2

INSERVICE INSPECTION—EXAMINATION SUMMARY

MAJOR ITEM:

| SUB ITEM | EXAM CATE-GORY | COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED | INSP. PER. | REQ'D AMT. | AMOUNT EXAM | ITEM IDENTIFICATION | INSPECTION REPORT NO. |
|----------------|----------------|--|------------|------------|-------------|---------------------|---|
| C5.31 | C-F | <u>CIRCUMFERENTIAL WELDS</u> | | | | | |
| | | ('75 CATEGORY C-G) | | | | | |
| | | MAIN STEAM A & B RELIEF HEADER | | | | | |
| | | 30-2MS-1 | ONE | 2 | 2 | MS-181B | 85-012,019 |
| | | 30-2MS-2 | TWO | 2 | 2 | MS-187A MS-185B | 86-088,085,101 89-270,271(ENCAPPED) |
| | | | THREE | 3 | - | MS-183B | 90-275,416,285 |
| C5.32 | C-F | <u>LONGITUDINAL WELDS</u> | | | | | |
| | | | | | | | |
| | | | | | | | |
| C7.30 C7.40 | C-H | <u>ALL PRESSURE RETAINING COMPONENTS</u> | | | | | |
| | | <u>PRESSURE RETAINING BOUNDARY</u> | * | - | - | | * PERFORMED BY PLANT PERSONNEL IN ACCORDANCE WITH IWA-5000 DURING EACH SYSTEM LEAKAGE TEST AND EACH SYSTEM HYDROSTATIC TEST REQUIRED BY IWB-5000. |
| | | <u>PRESSURE RETAINING BOUNDARY</u> | * | - | - | | |

P22S2-2

INSPECTION—EXAMINATION SUMMARY

MAJOR ITEM:

| SUB ITEM | EXAM CATEGORY | COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED | INSP. PER. | REQ'D AMT. | AMOUNT EXAM | ITEM IDENTIFICATION | INSPECTION REPORT NO. |
|----------|---------------|---|---------------------|-------------|-------------|---------------------------------|------------------------------------|
| C3.30 | C-C | INTEGRAL ATTACHMENT FOR PUMPS | | | | | |
| | C-C | INTEGRALLY WELDED ATTACHMENTS | | | | | |
| | | RESIDUAL HEAT REMOVAL | | | | | |
| | | PUMP NO. 21 PUMP NO. 22 | ONE TWO THREE | - 1 1 | - 1 - | G | 90-020,022,001 |
| C4.30 | | SAFETY INJECTION | | | | | |
| | | PUMP NO. 21 PUMP NO. 22 | ONE | 4 | 4 | SUPPORT A,B(21&22) | 86-003,005,009,004 004R,006,010 |
| | | | TWO | 4 | 4 | SUPPORT C,D SUPPORT C,D (VT) | 88-274,267,275,268 89-030,031 |
| | | | THREE | 4 | - | SUPPORT C,D(21&22) | 90-378,267,379, 268,008,009 |
| | C-D | PRESSURE RETAINING BOLTING, GREATER THAN 2 INCH IN DIAMETER | | | | | |
| | C-D | BOLTS AND STUDS | | | | -NONE- | |

P2252-3

INSERVICE INSPECTION—EXAMINATION SUMMARY

MAJOR ITEM:

| SUB ITEM | EXAM CATEGORY | COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED | INSP. PER. | REQ'D AMT. | AMOUNT EXAM | ITEM IDENTIFICATION | INSPECTION REPORT NO. |
|----------|---------------|--|---------------------|-------------|-------------|---------------------|---|
| C6.10 | C-G | <u>PRESSURE RETAINING WELDS IN PUMPS</u> | | | | | |
| | C-G | <u>PUMP CASING WELDS</u> | | | | | |
| | | SAFETY INJECTION PUMPS | | | | | |
| | | CASING TO FLANGE WELD ON DISCHARGE | | | | | |
| | | PUMP NO. 21 & 22 | ONE TWO THREE | - - 1 | - - - | | |
| | | CASING TO FLANGE WELD ON SUCTION | | | | | |
| | | PUMP NO. 21 & 22 | ONE TWO THREE | - 1 - | - 1 - | W-C | 90-380,381 |
| | C-H | <u>ALL PRESSURE RETAINING COMPONENTS</u> | | | | | |
| C7.50 | C-H | <u>PPRESSURE RETAINING BOUNDARY</u> | * | - | - | | * PERFORMED BY PLANT PERSONNEL IN ACCORDANCE WITH IWA-5000 DURING EACH SYSTEM LEAKAGE TEST AND EACH SYSTEM HYDROSTATIC TEST REQUIRED BY IWB-5000. |
| C7.60 | C-H | <u>PRESSURE RETAINING BOUNDARY</u> | * | - | - | | |

P22S-3

NORTHERN STATES POWER COMPANY
PRAIRIE ISLAND UNIT II

TABLE 8-II

Examination Comparison Summary

| SUB-ITEM | SYSTEM | CLASS | ISO | METH | ITEM | REPORT | PREVIOUS RESULTS | SCAN | CURRENT RESULTS | LIMITATIONS |
|----------|--------------------|-------|----------|------|------|--------|------------------|------|-----------------|--------------------------------|
| C 1. 10 | STEAM GENERATOR 21 | II | 2-1S1-37 | UT0 | W-E | 90-228 | Results:NONE | 1L | Results:NONE | SEE REPORT 90-227 |
| C 1. 10 | STEAM GENERATOR 21 | II | 2-1S1-37 | UT45 | W-E | 90-227 | Results:NONE | 2 | Results:NONE | NO SCAN 1 RESTRAINT, NO SCAN |
| C 1. 10 | STEAM GENERATOR 21 | II | 2-1S1-37 | UT45 | W-E | 90-227 | Results:NONE | 3 | Results:NONE | 3 & 4 UPSTREAM, LIMIT'D @ 15', |
| C 1. 10 | STEAM GENERATOR 21 | II | 2-1S1-37 | UT45 | W-E | 90-227 | Results:NONE | 4 | Results:NONE | 17', 32', 36' INSULATION LUGS |
| C 1. 10 | STEAM GENERATOR 21 | II | 2-1S1-37 | UT60 | W-E | 90-229 | Results:NONE | 2 | Results:GEO | NO SCAN 1 RESTRAINT |
| | | | | | | | | | Scan: 2 | |
| | | | | | | | | | Type:ID | |
| | | | | | | | | | Amplitude:21 | |
| | | | | | | | | | Ax Loc: | |
| | | | | | | | | | Circ Loc: | |
| | | | | | | | | | Length:0.5" | |
| C 1. 10 | STEAM GENERATOR 21 | II | 2-1S1-37 | UT60 | W-E | 90-229 | Results:NONE | 3 | Results:GEO | SEE REPORT 90-227 |
| | | | | | | | | | Scan: 3 | |
| | | | | | | | | | Type:ID | |
| | | | | | | | | | Amplitude:210 | |
| | | | | | | | | | Ax Loc: | |
| | | | | | | | | | Circ Loc: | |
| | | | | | | | | | Length:4.5" | |
| C 1. 10 | STEAM GENERATOR 21 | II | 2-1S1-37 | UT60 | W-E | 90-229 | Results:NONE | 4 | Results:GEO | NONE |
| | | | | | | | | | Scan: 4 | |
| | | | | | | | | | Type:ID | |
| | | | | | | | | | Amplitude:200 | |
| | | | | | | | | | Ax Loc: | |
| | | | | | | | | | Circ Loc: | |
| | | | | | | | | | Length:4.5" | |
| C 1. 10 | STEAM GENERATOR 21 | II | 2-1S1-37 | V11 | W-E | 90-204 | Results:NONE | | Results:NONE | NONE |
| C 1. 10 | STEAM GENERATOR 21 | II | 2-1S1-37 | UT0 | W-F | 90-136 | Results:NONE | 1L | Results:NONE | SEE REPORT 90-156 |
| C 1. 10 | STEAM GENERATOR 21 | II | 2-1S1-37 | UT45 | W-F | 90-156 | Results:NONE | 1 | Results:GEO | INSULATION LUGS @ 5'7"-5'10", |
| | | | | | | | | | Scan: 1 | |
| | | | | | | | | | Type:ID | |
| | | | | | | | | | Amplitude:110 | |
| | | | | | | | | | Ax Loc: | |
| | | | | | | | | | Circ Loc: | |
| | | | | | | | | | Length:1.5" | |
| C 1. 10 | STEAM GENERATOR 21 | II | 2-1S1-37 | UT45 | W-F | 90-156 | Results:NONE | 1 | Results:GEO | 13'3"-13'7", 17'1"-17'4", |
| | | | | | | | | | Scan: 1 | |
| | | | | | | | | | Type:ID | |
| | | | | | | | | | Amplitude:100 | |
| | | | | | | | | | Ax Loc: | |
| | | | | | | | | | Circ Loc: | |
| | | | | | | | | | Length:1.6" | |

NORTHERN STATES POWER COMPANY
PRAIRIE ISLAND UNIT II

TABLE 8-II

Examination Comparison Summary

| SUB-ITEM | SYSTEM | CLASS | ISO | METH | ITEM | REPORT | PREVIOUS RESULTS | SCAN | CURRENT RESULTS | LIMITATIONS |
|----------|--------------------|-------|----------|------|------|--------|------------------|------|--|----------------------------|
| C 1. 10 | STEAM GENERATOR 21 | 11 | 2-1S1-37 | UT45 | W-F | 90-156 | Results:NONE | 2 | Results:IND Scan: 2 Type:LINEAR Amplitude:25 Ax Loc:+ 1.45 Circ Loc:20' 5" Length:0.9" | 20'11"-21'3", 24'9"-25'1" |
| C 1. 10 | STEAM GENERATOR 21 | 11 | 2-1S1-37 | UT45 | W-F | 90-156 | Results:NONE | 3 | Results:GEO Scan: 3 Type:ID Amplitude:110 Ax Loc: Circ Loc: Length:0.8" | 28'7"-28'10", 40'1"-40'4" |
| C 1. 10 | STEAM GENERATOR 21 | 11 | 2-1S1-37 | UT45 | W-F | 90-156 | Results:NONE | 4 | Results:GEO Scan: 4 Type:ID Amplitude:80 Ax Loc: Circ Loc: Length:0.7" | NONE |
| C 1. 10 | STEAM GENERATOR 21 | 11 | 2-1S1-37 | UT45 | W-F | 90-156 | Results:NONE | 4 | Results:GEO Scan: 4 Type:ID Amplitude:200 Ax Loc: Circ Loc: Length:1.5" | NONE |
| C 1. 10 | STEAM GENERATOR 21 | 11 | 2-1S1-37 | UT60 | W-F | 90-145 | Results:NONE | 1 | Results:NONE | INSULATION LUGS @ 5'7"-10" |
| C 1. 10 | STEAM GENERATOR 21 | 11 | 2-1S1-37 | UT60 | W-F | 90-145 | Results:NONE | 2 | Results:NONE | 17'1"-17'4", 24'9"-25'1" |
| C 1. 10 | STEAM GENERATOR 21 | 11 | 2-1S1-37 | UT60 | W-F | 90-145 | Results:NONE | 3 | Results:NONE | 28'7"-29'10", 40'1"-40'4" |
| C 1. 10 | STEAM GENERATOR 21 | 11 | 2-1S1-37 | UT60 | W-F | 90-145 | Results:NONE | 4 | Results:NONE | 13'3"-13'7", 20'11"-21'3" |
| C 1. 10 | STEAM GENERATOR 21 | 11 | 2-1S1-37 | VT1 | W-F | 90-155 | Results:NONE | | Results:NONE | NONE |
| C 2. 10 | RHR HEAT EXCH 21 | 11 | 2-1S1-69 | PT | W-3 | 90-047 | Results:N/A | | Results:NONE | NONE |
| C 2. 10 | RHR HEAT EXCH 21 | 11 | 2-1S1-69 | VT1 | W-3 | 90-049 | Results:N/A | | Results:NONE | NONE |

NORTHERN STATES POWER COMPANY
PRAIRIE ISLAND UNIT II

TABLE S-II

Examination Comparison Summary

| SUB-ITEM | SYSTEM | CLASS | ISO | METH | ITEM | REPORT | PREVIOUS RESULTS | SCAN | CURRENT RESULTS | LIMITATIONS |
|----------|--------------------|-------|-----------|------|-----------|---------|------------------|------|---------------------|------------------------------|
| C 3. 10 | RHR HEAT EXCH 21 | 11 | 2-1S1-69 | PT | SUPPORT A | 90-048 | Results:NONE | | Results:NONE | NONE |
| C 3. 10 | RHR HEAT EXCH 21 | 11 | 2-1S1-69 | VT1 | SUPPORT A | 90-050 | Results:NONE | | Results:NONE | NONE |
| C 3. 20 | FEEDWATER A | 11 | 2-1S1-48A | MT | FWH-68/B | 90-237 | Results:NONE | | Results:IND | NONE |
| | | | | | | | | | Type:LINEAR | |
| | | | | | | | | | Ax Loc:+ 0.5" | |
| | | | | | | | | | Circ Loc:360" INTER | |
| | | | | | | | | | Length:360" INTER | |
| C 3. 20 | FEEDWATER A | 11 | 2-1S1-48A | MT1 | FWH-68/B | 90-237R | Results:N/A | | Results:NONE | NONE |
| C 3. 20 | FEEDWATER A | 11 | 2-1S1-48A | VT1 | FWH-68/B | 90-265 | Results:NONE | | Results:NONE | NONE |
| C 3. 20 | FEEDWATER A | 11 | 2-1S1-48A | MT1 | FWH-70/F | 90-238 | Results:NONE | | Results:NONE | NONE |
| C 3. 20 | FEEDWATER A | 11 | 2-1S1-48A | VT1 | FWH-70/F | 90-266 | Results:NONE | | Results:NONE | NONE |
| C 3. 20 | MAIN STEAM A | 11 | 2-1S1-46A | MT1 | MSH-34/K | 90-239 | Results:N/A | | Results:NONE | NONE |
| C 3. 20 | MAIN STEAM A | 11 | 2-1S1-46A | VT1 | MSH-34/K | 90-259 | Results:NONE | | Results:NONE | NONE |
| C 3. 20 | MAIN STEAM A | 11 | 2-1S1-46B | MT1 | MSH-32/M | 90-273 | Results:N/A | | Results:N/A | NONE |
| C 3. 20 | MAIN STEAM A | 11 | 2-1S1-46B | VT1 | MSH-32/M | 90-260 | Results:NONE | | Results:NONE | NONE |
| C 3. 20 | MAIN STEAM B | 11 | 2-1S1-47A | MT1 | MSH-41/H | 90-135 | Results:NONE | | Results:NONE | PARTIAL - INACCESSIBLE AREAS |
| C 3. 20 | MAIN STEAM B | 11 | 2-1S1-47A | VT1 | MSH-41/H | 90-097 | Results:NONE | | Results:NONE | NONE |
| C 3. 20 | MAIN STEAM B | 11 | 2-1S1-47A | MT | MSH-46/C | 90-240 | Results:N/A | | Results:IND | NONE |
| | | | | | | | | | Type:ARC STRIKE | |
| | | | | | | | | | Ax Loc:+ 0.250" | |
| | | | | | | | | | Circ Loc:0.0" | |
| | | | | | | | | | Length:1.25" | |
| C 3. 20 | MAIN STEAM B | 11 | 2-1S1-47A | VT1 | MSH-46/C | 90-096 | Results:N/A | | Results:NONE | NONE |
| C 3. 20 | MAIN STEAM B | 11 | 2-1S1-47A | MT1 | MSH-50/A1 | 90-055 | Results:N/A | | Results:NONE | NONE |
| C 3. 20 | MAIN STEAM B | 11 | 2-1S1-47A | VT1 | MSH-50/A1 | 90-058 | Results:N/A | | Results:NONE | NONE |
| C 3. 20 | RHR PUMP DISCH A | 11 | 2-1S1-57 | PT | RHRH-57/L | 90-270 | Results:IND | | Results:NONE | NONE |
| | | | | | | | Type:POROSITY | | | |
| | | | | | | | Ax Loc: | | | |
| | | | | | | | Circ Loc: | | | |
| | | | | | | | Length: | | | |
| C 3. 20 | RHR PUMP DISCH A | 11 | 2-1S1-57 | VT1 | RHRH-57/L | 90-220 | Results:NONE | | Results:NONE | NONE |
| C 3. 20 | RHR PUMP SUCTION B | 11 | 2-1S1-51 | PT | RHRH-56/C | 90-269 | Results:IND | | Results:NONE | NONE |
| | | | | | | | Type:INTERMIT | | | |
| | | | | | | | Ax Loc:UNDERCUT | | | |
| | | | | | | | Circ Loc: | | | |
| | | | | | | | Length: | | | |

NORTHERN STATES POWER COMPANY
PRAIRIE ISLAND UNIT II

TABLE S-II

Examination Comparison Summary

| SUB-ITEM | SYSTEM | CLASS | ISO | METH | ITEM | REPORT | PREVIOUS RESULTS | SCAN | CURRENT RESULTS | LIMITATIONS |
|----------|--------------------|-------|-----------|------|----------------|--------|--|------|---|--------------------------|
| C 3. 29 | RHR PUMP SUCTION B | II | 2-1S1-51 | VT1 | RHRH-56/C | 90-219 | Results:NONE | | Results:NONE | NONE |
| C 3. 30 | RHR PUMP 21 | II | 2-1S1-53 | PT | BASE/G | 90-020 | Results:N/A | | Results:NONE | NONE |
| C 3. 30 | RHR PUMP 21 | II | 2-1S1-53 | VT1 | BASE/G | 90-022 | Results:N/A | | Results:NONE | NONE |
| C 3. 30 | SI PUMP 21 | II | 2-1S1-60 | MT1 | SUPPORT C | 90-378 | Results:N/A | | Results:NONE | NONE |
| C 3. 30 | SI PUMP 21 | II | 2-1S1-60 | VT1 | SUPPORT C | 90-267 | Results:N/A | | Results:NONE | NONE |
| C 3. 30 | SI PUMP 21 | II | 2-1S1-60 | MT1 | SUPPORT D | 90-379 | Results:N/A | | Results:NONE | NONE |
| C 3. 30 | SI PUMP 21 | II | 2-1S1-60 | VT1 | SUPPORT D | 90-268 | Results:N/A | | Results:NONE | NONE |
| C 5. 11 | BORIC ACID SUPPLY | II | 2-1S1-74 | PT | W-1B | 90-045 | Results:N/A | | Results:NONE | NONE |
| C 5. 11 | BORIC ACID SUPPLY | II | 2-1S1-74 | VT1 | W-1B | 90-046 | Results:N/A | | Results:NONE | NONE |
| C 5. 11 | BORIC ACID TO SI | II | 2-1S1-61 | PT | W-3B | 90-039 | Results:N/A | | Results:NONE | NONE |
| C 5. 11 | BORIC ACID TO SI | II | 2-1S1-61 | VT1 | W-3B | 90-042 | Results:N/A | | Results:NONE | NONE |
| C 5. 11 | BORIC ACID TO SI | II | 2-1S1-61 | PT | W-4B | 90-040 | Results:N/A | | Results:NONE | NONE |
| C 5. 11 | BORIC ACID TO SI | II | 2-1S1-61 | VT1 | W-4B | 90-043 | Results:N/A | | Results:NONE | NONE |
| C 5. 11 | BORIC ACID TO SI | II | 2-1S1-61 | PT | W-55F | 90-041 | Results:N/A | | Results:NONE | NONE |
| C 5. 11 | BORIC ACID TO SI | II | 2-1S1-61 | VT1 | W-55F | 90-044 | Results:N/A | | Results:NONE | NONE |
| C 5. 11 | FEEDWATER A | II | 2-1S1-48A | UT45 | FW-177 (THICK) | 90-099 | Results:GEO Scan:1 Type:GEOMETRY Amplitude:55 Ax Loc:6" Circ Loc:8" Length:360 INTER | 1 | Results:NONE | SCAN 1 GAMMA PLUG @ 9:00 |
| C 5. 11 | FEEDWATER A | II | 2-1S1-48A | UT45 | FW-177 (THICK) | 90-099 | Results:NONE | 3 | Results:NONE | NO SCAN 2 NOZZLE |
| C 5. 11 | FEEDWATER A | II | 2-1S1-48A | UT45 | FW-177 (THICK) | 90-099 | Results:NONE | 4 | Results:NONE | NONE |
| C 5. 11 | FEEDWATER A | II | 2-1S1-48A | MT1 | FW-177 (THIN) | 90-051 | Results:IMD Type:LINEARS Ax Loc: Circ Loc: Length: | | Results:NONE | NONE |
| C 5. 11 | FEEDWATER A | II | 2-1S1-48A | UT45 | FW-177 (THIN) | 90-101 | Results:GEO Scan:1 Type:ID GEO Amplitude:65 Ax Loc:.6" Circ Loc:28" Length:360 INTER | 1 | Results:GEO Scan: 1 Type:ID Amplitude:25 Ax Loc: Circ Loc: Length:0° - 360° | SCAN 1 GAMMA PLUG @ 9:00 |

NORTHERN STATES POWER COMPANY
PRAIRIE ISLAND UNIT II

TABLE S-II

Examination Comparison Summary

| SUB-ITEM | SYSTEM | CLASS | ISO | METH | ITEM | REPORT | PREVIOUS RESULTS | SCAN | CURRENT RESULTS | LIMITATIONS |
|----------|------------------|-------|-----------|------|----------------|--------|---|------|---|-------------------------------|
| C 5. 11 | FEEDWATER A | 11 | 2-1S1-48A | UT45 | FW-177 (THIN) | 90-101 | Results:NONE | 2 | Results:GEO Scan: 2 Type:00 Amplitude:50 Ax Loc: Circ Loc: Length:0° - 360° | LIMITED DUE TO NOZZLE CONFIG. |
| C 5. 11 | FEEDWATER A | 11 | 2-1S1-48A | UT45 | FW-177 (THIN) | 90-101 | Results:NONE | 3 | Results:NONE | NONE |
| C 5. 11 | FEEDWATER A | 11 | 2-1S1-48A | UT45 | FW-177 (THIN) | 90-101 | Results:NONE | 4 | Results:NONE | NONE |
| C 5. 11 | FEEDWATER A | 11 | 2-1S1-48A | VT1 | FW-177 (THIN) | 90-053 | Results:NONE | | Results:NONE | NONE |
| C 5. 11 | FEEDWATER B | 11 | 2-1S1-49A | UT45 | FW-133 (THICK) | 90-098 | Results:GEO Scan:1 Type:ID GEO Amplitude:55 Ax Loc:.7" Circ Loc:9" Length:360 INTER | 1 | Results:GEO Scan: 1 Type:ID Amplitude:45 Ax Loc: Circ Loc: Length:0° - 360° | SCAN 1 GAMMA PLUG @ 12:00 |
| C 5. 11 | FEEDWATER B | 11 | 2-1S1-49A | UT45 | FW-133 (THICK) | 90-098 | Results:NONE | 3 | Results:NONE | NO SCAN 2 NOZZLE |
| C 5. 11 | FEEDWATER B | 11 | 2-1S1-49A | UT45 | FW-133 (THICK) | 90-098 | Results:NONE | 4 | Results:NONE | NONE |
| C 5. 11 | FEEDWATER B | 11 | 2-1S1-49A | VT1 | FW-133 (THIN) | 90-052 | Results:NONE | | Results:NONE | NONE |
| C 5. 11 | FEEDWATER B | 11 | 2-1S1-49A | UT45 | FW-133 (THIN) | 90-100 | Results:GEO Scan:1 Type:ID GEO Amplitude:55 Ax Loc:.7" Circ Loc:9" Length:360 INTER | 1 | Results:GEO Scan: 1 Type:ID Amplitude:45 Ax Loc: Circ Loc: Length:0° - 360° | SCAN 2 LIMITED NOZZLE CONFIG. |
| C 5. 11 | FEEDWATER B | 11 | 2-1S1-49A | UT45 | FW-133 (THIN) | 90-100 | Results:NONE | 2 | Results:NONE | LIMITED DUE TO NOZZLE CONFIG. |
| C 5. 11 | FEEDWATER B | 11 | 2-1S1-49A | UT45 | FW-133 (THIN) | 90-100 | Results:NONE | 3 | Results:NONE | NONE |
| C 5. 11 | FEEDWATER B | 11 | 2-1S1-49A | UT45 | FW-133 (THIN) | 90-100 | Results:NONE | 4 | Results:NONE | NONE |
| C 5. 11 | FEEDWATER B | 11 | 2-1S1-49A | VT1 | FW-133 (THIN) | 90-054 | Results:NONE | | Results:NONE | NONE |
| C 5. 11 | RHR PUMP DISCH B | 11 | 2-1S1-54 | PT | W-29 | 90-032 | Results:N/A | | Results:NONE | NONE |
| C 5. 11 | RHR PUMP DISCH B | 11 | 2-1S1-54 | VT1 | W-29 | 90-035 | Results:N/A | | Results:SOBE | NONE |
| C 5. 11 | RHR PUMP DISCH B | 11 | 2-1S1-54 | PT | W-33 | 90-033 | Results:N/A | | Results:NONE | NONE |
| C 5. 11 | RHR PUMP DISCH B | 11 | 2-1S1-54 | VT1 | W-33 | 90-036 | Results:N/A | | Results:NONE | NONE |

NORTHERN STATES POWER COMPANY
PRAIRIE ISLAND UNIT II

TABLE 3-II

Examination Comparison Summary

| SUB-ITEM | SYSTEM | CLASS | ISO | METH | ITEM | REPORT | PREVIOUS RESULTS | SCAN | CURRENT RESULTS | REMARKS |
|----------|--------------------|-------|-----------|------|-------|--------|------------------|------|-----------------|-----------------------------|
| C 5. 11 | RHR PUMP SUCTION A | II | 2-1SI-52 | PT | W-102 | 90-021 | Results:N/A | | Results:NONE | NONE |
| C 5. 11 | RHR PUMP SUCTION A | II | 2-1SI-52 | VT1 | W-102 | 90-023 | Results:N/A | | Results:NONE | NONE |
| C 5. 11 | RHR PUMP SUCTION B | II | 2-1SI-50 | PT | W-135 | 90-028 | Results:N/A | | Results:NONE | NONE |
| C 5. 11 | RHR PUMP SUCTION B | II | 2-1SI-50 | VT1 | W-135 | 90-030 | Results:N/A | | Results:NONE | NONE |
| C 5. 11 | RWST DISCHARGE | II | 2-1SI-66 | PT | W-71W | 90-034 | Results:N/A | | Results:NONE | NONE |
| C 5. 11 | RWST DISCHARGE | II | 2-1SI-66 | VT1 | W-71W | 90-037 | Results:N/A | | Results:NONE | NONE |
| C 5. 11 | SI PUMP B SUCTION | II | 2-1SI-62 | PT | W-143 | 90-018 | Results:N/A | | Results:NONE | NONE |
| C 5. 11 | SI PUMP B SUCTION | II | 2-1SI-62 | VT1 | W-143 | 90-019 | Results:N/A | | Results:NONE | NONE |
| C 5. 11 | SI PUMP B SUCTION | II | 2-1SI-62 | PT | W-78 | 90-029 | Results:N/A | | Results:NONE | NONE |
| C 5. 11 | SI PUMP B SUCTION | II | 2-1SI-62 | VT1 | W-78 | 90-031 | Results:N/A | | Results:NONE | NONE |
| C 5. 21 | MAIN STEAM A | II | 2-1SI-46A | MT1 | MS-1 | 90-056 | Results:N/A | | Results:NONE | NONE |
| C 5. 21 | MAIN STEAM A | II | 2-1SI-46A | UT45 | MS-1 | 90-247 | Results:N/A | 1 | Results:GEO | 3"x4" LIMITATION @ 3:00 3" |
| C 5. 21 | MAIN STEAM A | II | 2-1SI-46A | UT45 | MS-1 | 90-247 | Results:N/A | 2 | Results:GEO | DOWNSTREAM (PIPE FITTING) |
| | | | | | | | | | Scan: 2 | |
| | | | | | | | | | Type:ID | |
| | | | | | | | | | Amplitude:28 | |
| | | | | | | | | | Ax Loc: | |
| | | | | | | | | | Circ Loc: | |
| | | | | | | | | | Length:360" | |
| C 5. 21 | MAIN STEAM A | II | 2-1SI-46A | UT45 | MS-1 | 90-247 | Results:N/A | 2 | Results:GEO | UPSTREAM LIMITED TO 2" SCAN |
| | | | | | | | | | Scan: 2 | |
| | | | | | | | | | Type:OD | |
| | | | | | | | | | Amplitude:120 | |
| | | | | | | | | | Ax Loc: | |
| | | | | | | | | | Circ Loc: | |
| | | | | | | | | | Length:360" | |
| C 5. 21 | MAIN STEAM A | II | 2-1SI-46A | UT45 | MS-1 | 90-247 | Results:N/A | 2 | Results:GEO | AREA DUE TO CONFIGURATION |
| | | | | | | | | | Scan: 2 | |
| | | | | | | | | | Type:ID | |
| | | | | | | | | | Amplitude:40 | |
| | | | | | | | | | Ax Loc: | |
| | | | | | | | | | Circ Loc: | |
| | | | | | | | | | Length:360" | |
| C 5. 21 | MAIN STEAM A | II | 2-1SI-46A | UT45 | MS-1 | 90-247 | Results:N/A | 3 | Results:NONE | NONE |
| C 5. 21 | MAIN STEAM A | II | 2-1SI-46A | UT45 | MS-1 | 90-247 | Results:N/A | 4 | Results:NONE | NONE |

NORTHERN STATES POWER COMPANY
PRAIRIE ISLAND UNIT II

TABLE S-II

Examination Comparison Summary

| SUB-ITEM | SYSTEM | CLASS | ISO | METH | ITEM | REPORT | PREVIOUS RESULTS | SCAN | CURRENT RESULTS | LIMITATIONS |
|----------|--------------|-------|-----------|------|-------|---------|------------------|------|--|-------------------|
| C 5. 21 | MAIN STEAM A | II | 2-1SI-46A | UT45 | MS-1 | 90-247 | Results:N/A | 5 | Results:NONE | NONE |
| C 5. 21 | MAIN STEAM A | II | 2-1SI-46A | UT45 | MS-1 | 90-247 | Results:N/A | 6 | Results:NONE | NONE |
| C 5. 21 | MAIN STEAM A | II | 2-1SI-46A | UT45 | MS-1 | 90-247 | Results:N/A | 7 | Results:NONE | NONE |
| C 5. 21 | MAIN STEAM A | II | 2-1SI-46A | UT45 | MS-1 | 90-247 | Results:N/A | 8 | Results:NONE | NONE |
| C 5. 21 | MAIN STEAM A | II | 2-1SI-46A | UT45 | MS-1 | 90-247 | Results:N/A | 9 | Results:NONE | NONE |
| C 5. 21 | MAIN STEAM A | II | 2-1SI-46A | UT45 | MS-1 | 90-247 | Results:N/A | 10 | Results:NONE | NONE |
| C 5. 21 | MAIN STEAM A | II | 2-1SI-46A | UT45 | MS-1 | 90-247 | Results:N/A | 11 | Results:NONE | NONE |
| C 5. 21 | MAIN STEAM A | II | 2-1SI-46A | UT45 | MS-1 | 90-247 | Results:N/A | 12 | Results:NONE | NONE |
| C 5. 21 | MAIN STEAM A | II | 2-1SI-46A | VT1 | MS-1 | 90-059 | Results:N/A | | Results:NONE | NONE |
| C 5. 21 | MAIN STEAM B | II | 2-1SI-47A | MT | MS-82 | 90-057 | Results:N/A | | Results:IND Type:LINEAR Ax Loc:-1"FRM TOE Circ Loc:12 O'CLOCK Length:1/2" | NONE |
| C 5. 21 | MAIN STEAM B | II | 2-1SI-47A | MT | MS-82 | 90-057 | Results:N/A | | Results:IND Type:LINEAR Ax Loc:@ TOE Circ Lo: 12 O'CLOCK Length:5/8" | NONE |
| C 5. 21 | MAIN STEAM B | II | 2-1SI-47A | MT | MS-82 | 90-057 | Results:N/A | | Results:IND Type:LINEAR Ax Loc:-1"FRM TOE Circ Loc:6 O'CLOCK Length:5/8" | NONE |
| C 5. 21 | MAIN STEAM B | II | 2-1SI-47A | MT1 | MS-82 | 90-057R | Results:N/A | | Results:NONE | NONE |
| C 5. 21 | MAIN STEAM B | II | 2-1SI-47A | UT45 | MS-82 | 90-323 | Results:N/A | 1 | Results:NONE | GAMMA PLUG @ 9:00 |
| C 5. 21 | MAIN STEAM B | II | 2-1SI-47A | UT45 | MS-82 | 90-323 | Results:N/A | 2 | Results:GEO Scan: 2 Type:00 Amplitude:90 Ax Loc: Circ Loc: Length:360° INTER | NONE |
| C 5. 21 | MAIN STEAM B | II | 2-1SI-47A | UT45 | MS-82 | 90-323 | Results:N/A | 3 | Results:NONE | NONE |
| C 5. 21 | MAIN STEAM B | II | 2-1SI-47A | UT45 | MS-82 | 90-323 | Results:N/A | 4 | Results:NONE | NONE |

NORTHERN STATES POWER COMPANY
PRAIRIE ISLAND UNIT II

TABLE S-II

Examination Comparison Summary

| SUB-ITEM | SYSTEM | CLASS | ISO | METH | ITEM | REPORT | PREVIOUS RESULTS | SCAN | CURRENT RESULTS | LIMITATIONS |
|----------|---------------------|-------|-----------|------|---------|--------|--|------|--|-----------------------------|
| C 5. 21 | MAIN STEAM B | II | 2-1S1-47A | VT1 | MS-82 | 90-060 | Results:W/A | | Results:NONE | NONE |
| C 5. 21 | MAIN STEAM RELIEF A | II | 2-1S1-46B | MT1 | MS-23 | 90-274 | Results:W/A | | Results:NONE | NONE |
| C 5. 21 | MAIN STEAM RELIEF A | II | 2-1S1-46B | UT45 | MS-23 | 90-297 | Results:GED Scan:1 Type:ID Amplitude:100 Ax Loc: Circ Loc:18.5-18.6" Length:1/8" | 1 | Results:NONE | 1"x2.5" LIMITATION @ 12:00, |
| C 5. 21 | MAIN STEAM RELIEF A | II | 2-1S1-46B | UT45 | MS-23 | 90-297 | Results:GED Scan:2 Type:OD Amplitude:150 Ax Loc: Circ Loc:24-24.5" Length:1/2" | 2 | Results:GED Scan: 2 Type:OD Amplitude:50 Ax Loc: Circ Loc: Length:360° | 2" UPSTREAM FROM WELD TOE |
| C 5. 21 | MAIN STEAM RELIEF A | II | 2-1S1-46B | UT45 | MS-23 | 90-297 | Results:NONE | 3 | Results:NONE | NONE |
| C 5. 21 | MAIN STEAM RELIEF A | II | 2-1S1-46B | UT45 | MS-23 | 90-297 | Results:NONE | 4 | Results:NONE | NONE |
| C 5. 21 | MAIN STEAM RELIEF A | II | 2-1S1-46B | VT1 | MS-23 | 90-284 | Results:NONE | | Results:NONE | NONE |
| C 5. 31 | MAIN STEAM RELIEF B | II | 2-1S1-47B | MT1 | MS-183B | 90-275 | Results:W/A | | Results:NONE | NONE |
| C 5. 31 | MAIN STEAM RELIEF B | II | 2-1S1-47B | UT45 | MS-183B | 90-416 | Results:NONE | 1 | Results:NONE | NO SCAN 2 CONFIGURATION |
| C 5. 31 | MAIN STEAM RELIEF B | II | 2-1S1-47B | UT45 | MS-183B | 90-416 | Results:NONE | 3 | Results:NONE | NONE |
| C 5. 31 | MAIN STEAM RELIEF B | II | 2-1S1-47B | UT45 | MS-183B | 90-416 | Results:NONE | 4 | Results:NONE | NONE |
| C 5. 31 | MAIN STEAM RELIEF B | II | 2-1S1-47B | VT1 | MS-183B | 90-285 | Results:NONE | | Results:NONE | NONE |
| C 6. 10 | SI PUMP 21 | II | 2-1S1-60 | MT1 | W-C | 90-380 | Results:W/A | | Results:NONE | NONE |
| C 6. 10 | SI PUMP 21 | II | 2-1S1-60 | VT1 | W-C | 90-381 | Results:W/A | | Results:NONE | NONE |

NORTHERN STATES POWER COMPANY
 PRAIRIE ISLAND UNIT II
 ISOMETRIC SUMMARY

CLASS II

TABLE III
 PAGE 1 OF 4

| NSP ISO NUMBER | REVISION NUMBER | COMPONENT OR SYSTEM | LOOP DESIG | LINE NUMBER | LINE SIZE | WALL THICK | UT-CAL STD | MAT'L TYPE |
|----------------|-----------------|----------------------|------------|---------------------|-----------|----------------------|------------|------------|
| 2-ISI-37 | 1 | STEAM GENERATOR | A&B | SHELL | - | 2.82" | 26 | C/S |
| | | | | SHELL-TO-TRANSITION | - | 2.82" | 26 | C/S |
| | | | | TRANSITION-TO-SHELL | - | 3.68" | 26 | C/S |
| | | | | SHELL-TO-HEAD | - | 3.62" | 26 | C/S |
| | | | | TUBESHEET-TO-SHELL | - | 3.25" | 26 | C/S |
| | | | | MS NOZZLE | - | 3.62" | 26 | C/S |
| | | | | 2-ISI-46 | 0 | MAIN STEAM (GENERAL) | - | - |
| 2-ISI-46A | 0 | A | 32-2MS-1 | 32" | - | | NO. — | |
| 2-ISI-46B | 0 | A | 31-2MS-1 | 31" | 1.534" | | 24 | C/S |
| | | | A | 30-2MS-1 | 30" | 1.045" | 23 | C/S |
| | | | A | 6-2MS-1 | 6" | .432" | 7 | C/S |
| 2-ISI-47 | 0 | MAIN STEAM (GENERAL) | - | - | - | - | - | |
| 2-ISI-47A | 0 | | B | 32-2MS-2 | 32" | - | NO. — | |
| 2-ISI-47B | 0 | | B | 31-2MS-1 | 31" | 1.534" | 24 | C/S |
| | | | B | 30-2MS-2 | 30" | 1.045" | 23 | C/S |
| | | | B | 6-2MS-2 | 6" | .432" | 7 | C/S |
| 2-ISI-48 | 0 | FEEDWATER (GENERAL) | - | - | - | - | - | |
| 2-ISI-48A | 0 | | A | 16-2FW-13 | 16" | 1.031" | 13/36 | C/S |
| 2-ISI-48B | 0 | | A | 16-2FW-12 | 16" | 1.438" | 21 | C/S |
| | | | A | 16-2FW-11 | 16" | 1.031" | 13 | C/S |
| | | | A | 3-2AF-11 | 8" | .594" | NO. — | |
| 2-ISI-49 | 0 | FEEDWATER (GENERAL) | - | - | - | - | - | |
| 2-ISI-49A | 0 | | B | 16-2FW-16 | 16" | 1.031" | 13/36 | C/S |
| 2-ISI-49B | 0 | | B | 16-2FW-15 | 16" | 1.438" | 21 | C/S |
| | | | B | 3-2AF-12 | 8" | .594" | NO. — | |

NORTHERN STATES POWER COMPANY
 PRAIRIE ISLAND UNIT II
 ISOMETRIC SUMMARY

CLASS II

TABLE III
 PAGE 2 OF 4

| NSP ISO NUMBER | REVISION NUMBER | COMPONENT OR SYSTEM | LOOP DESIG | LINE NUMBER | LINE SIZE | WALL THICK | UT-CAL STD | MAT'L TYPE |
|----------------|-----------------|---|------------|-------------|-----------|------------|------------|------------|
| 2-ISI-50 | 3 | RHR PUMP B SUCTION (WELDS) (HANGERS) | B | 10-2RH-3 | 10" | .365" | 22 | S/S |
| 2-ISI-51 | 3 | | B | 8-2RH-4B | 8" | .322" | 29 | S/S |
| | | | B | 8-2RH-5B | 8" | .322" | 29 | S/S |
| | | | B | 12-2RH-5B | 12" | .375" | 32 | S/S |
| | | | B | 10-2SI-9B | 10" | .365" | 22 | S/S |
| 2-ISI-52 | 3 | RHR PUMP A SUCTION (WELDS) (HANGERS) | A | 8-2RH-4A | 8" | .322" | 29 | S/S |
| 2-ISI-53 | 3 | | A | 8-2RH-5A | 8" | .322" | 29 | S/S |
| | | | A | 12-2RH-5A | 12" | .375" | 32 | S/S |
| | | | A | 10-2SI-9A | 10" | .365" | 22 | S/S |
| 2-ISI-54 | 3 | RHR PUMP B DISCHARGE (WELDS) (HANGERS) | B | 8-2RH-7B | 8" | .322" | 29 | S/S |
| 2-ISI-55 | 2 | | B | 8-2RH-9B | 8" | .322" | 29 | S/S |
| | | | B | 6-2SI-10B | 6" | .280" | 27 | S/S |
| 2-ISI-56 | 3 | RHR PUMP A DISCHARGE (WELDS) (HANGERS) | A | 8-2RH-7A | 8" | .322" | 29 | S/S |
| 2-ISI-57 | 2 | | A | 8-2RH-9A | 8" | .322" | 29 | S/S |
| | | | A | 6-2SI-11 | 6" | .365" | 22 | S/S |
| 2-ISI-58 | 2 | CONTAINMENT SUMP B DISCHARGE | B | 12-2RH-6B | 12" | .375" | 32 | S/S |
| | | | B | 14-2SI-33B | 14" | .250" | 34 | S/S |
| | | | B | 12-2SI-34B | 12" | .375" | 32 | S/S |
| 2-ISI-59 | 3 | CONTAINMENT SUMP A DISCHARGE | A | 12-2RH-6A | 12" | .375" | 32 | S/S |
| | | | A | 14-2SI-33A | 14" | .250" | 34 | S/S |
| | | | A | 12-2SI-34A | 12" | .375" | 32 | S/S |
| 2-ISI-60 | 2 | SAFETY INJECTION PUMPS SUCTION | A | 6-2SI-13A | 6" | .134" | 28 | S/S |
| | | | B | 6-2SI-13B | 6" | .134" | 28 | S/S |

NORTHERN STATES POWER COMPANY
 PRAIRIE ISLAND UNIT II
 ISOMETRIC SUMMARY

CLASS II

TABLE III
 PAGE 3 OF 4

| NSP ISO NUMBER | REVISION NUMBER | COMPONENT OR SYSTEM | LOOP DESIG | LINE NUMBER | LINE SIZE | WALL THICK | UT-CAL STD | MAT'L TYPE |
|----------------|-----------------|--|------------|-------------|-----------|------------|------------|------------|
| 2-ISI-61 | 3 | BORIC ACID SUPPLY TO SAFETY INJECTION | - | 12-2SI-11 | 12" | .180" | 33 | S/S |
| | | | - | 8-2SI-18 | 8" | .322" | 38 | S/S |
| 2-ISI-62 | 2 | SAFETY INJECTION PUMP 22 SUCTION (WELDS) | B | 6-2RH-10B | 6" | .280" | 27 | S/S |
| 2-ISI-63 | 2 | SAFETY INJECTION PUMP 22 SUCTION (HANGERS) | - | - | - | - | - | - |
| 2-ISI-64 | 2 | SAFETY INJECTION PUMP 21 SUCTION (WELDS) | A | 6-2RH-10A | 6" | .280" | 27 | S/S |
| 2-ISI-65 | 2 | SAFETY INJECTION PUMP 21 SUCTION (HANGERS) | - | - | - | - | - | - |
| 2-ISI-66 | 2 | REFUELING WATER STORAGE TANK DISCHARGE (WELDS) | - | 14-2SI-1 | 14" | .250" | 34 | S/S |
| 2-ISI-67 | 2 | REFUELING WATER STORAGE TANK DISCHARGE (HANGERS) | - | 12-2SI-3A | 12" | .180" | 33 | S/S |
| | | | - | 12-2SI-3B | 12" | .180" | 33 | S/S |
| | | | - | 12-2SI-4 | 12" | .180" | 33 | S/S |
| | | | - | 10-2SI-8 | 10" | .165" | 31 | S/S |
| | | | - | 12-2SI-11 | 12" | .180" | 33 | S/S |
| 2-ISI-68 | 1 | BORIC ACID TANK 21 | - | SHELL | - | .312" | NO. ___ | - |
| | | | - | BOTTOM HEAD | - | .375" | NO. ___ | - |
| 2-ISI-69 | 1 | RESIDUAL HEAT EXCHANGERS | A | HEAD | - | .500" | NO. ___ | - |
| | | | B | HEAD | - | .500" | NO. ___ | - |
| 2-ISI-70 | 2 | REACTOR VESSEL SAFETY INJECTION (WELDS) | B | 6-2SI-25B | 6" | .719" | 6 | S/S |
| 2-ISI-71 | 2 | REACTOR VESSEL SAFETY INJECTION (HANGERS) | - | - | - | - | - | - |

| NSP ISO NUMBER | REVISION NUMBER | COMPONENT OR SYSTEM | LOOP DESIG | LINE NUMBER | LINE SIZE | WALL THICK | UT-CAL STD | MAT'L TYPE |
|----------------|-----------------|---|------------|-------------|-----------|------------|------------|------------|
| 2-ISI-72 | 2 | REACTOR VESSEL SAFETY INJECTION (WELDS) | A | 6-2SI-25A | 6" | .719" | 6 | S/S |
| 2-ISI-73 | 2 | REACTOR VESSEL SAFETY INJECTION (HANGERS) | | | | | | |
| 2-ISI-74 | 2 | BORIC ACID SUPPLY (WELDS) | - | 8-2SI-18 | 8" | .322" | 38 | S/S |
| 2-ISI-75 | 3 | ACCUMULATOR DISCHARGE | A | 12-2SI-28A | 12" | 1.312" | 11 | S/S |
| | | | A | 12-2SI-29A | 12" | 1.312" | 11 | S/S |
| | | | B | 12-2SI-28B | 12" | 1.312" | 11 | S/S |
| | | | B | 12-2SI-29B | 12" | 1.312" | 11 | S/S |
| 2-ISI-76 | 1 | ACCUMULATOR TANKS | A | SHELL | - | 2.75" | NO. ___ | |
| | | | A | HEAD | - | 1.39" | NO. ___ | |
| | | | B | SHELL | - | 2.75" | NO. ___ | |
| | | | B | HEAD | - | 1.39" | NO. ___ | |

APPENDIX C
FSAR AUGMENTED EXAMINATIONS

INSERVICE INSPECTION—EXAMINATION SUMMARY

MAJOR ITEM:

| SUB ITEM | EXAM CATE-GORY | COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED | INSP. PER. | REQ'D AMT. | AMOUNT EXAM | ITEM IDENTIFICATION | INSPECTION REPORT NO. |
|----------|----------------|--|------------|------------|-------------|---------------------|-----------------------|
| C5.10 | C-F | <u>PRESSURE RETAINING WELDS IN PIPING</u> | | | | | |
| | C-F | <u>PIPING WELDS 1/2 INCH AND LESS NOMINAL WALL THICKNESS</u> | | | | | |
| C5.11 | C-F | <u>CIRCUMFERENTIAL WELDS AND</u> | | | | | |
| C5.12 | C-F | <u>LONGITUDINAL WELDS</u> | | | | | |
| | | MAIN STEAM A & B | | | | | |
| | | 6-2MS-1 | ONE | 1 | 1 | MS-35 | 85-142 |
| | | 6-2MS-2 | TWO | - | 2 | MS-114,115 | 89-264,265,266,267 |
| | | 5-2MS-1 | THREE | 1 | - | | |
| | | 5-2MS-2 | | | | | |
| C5.20 | C-F | <u>PIPING WELDS GREATER THAN 1/2 INCH NOMINAL WALL THICKNESS</u> | | | | | |
| C5.21 | C-F | <u>CIRCUMFERENTIAL WELDS AND</u> | | | | | |
| C5.22 | C-F | <u>LONGITUDINAL WELDS</u> | | | | | |
| | | MAIN STEAM A | | | | | |
| | | 31-2MS-1 | ONE | 1 | 1 | MS-16 | 86-089,090,103 |
| | | | TWO | 1 | 1 | MS-17 | 90-276,415,286 |
| | | | THREE | 2 | - | | |
| | | MAIN STEAM B | * | - | - | | * ENCAPSULATED |
| | | 31-2MS-32 | | | | | |

P225 FSAR

INSERVICE INSPECTION—EXAMINATION SUMMARY

MAJOR ITEM:

| SUB ITEM | EXAM CATEGORY | COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED | INSP. PER. | REQ'D AMT. | AMOUNT EXAM | ITEM IDENTIFICATION | INSPECTION REPORT NO. |
|---------------|---------------|--|---|---|---|--|---|
| C5.21 & C5.22 | C-F | <p>(CONTINUED)</p> <p>MAIN STEAM A RELIEF HEADER</p> <p>30-2MS-1</p> <p>MAIN STEAM B RELIEF HEADER</p> <p>30-2MS-2</p> <p>MAIN STEAM A</p> <p>30-2MS-1 30-2MS-3</p> <p>MAIN STEAM B</p> <p>30-2MS-2 30-2MS-4</p> | <p>ONE TWO THREE</p> <p>ONE TWO THREE</p> <p>ONE TWO THREE</p> <p>ONE TWO THREE</p> | <p>1 - -</p> <p>- 1 1</p> <p>1 1 1</p> <p>- 1 1</p> | <p>1 - -</p> <p>- 1 -</p> <p>1 1 -</p> <p>- 1 -</p> | <p>MS-187</p> <p>MS-101</p> <p>MS-52 MS-48</p> <p>MS-120</p> | <p>88-040,032,039</p> <p>89-278,408,279</p> <p>85-013,029 90-277,414,287,287R</p> <p>89-268,407,269</p> |

P22SF SAR

INSERVICE INSPECTION—EXAMINATION SUMMARY

MAJOR ITEM:

| SUB ITEM | EXAM CATEGORY | COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED | INSP. PER. | REQ'D AMT. | AMOUNT EXAM | ITEM IDENTIFICATION | INSPECTION REPORT NO. |
|---------------|---------------|--|---------------------|-------------|-------------|---------------------|---------------------------------------|
| C5.21 & C5.22 | C-F | (CONTINUED) | | | | | |
| | | MAIN STEAM A | | | | | |
| | | 24-2MS-21 | ONE TWO THREE | 1 1 - | 1 1 - | MS-56 MS-56 | 85-014,020 90-278,417,288,288R |
| | | MAIN STEAM B | | | | | |
| | | 24-2MS-24 | ONE TWO THREE | - - 1 | - - - | | |
| | | MAIN STEAM A | | | | | |
| | | 8-2MS-21 | ONE TWO THREE | - 1 - | - 1 - | MS-62 | 89-262,409,263 |
| | | MAIN STEAM B | | | | | |
| | | 8-2MS-24 | ONE TWO THREE | - - 1 | - - - | | |
| | | FEEDWATER A | | | | | |
| | | 16-2FW-8 | ONE TWO THREE | 1 1 3 | 1 1 - | FW-141 FW-136 | 88-296,285,232 90-279,279R,389,289 |

P22S SAR

INSERVICE INSPECTION—EXAMINATION SUMMARY

MAJOR ITEM:

| SUB ITEM | EXAM CATEGORY | COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED | INSP. PER. | REQ'D AMT. | AMOUNT EXAM | ITEM IDENTIFICATION | INSPECTION REPORT NO. | |
|---------------|---------------|--|---------------------|---|---------------------|---------------------|-----------------------|--------------------|
| C5.21 & C5.22 | C-F | (CONTINUED) | | | | | | |
| | | FEEOWATER B | | | | | | |
| | | 16-2FW-8 | ONE TWO THREE | - 1 2 | - 1 - | FW-101 | 89-280,406,281 | |
| | | FEEOWATER A | | | | | | |
| | | 16-2FW-9 16-2FW-11 16-2FW-12 | ONE TWO THREE | 1 - 1 | 1 - - | FW-155 | 88-297,295,233 | |
| | | FEEOWATER B | | | | | | |
| | | 16-2FW-10 16-2FW-15 | ONE TWO THREE | 1 - 1 | 1 - - | FW-114 | 86-268,271,281 | |
| | | C5.30 | C-F | PIPE BRANCH CONNECTION GREATER THAN 4 INCH NOMINAL BRANCH PIPE SIZE | | | | |
| | | C5.31 | C-F | CIRCUMFERENTIAL WELDS | | | | |
| | | | | MAIN STEAM A RELIEF HEADER (AT 12") 30-2MS-1 | ONE TWO THREE | 1 1 1 | 1 1 - | MS-187B MS-185B |
| | | MAIN STEAM B RELIEF HEADER (AT 12") 30-2MS-2 | ONE TWO THREE | - 1 1 | - 1 - | MS-181B | 90-280,290 | |

P225 SAR

INSERVICE INSPECTION—EXAMINATION SUMMARY

MAJOR ITEM: _____

| SUB ITEM | EXAM CATE- GORY | COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED | INSP. PER. | REQ'D AMT. | AMOUNT EXAM | ITEM IDENTIFICATION | INSPECTION REPORT NO. |
|-------------|-----------------------|---|---------------------|---------------|----------------|------------------------|--------------------------|
| C5.31 | C-F | (CONTINUED) MAIN STEAM A & B 24-2MS-21 24-2MS-24 | ONE TWO THREE | - - 1 | - - - | | |
| C5.32 | C-F | <u>LONGITUDINAL WELDS</u> | - | - | - | | INCLUDED WITH C5.31 |

P22S-SAR

NORTHERN STATES POWER COMPANY
PRAIRIE ISLAND UNIT II

TABLE S-II

Examination Comparison Summary

| SUB-ITEM | SYSTEM | CLASS | ISO | METH | ITEM | REPORT | PREVIOUS RESULTS | SCAN | CURRENT RESULTS | LIMITATIONS |
|----------|--------------|-------|-----------|------|--------|---------|------------------|------|--|---------------------------|
| C 5. 21 | FEEDWATER A | FSAR | 2-1S1-48C | MT | FW-136 | 90-279 | Results:N/A | | Results:IND Type:LINEAR Ax Loc:- 0.9" Circ Loc:1.8" CCW Length:0.50" | NONE |
| C 5. 21 | FEEDWATER A | FSAR | 2-1S1-48C | MT1 | FW-136 | 90-279R | Results:N/A | | Results:NONE | NONE, REEXAM AFTER REPAIR |
| C 5. 21 | FEEDWATER A | FSAR | 2-1S1-48C | UT45 | FW-136 | 90-389 | Results:NONE | 1 | Results:NONE | GAMMA PLUG @ 12:00 |
| C 5. 21 | FEEDWATER A | FSAR | 2-1S1-48C | UT45 | FW-136 | 90-389 | Results:NONE | 2 | Results:NONE | NONE |
| C 5. 21 | FEEDWATER A | FSAR | 2-1S1-48C | UT45 | FW-136 | 90-389 | Results:NONE | 3 | Results:NONE | NONE |
| C 5. 21 | FEEDWATER A | FSAR | 2-1S1-48C | UT45 | FW-136 | 90-389 | Results:NONE | 4 | Results:NONE | NONE |
| C 5. 21 | FEEDWATER A | FSAR | 2-1S1-48C | VT1 | FW-136 | 90-289 | Results:N/A | | Results:NONE | NONE |
| C 5. 21 | MAIN STEAM A | FSAR | 2-1S1-46B | MT1 | MS-17 | 90-276 | Results:NONE | | Results:NONE | NONE |
| C 5. 21 | MAIN STEAM A | FSAR | 2-1S1-46B | UT45 | MS-17 | 90-415 | Results:NONE | 1 | Results:NONE | NONE |
| C 5. 21 | MAIN STEAM A | FSAR | 2-1S1-46B | UT45 | MS-17 | 90-415 | Results:NONE | 2 | Results:NONE | NONE |
| C 5. 21 | MAIN STEAM A | FSAR | 2-1S1-46B | UT45 | MS-17 | 90-415 | Results:NONE | 3 | Results:NONE | NONE |
| C 5. 21 | MAIN STEAM A | FSAR | 2-1S1-46B | UT45 | MS-17 | 90-415 | Results:NONE | 4 | Results:NONE | NONE |
| C 5. 21 | MAIN STEAM A | FSAR | 2-1S1-46B | UT45 | MS-17 | 90-415 | Results:NONE | 5 | Results:NONE | NONE |
| C 5. 21 | MAIN STEAM A | FSAR | 2-1S1-46B | UT45 | MS-17 | 90-415 | Results:NONE | 6 | Results:NONE | NONE |
| C 5. 21 | MAIN STEAM A | FSAR | 2-1S1-46B | UT45 | MS-17 | 90-415 | Results:NONE | 7 | Results:NONE | NONE |
| C 5. 21 | MAIN STEAM A | FSAR | 2-1S1-46B | UT45 | MS-17 | 90-415 | Results:NONE | 8 | Results:NONE | NONE |
| C 5. 21 | MAIN STEAM A | FSAR | 2-1S1-46B | UT45 | MS-17 | 90-415 | Results:NONE | 9 | Results:NONE | NONE |
| C 5. 21 | MAIN STEAM A | FSAR | 2-1S1-46B | UT45 | MS-17 | 90-415 | Results:NONE | 10 | Results:NONE | NONE |
| C 5. 21 | MAIN STEAM A | FSAR | 2-1S1-46B | UT45 | MS-17 | 90-415 | Results:NONE | 11 | Results:NONE | NONE |
| C 5. 21 | MAIN STEAM A | FSAR | 2-1S1-46B | UT45 | MS-17 | 90-415 | Results:NONE | 12 | Results:NONE | NONE |
| C 5. 21 | MAIN STEAM A | FSAR | 2-1S1-46B | UT45 | MS-17 | 90-415 | Results:NONE | 13 | Results:NONE | NONE |
| C 5. 21 | MAIN STEAM A | FSAR | 2-1S1-46B | UT45 | MS-17 | 90-415 | Results:NONE | 14 | Results:NONE | NONE |
| C 5. 21 | MAIN STEAM A | FSAR | 2-1S1-46B | UT45 | MS-17 | 90-415 | Results:NONE | 15 | Results:NONE | NONE |
| C 5. 21 | MAIN STEAM A | FSAR | 2-1S1-46B | UT45 | MS-17 | 90-415 | Results:NONE | 16 | Results:NONE | NONE |
| C 5. 21 | MAIN STEAM A | FSAR | 2-1S1-46B | VT1 | MS-17 | 90-286 | Results:NONE | | Results:NONE | NONE |
| C 5. 21 | MAIN STEAM A | FSAR | 2-1S1-46C | MT1 | MS-48 | 90-277 | Results:N/A | | Results:NONE | NONE |
| C 5. 21 | MAIN STEAM A | FSAR | 2-1S1-46C | UT45 | MS-48 | 90-414 | Results:N/A | 1 | Results:GEO Scan: 1 Type:ID Amplitude:30 Ax Loc: Circ Loc: Length:360" INTER | GAMMA PLUG @ 11:00 |

NORTHERN STATES POWER COMPANY
PRAIRIE ISLAND UNIT II

TABLE S-II

Examination Comparison Summary

| SUB-ITEM | SYSTEM | CLASS | ISO | METH | ITEM | REPORT | PREVIOUS RESULTS | SCAN | CURRENT RESULTS | LIMITATIONS |
|----------|---------------------|-------|-----------|------|---------|---------|------------------|------|--|--------------------------------|
| C 5. 21 | MAIN STEAM A | FSAR | 2-ISI-46C | UT45 | MS-48 | 90-414 | Results:N/A | 2 | Results:GEO Scan: 2 Type:ID Amplitude:35 Ax Loc: Circ Loc: Length:360° INTER | NONE |
| C 5. 21 | MAIN STEAM A | FSAR | 2-ISI-46C | UT45 | MS-48 | 90-414 | Results:N/A | 3 | Results:NONE | NONE |
| C 5. 21 | MAIN STEAM A | FSAR | 2-ISI-46C | UT45 | MS-48 | 90-414 | Results:N/A | 4 | Results:NONE | NONE |
| C 5. 21 | MAIN STEAM A | FSAR | 2-ISI-46C | UT45 | MS-48 | 90-414 | Results:N/A | 5 | Results:NONE | NONE |
| C 5. 21 | MAIN STEAM A | FSAR | 2-ISI-46C | UT45 | MS-48 | 90-414 | Results:N/A | 6 | Results:NONE | NONE |
| C 5. 21 | MAIN STEAM A | FSAR | 2-ISI-46C | UT45 | MS-48 | 90-414 | Results:N/A | 7 | Results:NONE | NONE |
| C 5. 21 | MAIN STEAM A | FSAR | 2-ISI-46C | UT45 | MS-48 | 90-414 | Results:N/A | 8 | Results:NONE | NONE |
| C 5. 21 | MAIN STEAM A | FSAR | 2-ISI-46C | UT45 | MS-48 | 90-414 | Results:N/A | 9 | Results:NONE | NONE |
| C 5. 21 | MAIN STEAM A | FSAR | 2-ISI-46C | UT45 | MS-48 | 90-414 | Results:N/A | 10 | Results:NONE | NONE |
| C 5. 21 | MAIN STEAM A | FSAR | 2-ISI-46C | UT45 | MS-48 | 90-414 | Results:N/A | 11 | Results:NONE | NONE |
| C 5. 21 | MAIN STEAM A | FSAR | 2-ISI-46C | UT45 | MS-48 | 90-414 | Results:N/A | 12 | Results:NONE | NONE |
| C 5. 21 | MAIN STEAM A | FSAR | 2-ISI-46C | VT1 | MS-48 | 90-287 | Results:N/A | | Results:IND Type:ARC STRIKE Ax Loc: Circ Loc: Length: | NONE |
| C 5. 21 | MAIN STEAM A | FSAR | 2-ISI-46C | VT1 | MS-48 | 90-287R | Results:N/A | | Results:NONE | NONE, REEXAM AFTER REPAIR |
| C 5. 21 | MAIN STEAM A | FSAR | 2-ISI-46D | MT1 | MS-56 | 90-278 | Results:N/A | | Results:NONE | NONE |
| C 5. 21 | MAIN STEAM A | FSAR | 2-ISI-46D | UT45 | MS-56 | 90-417 | Results:N/A | 1 | Results:NONE | NO SCAN 2 DUE TO CONFIGURATION |
| C 5. 21 | MAIN STEAM A | FSAR | 2-ISI-46D | UT45 | MS-56 | 90-417 | Results:N/A | 3 | Results:NONE | LIMITED DUE TO CONFIGURATION |
| C 5. 21 | MAIN STEAM A | FSAR | 2-ISI-46D | UT45 | MS-56 | 90-417 | Results:N/A | 4 | Results:NONE | LIMITED DUE TO CONFIGURATION |
| C 5. 21 | MAIN STEAM A | FSAR | 2-ISI-46D | VT1 | MS-56 | 90-288 | Results:NONE | | Results:IND Type:GOUGES Ax Loc: Circ Loc: Length: | NONE |
| C 5. 21 | MAIN STEAM A | FSAR | 2-ISI-46D | VT1 | MS-56 | 90-288R | Results:N/A | | Results:NONE | NONE, REEXAM AFTER REPAIR |
| C 5. 31 | MAIN STEAM RELIEF B | FSAR | 2-ISI-47B | MT1 | MS-181B | 90-280 | Results:N/A | | Results:NONE | NONE |
| C 5. 31 | MAIN STEAM RELIEF B | FSAR | 2-ISI-47B | VT1 | MS-181B | 90-290 | Results:NONE | | Results:NONE | NONE |

NORTHERN STATES POWER COMPANY
 PRAIRIE ISLAND UNIT II
 ISOMETRIC SUMMARY

FSAR

TABLE III
 PAGE 1 OF 1

| NSP ISO NUMBER | REVISION NUMBER | COMPONENT OR SYSTEM | LOOP DESIG | LINE NUMBER | LINE SIZE | WALL THICK | UT-CAL STD | MAT'L TYPE |
|----------------|-----------------|----------------------|------------|-------------|-----------|------------|------------|------------|
| 2-ISI-46 | 0 | MAIN STEAM (GENERAL) | - | - | - | - | - | - |
| 2-ISI-46B | 0 | | A | 31-2MS-1 | 31" | 1.534" | 24 | C/S |
| 2-ISI-46C | 0 | | A | 31-2MS-1 | 31" | 1.045" | 23 | C/S |
| 2-ISI-46D | 0 | | A | 30-2MS-3 | 30" | 1.045" | 23 | C/S |
| | | | A | 24-2MS-21 | 24" | 1.219" | 20 | C/S |
| | | | A | 12-2MS-3 | 12" | .688" | NO. — | |
| | | | A | 8-2MS-21 | 8" | - | NO. — | |
| | | A | 6-2MS-1 | 6" | .432" | 7 | C/S | |
| 2-ISI-47 | 0 | MAIN STEAM (GENERAL) | - | - | - | - | - | - |
| 2-ISI-47B | 0 | | B | 31-2MS-2 | 31" | 1.534" | 24 | C/S |
| 2-ISI-47C | 0 | | B | 30-2MS-2 | 30" | 1.045" | 23 | C/S |
| | | | B | 30-2MS-4 | 30" | 1.045" | 23 | C/S |
| | | | B | 24-2MS-24 | 24" | 1.219" | 20 | C/S |
| | | | B | 12-2MS-4 | 12" | .688" | NO. — | |
| | | B | 6-2MS-2 | 6" | .432" | 7 | C/S | |
| 2-ISI-48 | 0 | FEEDWATER (GENERAL) | - | - | - | - | - | - |
| 2-ISI-48B | 0 | | A | 16-2FW-12 | 16" | 1.438" | 21 | C/S |
| 2-ISI-48C | 0 | | A | 16-2FW-11 | 16" | 1.031" | 13 | C/S |
| | | | A | 16-2FW-9 | 16" | 1.031" | 13 | C/S |
| | | A | 16-2FW-8 | 16" | 1.031" | 13 | C/S | |
| 2-ISI-49 | 0 | FEEDWATER (GENERAL) | - | - | - | - | - | - |
| 2-ISI-49B | 0 | | B | 16-2FW-15 | 16" | 1.438" | 21 | C/S |
| 2-ISI-49C | 0 | | B | 16-2FW-14 | 16" | 1.031" | 13 | C/S |
| | | | B | 16-2FW-10 | 16" | 1.031" | 13 | C/S |
| | | B | 16-2FW-8 | 16" | 1.031" | 13 | C/S | |

APPENDIX D
COMPONENT SUPPORTS

INSERVICE INSPECTION—EXAMINATION SUMMARY

MAJOR ITEM:

| SUB ITEM | EXAM CATEGORY | COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED | INSP. PER. | REQ'D AMT. | AMOUNT EXAM | ITEM IDENTIFICATION | INSPECTION REPORT NO. |
|----------|---------------|--|---------------------|--------------|--------------|--|--|
| | | UPPER RING GIRDER (WALL BOLTS) | ONE TWO THREE | 30 - - | 30 - - | PAD 1,2 | 88-012,014 |
| | | UPPER RING GIRDER (SNUBBER BOLTS) | ONE TWO THREE | - - 32 | - - - | | |
| | | UPPER RING GIRDER (CONNECTING BOLTS) | ONE TWO THREE | - 40 - | - 40 - | CONNECTIONS 1-4 CONNECTIONS 1-4 | 89-067,068,069,070 90-082,082R,083,083R 084,084R,085,085R |
| | | UPPER RING GIRDER (SPRING HANGERS) | ONE TWO THREE | - - 2 | - - - | | |
| | | COLUMN PINS | ONE TWO THREE | 2 4 2 | 5 4 - | COL 1 TOP COL 1-4 BOT COL 2 TOP & BOTT COL 3 TOP & BOTT | 88-063,051,044 88-058,056,049,061, 054,047 90-106,064,086, 405,367,361 90-105,371,362, 404,370,369 |
| | | BASE ANCHOR BOLTS | ONE TWO THREE | 16 8 8 | 16 8 - | COL 2,3 COL 4 | 85-056,057 89-226 |

P22SCS11

INSERVICE INSPECTION--EXAMINATION SUMMARY

MAJOR ITEM:

| SUB ITEM | EXAM CATEGORY | COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED | INSP. PER. | REQ'D AMT. | AMOUNT EXAM | ITEM IDENTIFICATION | INSPECTION REPORT NO. |
|----------|---------------|--|---------------------|--------------|--------------|------------------------------------|--|
| | | TOP COLUMN CONNECTING BOLTS | ONE TWO THREE | 4 8 4 | 4 8 - | COL 1 COL 4 COL 3 | 88-043 89-323 90-368 |
| | | SUPPORT PAD HELICOIL SCREWS | ONE TWO THREE | 6 6 12 | 6 6 - | COL 4 COL 1 | 88-200,010,011 89-327,338,322 |
| | | <u>STEAM GENERATOR NO 22</u> | | | | | |
| | | UPPER RING GIRDER (SNUBBER PINS) | ONE TWO THREE | - - 4 | - - - | | |
| | | UPPER RING GIRDER (SNUBBER WALL BOLTS) | ONE TWO THREE | 15 - - | 15 - - | PAD 1 | 86-185 |
| | | UPPER RING GIRDER (WALL BOLTS) | ONE TWO THREE | 30 - - | 30 - - | PAD 2,4,RING 1,2 | 86-184 |
| | | UPPER RING GIRDER (SNUBBER BOLTS) | ONE TWO THREE | - - 32 | - - - | | |
| | | UPPER RING GIRDER (CONNECTING BOLTS) | ONE TWO THREE | - 40 - | - 40 - | CONNECTIONS 1-4 CONNECTIONS 1-4 | 89-071,072,073,074 90-130,130R,129,129R, 128,128R,127,127R, 127R1 |

P22SCS11

INSERVICE INSPECTION—EXAMINATION SUMMARY

MAJOR ITEM:

| SUB ITEM | EXAM CATEGORY | COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED | INSP. PER. | REQ'D AMT. | AMOUNT EXAM | ITEM IDENTIFICATION | INSPECTION REPORT NO. |
|----------|---------------|--|-----------------------------|---------------------|---------------------|--|--|
| | | UPPER RING GIRDER (SPRING HANGERS) | ONE TWO THREE | - - 2 | - - - | | |
| | | COLUMN PINS | ONE TWO THREE | 2 2 4 | 5 2 - | COL 1 TOP COL 1-4 BOT COL 2 TOP & BOTT COL 3 TOP & BOTT | 88-064,050,041 88-062,055,048 90-107,065,087, 402,324,363 90-104,066,088, 401,325,364 |
| | | BASE ANCHOR BOLTS | ONE TWO THREE | 16 8 8 | 16 8 - | COL 2,3 COL 4 | 85-053,054 89-087/90-071 |
| | | TOP COLUMN CONNECTING BOLTS | ONE TWO THREE | 4 8 4 | 4 12 - | COL 1 COL 4 COL 2 & 3 | 88-042 89-227 90-327,326 |
| | | SUPPORT PAD HELICOIL SCREWS | ONE TWO THREE | 6 12 6 | 6 6 - | COL 4 COL 1 | 88-201,009,016 89-228,339,307 |

P225 S11

INSERVICE INSPECTION—EXAMINATION SUMMARY

MAJOR ITEM:

| SUB ITEM | EXAM CATEGORY | COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED | INSP. PER. | REQ'D AMT. | AMOUNT EXAM | ITEM IDENTIFICATION | INSPECTION REPORT NO. |
|----------|---------------|--|------------|------------|-------------|---------------------|--------------------------------|
| | | <u>PUMPS</u> | | | | | |
| | | <u>REACTOR CORE COOLANT NO 21</u> | | | | | |
| | | COLUMN PINS | ONE | 2 | 4 | COL 1 TOP | 88-059,053,046 |
| | | | TWO | 2 | 2 | COL 1-3 BOTTOM | 88-125,117,124 |
| | | | THREE | 2 | - | COL 2 TOP & BOTT | 90-092,067,089, 093,102,382 |
| | | BASE ANCHOR BOLTS | ONE | 8 | 8 | COL 3 | 85-058 |
| | | | TWO | 8 | 8 | COL 1 | 89-082/90-070 |
| | | | THREE | 8 | - | | |
| | | COLUMN CONNECTING BOLTS: | ONE | 4 | 4 | COL 1 | 88-205 |
| | | | TWO | 4 | 4 | COL 1 | 89-324 |
| | | | THREE | 4 | - | COL 3 | 90-391 |
| | | TIE BACK BOLTS | ONE | 1 | 1 | COL 1 | 88-025 |
| | | | TWO | 1 | 1 | COL 2 | 89-325 |
| | | | THREE | 1 | - | | |
| | | TIE BACK PINS | ONE | 1 | 1 | COL 3 | 88-198,202,207,207R |
| | | | TWO | 1 | 1 | COL 1 | 90-406,372,365 |
| | | | THREE | 1 | - | | |
| | | THROUGH ANCHOR BOLTS | ONE | - | - | | |
| | | | TWO | - | - | | |
| | | | THREE | 6 | - | | |

P22S S11

INSERVICE INSPECTION—EXAMINATION SUMMARY

MAJOR ITEM:

| SUB ITEM | EXAM CATEGORY | COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED | INSP. PER. | REQ'D AMT. | AMOUNT EXAM | ITEM IDENTIFICATION | INSPECTION REPORT NO. |
|----------|---------------|--|---------------------|-------------|-------------|--|--|
| | | LATERAL SUPPORT AND WALL BOLTS | ONE TWO THREE | 6 4 - | 6 4 - | COL 3 COL 3 | 88-013 89-326 |
| | | <u>REACTOR CORE COOLANT NO 22</u> | | | | | |
| | | COLUMN PINS | ONE TWO THREE | 2 2 2 | 4 2 - | COL 1 TOP COL 1-3 BOTTOM COL 2 TOP BOTTOM | 88-060,052,045 88-118,119,126 90-094,103,383 90-091,069,090 |
| | | BASE ANCHOR BOLTS | ONE TWO THREE | 8 8 8 | 8 8 - | COL 3 COL 1 | 85-055 90-068 |
| | | COLUMN CONNECTING BOLTS | ONE TWO THREE | 4 4 4 | 4 4 - | COL 1 COL 1, 3 | 88-206 89-122,123 |
| | | TIE BACK BOLTS | ONE TWO THREE | 1 1 1 | 1 1 - | COL 3 COL 2 | 85-039 89-124 |
| | | TIE BACK PINS | ONE TWO THREE | 1 1 1 | 2 1 - | COL 1 COL 3 COL 1 | 85-039 88-199,203,208,208R 90-403,373,366 |

P22SCS11

INSERVICE INSPECTION—EXAMINATION SUMMARY

MAJOR ITEM:

| SUB ITEM | EXAM CATEGORY | COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED | INSP. PER. | REQ'D AMT. | AMOUNT EXAM | ITEM IDENTIFICATION | INSPECTION REPORT NO. |
|----------|---------------|--|---------------------|-------------|-------------|------------------------|---------------------------------------|
| | | THROUGH ANCHOR BOLTS | ONE TWO THREE | - - 6 | 6 - - | COL 1 | 86-188 |
| | | LATERAL SUPPORT AND WALL BOLTS | ONE TWO THREE | 6 4 - | 6 - - | COL 3 | 86-187 |
| | | <u>PIPING</u> | | | | | |
| | | SEAL INJECTION LOOP A | ONE | 6 | 6 | N, P1/P1 G | 85-084,089/86-123 86-124 |
| | | | TWO | 6 | 6 | A1, B, E G, P1 | 88-027,029,031 88-030,028 |
| | | | THREE | 7 | - | C, H, J, P1 D, A, I | 89-347,084, ,63,064 90-163,162,146 |
| | | DRAIN LINE ON CROSSOVER LOOP A | ONE TWO THREE | - - 1 | - - - | | |
| | | RESIDUAL TEMPERATURE DETECTOR - TAKE OFF COLD LEG LOOP A | ONE TWO THREE | 1 1 2 | 1 1 - | A B1 | 88-018 90-164 |
| | | RESIDUAL TEMPERATURE DETECTOR - TAKE OFF HOT LEG LOOP A | ONE TWO THREE | 2 3 3 | 2 2 - | D, C G/F | 86-122,121 89-346/90-166 |

P225 S11

INSERVICE INSPECTION—EXAMINATION SUMMARY

MAJOR ITEM:

| SUB ITEM | EXAM CATEGORY | EQUIPMENT OR SYSTEM DESCRIPTION OF BE EXAMINED | INSP. PER. | REQ'D AMT. | AMOUNT EXAM | ITEM IDENTIFICATION | INSPECTION REPORT NO. |
|----------|---------------|--|------------|------------|-------------|-----------------------|---|
| | | PROTECTION | ONE | 1 | 1 | C | 85-082,082R/86-155 |
| | | HIGH P. LOOP A | TWO | 1 | 1 | B | 89-340 |
| | | | THREE | 2 | - | | |
| | | RESIDUAL TEMPERATURE DETECTOR - RETURN LOOP A | ONE | 1 | 1 | C | 88-017 |
| | | | TWO | 1 | 1 | C | 90-167 |
| | | | THREE | 1 | - | | |
| | | SPRAY TO PRESSURIZER BRANCH A | ONE | 6 | 7 | J,N,T D1,O,J | 85-085,085R,069,045 |
| | | | TWO | 7 | 7 | M K,H,L | 88-123 89-256,257,258 |
| | | | THREE | 7 | - | B,D,C,V | 90-168,170,169,189 |
| | | SPRAY TO PRESSURIZER BRANCH B | ONE | 3 | 3 | G | 85-046/86-172 |
| | | | TWO | 3 | 3 | F,H F1 | 86-174,173 89-158 |
| | | | THREE | 4 | - | E,D | 90-191,190 |
| | | RESIDUAL HEAT REMOVAL TAKE OFF LOOP A | ONE | 6 | 6 | O,Q,T Q | 85-033,034,032 86-225 |
| | | | TWO | 6 | 6 | K,P,S,Q D,C H,U | 88-021,023,022,024 89-362,363,363R, 250,291 |
| | | | THREE | 7 | - | D,C,B,E | 90-131,126,126R 124,125 |

P225511

INSERVICE INSPECTION—EXAMINATION SUMMARY

MAJOR ITEM:

| SUB ITEM | EXAM CATEGORY | COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED | INSP. PER. | REQ'D AMT. | AMOUNT EXAM | ITEM IDENTIFICATION | INSPECTION REPORT NO. |
|----------|---------------|--|------------|------------|-------------|--|---|
| | | ACCUMULATOR DISCHARGE LOOP A | ONE | 3 | 3 | H | 85-083 |
| | | | TWO | 3 | 3 | G, I E | 88-020, 019 89-225 |
| | | | THREE | 3 | - | F, D | 90-110, 109 |
| | | SEAL INJECTION LOOP B | ONE | 5 | 5 | O, P P | 85-090, 092, 092R 86-056 |
| | | | TWO | 5 | 5 | N, K Q, K K, L, M, D E, A | 86-055, 054, 054R 88-026, 120 89-308, 309, 310, 311 90-193, 192 |
| | | | THREE | 6 | - | | |
| | | CHARGING LINE CVCS | ONE | 9 | 9 | G, U, W, Z R, I, S, X Y | 85-040, 070, 087, 091, 091R 86-118, 119, 117, 115, 114 |
| | | | TWO | 9 | 9 | G, W, Z G, I, Y, Z I, A, K, M Q, V, Z N, O, T, E | 86-120, 120R, 116, 113 88-121, 131, 122, 130 89-259, 111, 348, 351 89-085, 086, 349 90-112, 111, 148, 147 |
| | | | THREE | 9 | - | | |
| | | RESIDUAL TEMPERATURE DETECTOR - TAKE OFF | ONE | 2 | 3 | A1/A1 | 85-044, 044R/86-075 |
| | | COLD LEG - LOOP B | TWO | 2 | 2 | A, B C | 86-074, 091, 091R 89-112 |
| | | | THREE | 3 | - | B | 90-194, 194R |

P22SCS11

INSERVICE INSPECTION - EXAMINATION SUMMARY

MAJOR ITEM:

| SUB ITEM | EXAM CATEGORY | COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED | INSP. PER. | REQ'D AMT. | AMOUNT EXAM | ITEM IDENTIFICATION | INSPECTION REPORT NO. |
|----------|---------------|--|------------|------------|-------------|---------------------|---------------------------------|
| | | RESIDUAL TEMPERATURE DETECTOR - TAKE OFF HOT LEG - LOOP B | ONE | 2 | 2 | A2, B | 88-145, 145R, 146 |
| | | | TWO | 2 | 2 | A, A2, B | 89-113, 114, 115 |
| | | | THREE | 2 | - | A1 | 90-195 |
| | | DRAIN LINE AND LETDOWN LINE | ONE | 2 | 2 | C | 85-041, 041R/86-226 |
| | | | TWO | 2 | 2 | E B | 88-148 |
| | | | THREE | 2 | - | E (BASELINE) A | 89-251 89-312 90-113 |
| | | RESIDUAL TEMPERATURE DETECTOR - RETURN LOOP B | ONE | - | - | | |
| | | | TWO | 1 | 1 | A | 90-196 |
| | | | THREE | - | - | | |
| | | RESIDUAL HEAT REMOVAL TAKE OFF - LOOP B | ONE | 6 | 6 | M, N H, E | 85-093, 094 86-013, 070 |
| | | | TWO | 6 | 6 | L, O A, B, D | 88-143, 142 89-116, 117, 118 |
| | | | THREE | 7 | - | C, K, KI | 90-245, 206, 207 |
| | | RESIDUAL HEAT REMOVAL RETURN - LOOP B | ONE | 1 | 1 | A | 86-069 |
| | | | TWO | 2 | 2 | E, B | 90-209, 208 |
| | | | THREE | 2 | - | | |
| | | ACCUMULATOR DISCHARGE LOOP B | ONE | 4 | 4 | A1, A1 | 85-079, 080 |
| | | | TWO | 5 | 5 | E, F G, B, B1 | 88-147, 144 89-359, 159, 160 |
| | | | THREE | 5 | - | A, B1 | 90-241, 205 |

P22S011

INSERVICE INSPECTION—EXAMINATION SUMMARY

MAJOR ITEM:

| SUB ITEM | EXAM CATEGORY | COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED | INSP. PER. | REQ'D AMT. | AMOUNT EXAM | ITEM IDENTIFICATION | INSPECTION REPORT NO. |
|----------|---------------|--|---------------------|-------------|-------------|------------------------------------|--|
| | | SAFETY INJECTION HIGH HEAD LOOP B | ONE TWO THREE | 1 1 1 | 1 1 - | C B | 86-156 90-210 |
| | | AUXILLIARY SPRAY CVCS | ONE TWO THREE | 1 2 2 | 1 2 - | A D B | 85-081 89-360 90-114 |
| | | REACTOR VESSEL SAFETY INJECTION LOOP A & B 2" | ONE TWO THREE | 1 1 - | 1 1 - | D A | 88-173 89-341, 341R |
| | | PRESSURIZER RELIEF LOOP B | ONE TWO THREE | - - 1 | - - - | | |
| | | REACTOR VESSEL SAFETY INJECTION LOOP A & B 4" & 6" | ONE TWO THREE | 2 3 4 | 2 4 - | A (REPEAT) D B A, B, A, A | 86-170, 170R/88-172 85-068 89-065 90-231, 151, 150, -11 |
| | | PRESSURIZER SAFETY | ONE TWO THREE | - 1 1 | 2 1 - | F, I AI | 85-043, 043R, 042, 042R 89-220 |

P22S-S11

MAJOR ITEM: _____

| SUB ITEM | EXAM CATEGORY | COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED | INSP. PER. | REQ'D AMT. | AMOUNT EXAM | ITEM IDENTIFICATION | INSPECTION REPORT NO. |
|----------|---------------|--|---------------------|-------------|-------------|--|--|
| | | PRESSURIZER SURGE | ONE TWO | 4 4 | 4 4 8 | I, F, K, J A, B, C, D AUGMENTED) K, J, H1 H, G, E, I F/F | 86-068, 067, 076, 077 89-134, 133, 132, 131 89-125, 126, 127 89-128, 129, 130, 119, 120/90-243 |
| | | | THREE | 4 | - | | |
| | | REACTOR CORE COOLANT LOOP A | ONE TWO THREE | 1 1 2 | 1 1 - | A1 A2 | 88-260 89-350 |
| | | REACTOR CORE COOLANT LOOP B | ONE TWO THREE | 1 1 2 | * 1 - | B1 | * SCHEDULED SUPPORT REMOVED 90-242 |

P22S511

NORTHERN STATES POWER COMPANY
PRAIRIE ISLAND UNIT II

TABLE S-II

Examination Comparison Summary

| SUB-ITEM | SYSTEM | CLASS | ISO | METH | ITEM | REPORT | PREVIOUS RESULTS | SCAN | CURRENT RESULTS | LIMITATIONS |
|----------|----------------------|-------|-----------|------|-----------------|--------|--|------|--|-------------------------|
| IWF | ACCUMULATOR DISCH A | I | 2-151-11 | VT-3 | S1RH-3/F | 90-110 | Results:NONE | | Results:NONE | NONE |
| IWF | ACCUMULATOR DISCH A | I | 2-151-11 | VT-3 | S1RH-4/D | 90-109 | Results:NONE | | Results:NONE | NONE |
| IWF | ACCUMULATOR DISCH B | I | 2-151-22 | VT-3 | RHRRH-23/A | 90-241 | Results:NONE | | Results:NONE | NONE |
| IWF | ACCUMULATOR DISCH B | I | 2-151-22 | VT-3 | RHRRH-36/B1 | 90-205 | Results:NONE | | Results:NONE | NONE |
| IWF | AUX SPRAY TO PZR | I | 2-151-24 | VT-3 | 114-2CVCS-1/B | 90-114 | Results:NONE | | Results:NONE | NONE |
| IWF | CHARGING LINE B | I | 2-151-13B | VT-3 | 109-2CVCS-1/N | 90-112 | Results:NONE | | Results:NONE | NONE |
| IWF | CHARGING LINE B | I | 2-151-13C | VT-3 | PRCVCH-1390/T | 90-148 | Results:NONE | | Results:NONE | NONE |
| IWF | CHARGING LINE B | I | 2-151-13B | VT-3 | PRCVCH-1395/O | 90-111 | Results:NONE | | Results:NONE | NONE |
| IWF | CHARGING LINE B | I | 2-151-13A | VT-3 | PRCVCH-1502/E | 90-147 | Results:NONE | | Results:NONE | NONE |
| IWF | DRAIN ON CROSSOVER B | I | 2-151-33 | VT-3 | B1 | 90-242 | Results:NONE | | Results:NONE | NONE |
| IWF | LETDOWN LINE B | I | 2-151-16 | VT-3 | 107-2CVCS-2/A | 90-113 | Results:NONE | | Results:NONE | NONE |
| IWF | PRESSURIZER | I | 2-151-36 | VT-3 | BOLTS 9-16 | 90-188 | Results:NONE | | Results:NONE | NONE |
| IWF | PRESSURIZER | I | 2-151-36 | VT-3 | W-6 | 90-187 | Results:NONE | | Results:NONE | NONE |
| IWF | PRESSURIZER SURGE | I | 2-151-31 | VT-3 | RCRH-50/F | 90-243 | Results:IND Type:BOTTOMED Ax Loc:OUT Circ Loc: Length: | | Results:IND Type:BOTTOMED Ax Loc: Circ Loc:OUT Length: | NONE, ENG. EVAL. ACCEPT |
| IWF | RCC PUMP 21 | I | 2-151-79 | VT-3 | COL 1 BASE | 90-070 | Results:NONE | | Results:NONE | NONE |
| IWF | RCC PUMP 21 | I | 2-151-84 | UT0 | COL 1 TIE PIN | 90-406 | Results:NONE | 1L | Results:NONE | NONE |
| IWF | RCC PUMP 21 | I | 2-151-84 | UT0 | COL 1 TIE PIN | 90-406 | Results:NONE | 2L | Results:NONE | NONE |
| IWF | RCC PUMP 21 | I | 2-151-84 | VT-3 | COL 1 TIE PIN | 90-372 | Results:NONE | | Results:NONE | NONE |
| IWF | RCC PUMP 21 | I | 2-151-84 | VT1 | COL 1 TIE PIN | 90-365 | Results:NONE | | Results:NONE | NONE |
| IWF | RCC PUMP 21 | I | 2-151-79 | UT0 | COL 2 PIN BOTT | 90-092 | Results:NONE | 1 | Results:NONE | NONE |
| IWF | RCC PUMP 21 | I | 2-151-79 | UT0 | COL 2 PIN BOTT | 90-092 | Results:NONE | 2 | Results:NONE | NONE |
| IWF | RCC PUMP 21 | I | 2-151-79 | VT-3 | COL 2 PIN BOTT | 90-067 | Results:NONE | | Results:NONE | NONE |
| IWF | RCC PUMP 21 | I | 2-151-79 | VT1 | COL 2 PIN BOTT | 90-089 | Results:NONE | | Results:NONE | NONE |
| IWF | RCC PUMP 21 | I | 2-151-80 | UT0 | COL 2 PIN TOP | 90-093 | Results:NONE | 1 | Results:NONE | NONE |
| IWF | RCC PUMP 21 | I | 2-151-80 | UT0 | COL 2 PIN TOP | 90-093 | Results:NONE | 2 | Results:NONE | NONE |
| IWF | RCC PUMP 21 | I | 2-151-80 | VT-3 | COL 2 PIN TOP | 90-102 | Results:NONE | | Results:NONE | NONE |
| IWF | RCC PUMP 21 | I | 2-151-80 | VT1 | COL 2 PIN TOP | 90-382 | Results:NONE | | Results:NONE | NONE |
| IWF | RCC PUMP 21 | I | 2-151-80 | VT-3 | COL 3 TOP CONN | 90-391 | Results:NONE | | Results:NONE | NONE |
| IWF | RCC PUMP 22 | I | 2-151-79 | VT-3 | COL 1 BASE ANCH | 90-068 | Results:NONE | | Results:NONE | NONE |
| IWF | RCC PUMP 22 | I | 2-151-81 | UT0 | COL 1 TIE BACK | 90-403 | Results:NONE | 1L | Results:NONE | NONE |
| IWF | RCC PUMP 22 | I | 2-151-81 | UT0 | COL 1 TIE BACK | 90-403 | Results:NONE | 2L | Results:NONE | NONE |

NORTHERN STATES POWER COMPANY
PRAIRIE ISLAND UNIT II

TABLE S-II

Examination Comparison Summary

| SUB-ITEM | SYSTEM | CLASS | ISO | METH | ITEM | REPORT | PREVIOUS RESULTS | SCAN | CURRENT RESULTS | LIMITATIONS |
|----------|---------------------|-------|-----------|------|----------------|---------|---|------|---|---------------------------|
| IWF | RCC PUMP 22 | I | 2-1S1-81 | VT-3 | COL 1 TIE BACK | 90-373 | Results:NONE | | Results:NONE | NONE |
| IWF | RCC PUMP 22 | I | 2-1S1-81 | VT1 | COL 1 TIE BACK | 90-366 | Results:NONE | | Results:NONE | NONE |
| IWF | RCC PUMP 22 | I | 2-1S1-79 | UT0 | COL 2 PIN BOTT | 90-091 | Results:NONE | 1 | Results:NONE | NONE |
| IWF | RCC PUMP 22 | I | 2-1S1-79 | UT0 | COL 2 PIN BOTT | 90-091 | Results:NONE | 2 | Results:NONE | NONE |
| IWF | RCC PUMP 22 | I | 2-1S1-79 | VT-3 | COL 2 PIN BOTT | 90-069 | Results:NONE | | Results:NONE | NONE |
| IWF | RCC PUMP 22 | I | 2-1S1-79 | VT1 | COL 2 PIN BOTT | 90-090 | Results:NONE | | Results:NONE | NONE |
| IWF | RCC PUMP 22 | I | 2-1S1-80 | UT0 | COL 2 PIN TOP | 90-094 | Results:NONE | 1 | Results:NONE | NONE |
| IWF | RCC PUMP 22 | I | 2-1S1-80 | UT0 | COL 2 PIN TOP | 90-094 | Results:NONE | 2 | Results:NONE | NONE |
| IWF | RCC PUMP 22 | I | 2-1S1-80 | VT-3 | COL 2 PIN TOP | 90-103 | Results:NONE | | Results:NONE | NONE |
| IWF | RCC PUMP 22 | I | 2-1S1-80 | VT1 | COL 2 PIN TOP | 90-383 | Results:NONE | | Results:NONE | NONE |
| IWF | RHR RETURN B | I | 2-1S1-21 | VT-3 | 10-2RHR-1/E | 90-209 | Results:NONE | | Results:NONE | NONE |
| IWF | RHR RETURN B | I | 2-1S1-21 | VT-3 | RHRRH-18/B | 90-208 | Results:NONE | | Results:NONE | NONE |
| IWF | RHR TAKE OFF HOT A | I | 2-1S1-10A | VT-3 | 9-2RHR-6/D | 90-131 | Results:IND Type:FLAME Ax Loc:CUT HOLES Circ Loc: Length: | | Results:NONE | NONE |
| IWF | RHR TAKE OFF HOT A | I | 2-1S1-10A | VT-3 | 9-2RHR-7/C | 90-126 | Results:IND Type:THREAD Ax Loc:ENGAGEMENT Circ Loc: Length: | | Results:IND Type:FLAME CUT Ax Loc: Circ Loc:HOLES Length: | NONE |
| IWF | RHR TAKE OFF HOT A | I | 2-1S1-10A | VT-3 | 9-2RHR-7/C | 90-126R | Results:N/A | | Results:NONE | NONE, REEXAM AFTER REPAIR |
| IWF | RHR TAKE OFF HOT A | I | 2-1S1-10A | VT-3 | 9-2RHR-8/B | 90-124 | Results:NONE | | Results:NONE | NONE |
| IWF | RHR TAKE OFF HOT A | I | 2-1S1-10A | VT-3 | RHRRH-1/E | 90-125 | Results:NONE | | Results:NONE | NONE |
| IWF | RHR TAKE OFF HOT B | I | 2-1S1-20B | VT-3 | 9-2RHR-14R/K | 90-206 | Results:NONE | | Results:NONE | NONE |
| IWF | RHR TAKE OFF HOT B | I | 2-1S1-20A | VT-3 | 9-2RHR-15A/C | 90-245 | Results:NONE | | Results:NONE | NONE |
| IWF | RHR TAKE OFF HOT B | I | 2-1S1-20B | VT-3 | RHRRH-13/K1 | 90-207 | Results:N/A | | Results:NONE | NONE |
| IWF | RTD RETURN A | I | 2-1S1-6 | VT-3 | 135-2RTD-48/C | 90-167 | Results:NONE | | Results:NONE | NONE |
| IWF | RTD RETURN B | I | 2-1S1-17 | VT-3 | 137-2RTD-48/A | 90-196 | Results:NONE | | Results:NONE | NONE |
| IWF | RTD TAKE OFF COLD A | I | 2-1S1-3 | VT-3 | PRRCH-281/B1 | 90-164 | Results:IND Type:SKewed Ax Loc: Circ Loc: Length: | | Results:NONE | NONE |

NORTHERN STATES POWER COMPANY
PRAIRIE ISLAND UNIT II

TABLE S-II

Examination Comparison Summary

| SUB-ITEM | SYSTEM | CLASS | ISO | METH | ITEM | REPORT | PREVIOUS RESULTS | SCAN | CURRENT RESULTS | LIMITATIONS |
|----------|---------------------|-------|-----------|------|----------------|---------|--|------|--|---------------------------|
| IWF | RTD TAKE OFF COLD B | I | 2-ISI-14 | VT-3 | 137-2RTD-2/B | 90-194 | Results:IND Type:LOOSE Ax Loc:NUTS Circ Loc: Length: | | Results:IND Type:LOOSE NUT Ax Loc: Circ Loc: Length: | NONE |
| IWF | RTD TAKE OFF COLD B | I | 2-ISI-14 | VT-3 | 137-2RTD-2/B | 90-194R | Results:N/A | | Results:NONE | NONE, REEXAM AFTER REPAIR |
| IWF | RTD TAKE OFF HOT A | I | 2-ISI-4 | VT-3 | PRRCH-279/F | 90-166 | Results:NONE | | Results:NONE | NONE |
| IWF | RTD TAKE OFF HOT B | I | 2-ISI-15 | VT-3 | 137-2RTD-6/A1 | 90-195 | Results:IND Type:LOOSE Ax Loc:NUTS Circ Loc: Length: | | Results:NONE | NONE |
| IWF | RX SAFETY INJ'N A | I | 2-ISI-25 | VT-3 | PRSIH-266/A | 90-231 | Results:IND Type:LOAD MARKS Ax Loc:OFF Circ Loc: Length: | | Results:NONE | NONE, ENG. EVAL. ACCEPT |
| IWF | RX SAFETY INJ'N A | I | 2-ISI-29 | VT-3 | RHRRH-32/B | 90-151 | Results:NONE | | Results:NONE | NONE |
| IWF | RX SAFETY INJ'N A | I | 2-ISI-29 | VT-3 | RHRRH-33/A | 90-150 | Results:NONE | | Results:NONE | NONE |
| IWF | RX SAFETY INJ'N B | I | 2-ISI-26 | VT-3 | PRSIH-345/A | 90-211 | Results:NONE | | Results:NONE | NONE |
| IWF | SEAL INJECTION A | I | 2-ISI-1B | VT-3 | PRCVCH-1520/I | 90-146 | Results:NONE | | Results:NONE | NONE |
| IWF | SEAL INJECTION A | I | 2-ISI-1A | VT-3 | PRCVCH-1524/D | 90-163 | Results:NONE | | Results:NONE | NONE |
| IWF | SEAL INJECTION A | I | 2-ISI-1A | VT-3 | PRCVCH-1526/A | 90-162 | Results:NONE | | Results:NONE | NONE |
| IWF | SEAL INJECTION B | I | 2-ISI-12B | VT-3 | PRCVCH-1381/E | 90-193 | Results:NONE | | Results:NONE | NONE |
| IWF | SEAL INJECTION B | I | 2-ISI-12C | VT-3 | RCVCH-1575/A | 90-192 | Results:NONE | | Results:NONE | NONE |
| IWF | SI HIGH HEAD B | I | 2-ISI-23 | VT-3 | PRSIH-205/B | 90-210 | Results:NONE | | Results:NONE | NONE |
| IWF | SPRAY TO PZR BR A | I | 2-ISI-7A | VT-3 | 113-2RC-1/B | 90-168 | Results:NONE | | Results:NONE | NONE |
| IWF | SPRAY TO PZR BR A | I | 2-ISI-7A | VT-3 | 113-2RC-2/D | 90-170 | Results:NONE | | Results:NONE | NONE |
| IWF | SPRAY TO PZR BR A | I | 2-ISI-7A | VT-3 | 113-2RC-4/C | 90-169 | Results:NONE | | Results:NONE | NONE |
| IWF | SPRAY TO PZR BR A | I | 2-ISI-7C | VT-3 | RCRH-5/V | 90-189 | Results:NONE | | Results:NONE | NONE |
| IWF | SPRAY TO PZR BR B | I | 2-ISI-7D | VT-3 | 111-2RC-2B/E | 90-191 | Results:NONE | | Results:NONE | NONE |
| IWF | SPRAY TO PZR BR B | I | 2-ISI-7D | VT-3 | RCRH-1/D | 90-190 | Results:NONE | | Results:NONE | NONE |
| IWF | STEAM GENERATOR 21 | I | 2-ISI-77 | UTO | COL 2 PIN BOTT | 90-106 | Results:NONE | 1 | Results:IND Scan: 1 Type:LINEAR Amplitude:70 Ax Loc:2.34 Circ Loc:2:00 Length:1.0" | NONE, ENG. EVAL. ACCEPT |

NORTHERN STATES POWER COMPANY
PRAIRIE ISLAND UNIT II

TABLE S-II

Examination Comparison Summary

| SUB-ITEM | SYSTEM | CLASS | ISO | METH | ITEM | REPORT | PREVIOUS RESULTS | SCAN | CURRENT RESULTS | LIMITATIONS |
|----------|--------------------|-------|----------|------|----------------|---------|------------------|------|-----------------|-------------------------------|
| IWF | STEAM GENERATOR 21 | 1 | 2-1S1-77 | UT0 | COL 2 PIN BOTT | 90-106 | Results:NONE | 2 | Results:NONE | NONE |
| IWF | STEAM GENERATOR 21 | 1 | 2-1S1-77 | VT-3 | COL 2 PIN BOTT | 90-064 | Results:NONE | | Results:NONE | NONE |
| IWF | STEAM GENERATOR 21 | 1 | 2-1S1-77 | VT1 | COL 2 PIN BOTT | 90-086 | Results:NONE | | Results:NONE | NONE |
| IWF | STEAM GENERATOR 21 | 1 | 2-1S1-78 | UT0 | COL 2 PIN TOP | 90-405 | Results:NONE | 1L | Results:NONE | NONE |
| IWF | STEAM GENERATOR 21 | 1 | 2-1S1-78 | UT0 | COL 2 PIN TOP | 90-405 | Results:NONE | 2L | Results:NONE | NONE |
| IWF | STEAM GENERATOR 21 | 1 | 2-1S1-78 | VT-3 | COL 2 PIN TOP | 90-367 | Results:NONE | | Results:NONE | NONE |
| IWF | STEAM GENERATOR 21 | 1 | 2-1S1-78 | VT1 | COL 2 PIN TOP | 90-361 | Results:NONE | | Results:NONE | NONE |
| IWF | STEAM GENERATOR 21 | 1 | 2-1S1-78 | VT-3 | COL 3 COL CONN | 90-368 | Results:NONE | | Results:NONE | NONE |
| IWF | STEAM GENERATOR 21 | 1 | 2-1S1-77 | UT0 | COL 3 PIN BOTT | 90-105 | Results:NONE | 1 | Results:NONE | NONE |
| IWF | STEAM GENERATOR 21 | 1 | 2-1S1-77 | UT0 | COL 3 PIN BOTT | 90-105 | Results:NONE | 2 | Results:NONE | NONE |
| IWF | STEAM GENERATOR 21 | 1 | 2-1S1-77 | VT-3 | COL 3 PIN BOTT | 90-371 | Results:NONE | | Results:NONE | NONE |
| IWF | STEAM GENERATOR 21 | 1 | 2-1S1-77 | VT1 | COL 3 PIN BOTT | 90-362 | Results:NONE | | Results:NONE | NONE |
| IWF | STEAM GENERATOR 21 | 1 | 2-1S1-78 | UT0 | COL 3 PIN TOP | 90-404 | Results:NONE | 1L | Results:NONE | NONE |
| IWF | STEAM GENERATOR 21 | 1 | 2-1S1-78 | UT0 | COL 3 PIN TOP | 90-404 | Results:NONE | 2L | Results:NONE | NONE |
| IWF | STEAM GENERATOR 21 | 1 | 2-1S1-78 | VT-3 | COL 3 PIN TOP | 90-370 | Results:NONE | | Results:NONE | NONE |
| IWF | STEAM GENERATOR 21 | 1 | 2-1S1-78 | VT1 | COL 3 PIN TOP | 90-369 | Results:NONE | | Results:NONE | NONE |
| IWF | STEAM GENERATOR 21 | 1 | 2-1S1-85 | VT-3 | PAD 1 UPP RING | 90-082 | Results:NONE | | Results:NONE | NONE |
| IWF | STEAM GENERATOR 21 | 1 | 2-1S1-85 | VT-3 | PAD 1 UPP RING | 90-082R | Results:N/A | | Results:NONE | NONE, REEXAM AFTER TIGHTENING |
| IWF | STEAM GENERATOR 21 | 1 | 2-1S1-85 | VT-3 | PAD 2 UPP RING | 90-083 | Results:NONE | | Results:NONE | NONE |
| IWF | STEAM GENERATOR 21 | 1 | 2-1S1-85 | VT-3 | PAD 2 UPP RING | 90-083R | Results:N/A | | Results:NONE | NONE, REEXAM AFTER TIGHTENING |
| IWF | STEAM GENERATOR 21 | 1 | 2-1S1-85 | VT-3 | PAD 3 UPP RING | 90-084 | Results:NONE | | Results:NONE | NONE |
| IWF | STEAM GENERATOR 21 | 1 | 2-1S1-85 | VT-3 | PAD 3 UPP RING | 90-084R | Results:N/A | | Results:NONE | NONE, REEXAM AFTER TIGHTENING |
| IWF | STEAM GENERATOR 21 | 1 | 2-1S1-85 | VT-3 | PAD 4 UPP RING | 90-085 | Results:NONE | | Results:NONE | NONE |
| IWF | STEAM GENERATOR 21 | 1 | 2-1S1-85 | VT-3 | PAD 4 UPP RING | 90-085R | Results:N/A | | Results:NONE | NONE, REEXAM AFTER TIGHTENING |
| IWF | STEAM GENERATOR 22 | 1 | 2-1S1-77 | UT0 | COL 2 PIN BOTT | 90-107 | Results:NONE | 1 | Results:NONE | NONE |
| IWF | STEAM GENERATOR 22 | 1 | 2-1S1-77 | UT0 | COL 2 PIN BOTT | 90-107 | Results:NONE | 2 | Results:NONE | NONE |
| IWF | STEAM GENERATOR 22 | 1 | 2-1S1-77 | VT-3 | COL 2 PIN BOTT | 90-065 | Results:NONE | | Results:NONE | NONE |
| IWF | STEAM GENERATOR 22 | 1 | 2-1S1-77 | VT1 | COL 2 PIN BOTT | 90-087 | Results:NONE | | Results:NONE | NONE |
| IWF | STEAM GENERATOR 22 | 1 | 2-1S1-78 | UT0 | COL 2 PIN TOP | 90-402 | Results:NONE | 1L | Results:NONE | NONE, ENG. EVAL. ACCEPT |
| IWF | STEAM GENERATOR 22 | 1 | 2-1S1-78 | UT0 | COL 2 PIN TOP | 90-402 | Results:NONE | 2L | Results:IND | NONE |
| | | | | | | | | | Scan: 2L | |
| | | | | | | | | | Type:SPOT | |
| | | | | | | | | | Amplitude:20 | |
| | | | | | | | | | Ax Loc:N/A | |
| | | | | | | | | | Circ Loc:0° | |
| | | | | | | | | | Length:SPOT | |

NORTHERN STATES POWER COMPANY
PRAIRIE ISLAND UNIT II

TABLE S-II

Examination Comparison Summary

| SUB-ITEM | SYSTEM | CLASS | ISO | METH | ITEM | REPORT | PREVIOUS RESULTS | SCAN | CURRENT RESULTS | LIMITATIONS |
|----------|--------------------|-------|----------|------|----------------|---------|------------------|------|--|-------------------------------|
| IWF | STEAM GENERATOR 22 | 1 | 2-1S1-78 | VT-3 | COL 2 PIN TOP | 90-324 | Results:NONE | | Results:NONE | NONE |
| IWF | STEAM GENERATOR 22 | 1 | 2-1S1-78 | VT1 | COL 2 PIN TOP | 90-363 | Results:NONE | | Results:NONE | NONE |
| IWF | STEAM GENERATOR 22 | 1 | 2-1S1-78 | VT-3 | COL 2 TOP CONN | 90-326 | Results:NONE | | Results:NONE | NONE |
| IWF | STEAM GENERATOR 22 | 1 | 2-1S1-77 | UT0 | COL 3 PIN BOTT | 90-104 | Results:NONE | 1 | Results:IND Scan: 1 Type:LINEAR Amplitude:30 Ax Loc:2.40 Circ Loc:7:00 Length:1.0" | NONE, ENG. EVAL. ACCEPT |
| IWF | STEAM GENERATOR 22 | 1 | 2-1S1-77 | UT0 | COL 3 PIN BOTT | 90-104 | Results:NONE | 2 | Results:IND Scan: 2 Type:LINEAR Amplitude:30 Ax Loc:2.40 Circ Loc:5:00 Length:1.0" | NONE, ENG. EVAL. ACCEPT |
| IWF | STEAM GENERATOR 22 | 1 | 2-1S1-77 | VT-3 | COL 3 PIN BOTT | 90-066 | Results:NONE | | Results:NONE | NONE |
| IWF | STEAM GENERATOR 22 | 1 | 2-1S1-77 | VT1 | COL 3 PIN BOTT | 90-088 | Results:NONE | | Results:NONE | NONE |
| IWF | STEAM GENERATOR 22 | 1 | 2-1S1-78 | UT0 | COL 3 PIN TOP | 90-401 | Results:NONE | 1L | Results:NONE | NONE |
| IWF | STEAM GENERATOR 22 | 1 | 2-1S1-78 | UT0 | COL 3 PIN TOP | 90-401 | Results:NONE | 2L | Results:NONE | NONE |
| IWF | STEAM GENERATOR 22 | 1 | 2-1S1-78 | VT-3 | COL 3 PIN TOP | 90-325 | Results:NONE | | Results:NONE | NONE |
| IWF | STEAM GENERATOR 22 | 1 | 2-1S1-78 | VT1 | COL 3 PIN TOP | 90-364 | Results:NONE | | Results:NONE | NONE |
| IWF | STEAM GENERATOR 22 | 1 | 2-1S1-78 | VT-3 | COL 3 TOP CONN | 90-327 | Results:NONE | | Results:NONE | NONE |
| IWF | STEAM GENERATOR 22 | 1 | 2-1S1-77 | VT-3 | COL 4 BASE | 90-071 | Results:NONE | | Results:NONE | NONE |
| IWF | STEAM GENERATOR 22 | 1 | 2-1S1-85 | VT-3 | PAD 1 UPP RING | 90-130 | Results:NONE | | Results:NONE | NONE |
| IWF | STEAM GENERATOR 22 | 1 | 2-1S1-85 | VT-3 | PAD 1 UPP RING | 90-130R | Results:N/A | | Results:NONE | NONE, REEXAM AFTER TIGHTENING |
| IWF | STEAM GENERATOR 22 | 1 | 2-1S1-85 | VT-3 | PAD 2 UPP RING | 90-129 | Results:NONE | | Results:NONE | NONE |
| IWF | STEAM GENERATOR 22 | 1 | 2-1S1-85 | VT-3 | PAD 2 UPP RING | 90-129R | Results:N/A | | Results:NONE | NONE, REEXAM AFTER TIGHTENING |
| IWF | STEAM GENERATOR 22 | 1 | 2-1S1-85 | VT-3 | PAD 3 UPP RING | 90-128 | Results:NONE | | Results:NONE | NONE |
| IWF | STEAM GENERATOR 22 | 1 | 2-1S1-85 | VT-3 | PAD 3 UPP RING | 90-128R | Results:N/A | | Results:NONE | NONE, REEXAM AFTER TIGHTENING |
| IWF | STEAM GENERATOR 22 | 1 | 2-1S1-85 | VT-3 | PAD 4 UPP RING | 90-127 | Results:NONE | | Results:NONE | NONE |
| IWF | STEAM GENERATOR 22 | 1 | 2-1S1-85 | VT-3 | PAD 4 UPP RING | 90-127R | Results:N/A | | Results:IND Type:LOOSE NUT Ax Loc: Circ Loc: Length: | NONE, REEXAM AFTER TIGHTENING |

NORTHERN STATES POWER COMPANY
 PRAIRIE ISLAND UNIT II

TABLE S-II

Examination Comparison Summary

| SUB-ITEM | SYSTEM | CLASS | ISO | METH | ITEM | REPORT | PREVIOUS RESULTS | SCAN | CURRENT RESULTS | LIMITATIONS |
|----------|--------------------|-------|----------|------|----------------|----------|------------------|------|-----------------|-------------------------------|
| 1WF | STEAM GENERATOR 22 | 1 | 2-151-85 | VT-3 | PAD 4 UPP RING | 90-127R1 | Results:N/A | | Results:NONE | NONE, REEXAM AFTER TIGHTENING |

INSERVICE INSPECTION—EXAMINATION SUMMARY

MAJOR ITEM:

| SUB ITEM | EXAM CATEGORY | COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED | INSP. PER. | REQ'D AMT. | AMOUNT EXAM | ITEM IDENTIFICATION | INSPECTION REPORT NO. |
|----------|---------------|--|------------|------------|-------------|---------------------|-----------------------------|
| | | MAIN STEAM B | ONE | 1 | 1 | P | 86-053 |
| | | RELIEF HEADER | TWO | 1 | 1 | O | 89-355 |
| | | 30-2MS-2 | THREE | 1 | - | | |
| | | 6-2MS-2 | | | | | |
| | | FEEDWATER A | ONE | 4 | 4 | A,D,A | 85-088,116,117 |
| | | 16-2FW-13 | | | | A | 86-034,057,058,065 |
| | | 13-2FW-12 | | | | H,A | 88-080,084,068 |
| | | 16-2FW-11 | TWO | 4 | 4 | L,E,F | 89-155,156,157 |
| | | | THREE | 5 | - | B,F | 90-078,080,079 |
| | | FEEDWATER B | ONE | 2 | 2 | A | 86-037 |
| | | 16-2FW-16 | TWO | 3 | * | B | 88-185 |
| | | | THREE | 3 | * | | * RELIEF NO. 50 |
| | | RHR PUMP SUCTION B | ONE | 6 | 6 | B,N | 85-095,110 |
| | | 10-2RH-3 | | | | J,L | 86-201,200 |
| | | 8-2RH-4B | TWO | 6 | 7 | P,A | 88-004,195 |
| | | | | | | F,G,H,P | 89-050,025,026, 026R,006 |
| | | 12-2RH-5B | THREE | 6 | - | C,I,O,F | 90-161,002,003,025 |
| | | | | | | H | 90-024 |
| | | RHR PUMP SUCTION A | ONE | 2 | 2 | F | 85-113 |
| | | 8-2RH-4A | TWO | 2 | 3 | C | 88-003 |
| | | 12-2RH-5A | THREE | 3 | - | E,G | 89-001,002 |
| | | | | | | D | 90-004 |

P225-S12

MAJOR ITEM:

| SUB ITEM | EXAM CATEGORY | COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED | INSP. PER. | REQ'D AMT. | AMOUNT EXAM | ITEM IDENTIFICATION | INSPECTION REPORT NO. |
|----------|---------------|---|------------|------------|-------------|---------------------|--|
| | | RHR PUMP DISCHARGE B 8-2RH-7B 8-2RH-9B 6-2RH-10B | ONE | 4 | 4 | D | 85-115 |
| | | | TWO | 4 | 4 | I C,H,D | 86-197 |
| | | | THREE | 5 | - | J,E A,F | 88-001,281,002 89-027,003 90-005,006 |
| | | RHR PUMP DISCHARGE A 8-2RH-7A 8-2RH-9A 10-2RH-11 6-2RH-12 | ONE | 4 | 4 | F,A A,H | 85-111,112 86-007,198 |
| | | | TWO | 4 | 3 | L | 88-174 |
| | | | THREE | 5 | - | L,G E,J,L,G | 89-249,028 90-007,011,171,010 |
| | | CONTAINMENT SUMP B DISCHARGE 12-2RH-6B 14-2SI-33B | ONE | - | 1 | D | RELIEF NO. 50 |
| | | | TWO | 1 | 1 | D | 86-135 |
| | | | THREE | 1 | - | | 90-014 |
| | | CONTAINMENT SUMP A DISCHARGE 12-2RH-6A 14-2SI-33A | ONE | 1 | 1 | D | RELIEF NO. 50 |
| | | | TWO | - | - | | 85-114,114R |
| | | | THREE | 1 | - | | |
| | | SAFETY INJECTION PUMP SUCTION 6-2SI-13A 6-2SI-13B | ONE | - | - | | |
| | | | TWO | 1 | 1 | D | 90-026 |
| | | | THREE | 1 | - | | |

P2250512

INSERVICE INSPECTION—EXAMINATION SUMMARY

MAJOR ITEM:

| SUB ITEM | EXAM CATEGORY | COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED | INSP. PER. | REQ'D AMT. | AMOUNT EXAM | ITEM IDENTIFICATION | INSPECTION REPORT NO. |
|----------|---------------|--|---------------------|-------------|-------------|------------------------------------|--|
| | | BORIC ACID SUPPLY TO SAFETY INJECTION 12-2SI-11 8-2SI-18 | ONE TWO THREE | 5 5 6 | 5 5 - | B,D,F,H,A A,B G,H,J,K E,I | 88-282,282R,277,278, 279,228,228R 89-019,020,020R, 89-032,033,034,035 90-012,015 |
| | | SAFETY INJECTION PUMP SUCTION B 6-2RH-10B | ONE TWO THREE | 1 2 2 | 1 2 - | C B B,A | 88-227 89-012 90-027,016 |
| | | SAFETY INJECTION PUMP SUCTION A 6-2RH-10A | ONE TWO THREE | 2 2 3 | 2 2 - | A,E B,G | 88-276,298 89-029,011 |
| | | REFUELING WATER STORAGE TANK DISCHARGE 14-2SI-1 12-2SI-4 10-2SI-8 | ONE TWO THREE | 1 1 2 | 1 1 - | A/A B | 85-147/86-125 90-017 |
| | | REACTOR VESSEL SAFETY INJECTION B 6-2SI-25B | ONE TWO THREE | 1 1 1 | 1 1 - | A/A C | 86-062/88-191 89-058 |

P22512

INSERVICE INSPECTION—EXAMINATION SUMMARY

MAJOR ITEM:

| SUB ITEM | EXAM CATEGORY | COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED | INSP. PER. | REQ'D AMT. | AMOUNT EXAM | ITEM IDENTIFICATION | INSPECTION REPORT NO. |
|----------|---------------|---|------------|------------|-------------|-----------------------------------|--------------------------------------|
| | | REACTOR VESSEL SAFETY INJECTION A 6-2SI-25A | ONE | 2 | 2 | E/E | 86-061/88-190 |
| | | | TWO | 3 | 3 | H | 88-192,192R |
| | | | THREE | 3 | - | H, F, D C, F, H | 89-031, 052, 053 90-172, 174, 173 |
| | | ACCUMULATOR DISCHARGE 12-2SI-28A 12-2SI-29A 12-2SI-28B | ONE | 1 | 1 | A | 85-101 |
| | | | TWO | 1 | 1 | B | 90-197 |
| | | | THREE | 1 | - | | |
| | | <u>PUMPS</u> | | | | | |
| | | RESIDUAL HEAT REMOVAL PUMP NO. 21 | ONE | 1 | 1 | P | 88-004 |
| | | PUMP NO. 22 | TWO | 1 | 1 | G | 90-001 |
| | | | THREE | 2 | - | | |
| | | SAFETY INJECTION PUMP NO. 21 | ONE | 4 | 4 | HOLDING LUG E, F | 86-011, 012 |
| | | PUMP NO. 22 | TWO | 4 | 4 | SUPPORT C, D | 88-274, 267, 275, 268 |
| | | | THREE | 4 | - | SUPPORT C, D (VT) SUPPORT C, D | 89-030, 031 90-008, 009 |
| | | <u>VESSELS</u> | | | | | |
| | | BORIC ACID TANK NO. 21 | ONE | 1 | 1 | SUPPORT LEG A | 88-194 |
| | | | TWO | 1 | 1 | SUPPORT LEG B | 90-038 |
| | | | THREE | 2 | - | | |

P22SCS12

MAJOR ITEM:

| SUB ITEM | EXAM CATEGORY | COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED | INSP. PER. | REQ'D AMT. | AMOUNT EXAM | ITEM IDENTIFICATION | INSPECTION REPORT NO. |
|----------|---------------|--|---------------------|-------------|-------------|------------------------|-----------------------|
| | | ACCUMULATOR TANKS NO. 21 NO. 22 | ONE TWO THREE | - 1 1 | - 1 - | SUPPORT SKIRT | 90-198,199 |
| | | HEAT EXCHANGERS | | | | | |
| | | RHR HEAT EXCHANGERS NO. 21 NO. 22 | ONE TWO THREE | 1 1 2 | 1 1 - | SUPPORT A SUPPORT A | 86-008 90-013 |

P225(S12

NORTHERN STATES POWER COMPANY
PRAIRIE ISLAND UNIT II

TABLE S-II

Examination Comparison Summary

| SUB-ITEM | SYSTEM | CLASS | ISO | METH | ITEM | REPORT | PREVIOUS RESULTS | SCAN | CURRENT RESULTS | LIMITATIONS |
|----------|----------------------|-------|-----------|------|---------------|--------|-------------------|------|-----------------|-------------|
| IWF | ACCUMULATOR DISCH A | II | 2-1S1-75 | VT-3 | SIRH-1/B | 90-197 | Results:NONE | | Results:NONE | NONE |
| IWF | ACCUMULATOR TANK 21 | II | 2-1S1-76 | VT-3 | SKIRT BOLTING | 90-198 | Results:N/A | | Results:NONE | NONE |
| IWF | ACCUMULATOR TANK 21 | II | 2-1S1-76 | VT-3 | SUPPORT SKIRT | 90-199 | Results:N/A | | Results:NONE | NONE |
| IWF | BORIC ACID TANK 22 | II | 2-1S1-68 | VT-3 | SUPPORT LEG B | 90-038 | Results:N/A | | Results:NONE | NONE |
| IWF | BORIC ACID TO SI | II | 2-1S1-61 | VT-3 | 2-SIH-112/I | 90-015 | Results:N/A | | Results:NONE | NONE |
| IWF | BORIC ACID TO SI | II | 2-1S1-61 | VT-3 | 2-SIH-116/E | 90-012 | Results:N/A | | Results:NONE | NONE |
| IWF | CONTAMT SUMP B DISCH | II | 2-1S1-58 | VI-3 | RHRH-3/D | 90-014 | Results:N/A | | Results:NONE | NONE |
| IWF | FEEDWATER A | II | 2-1S1-48A | VT-3 | 2-FW-4A/F | 90-080 | Results:IND | | Results:NONE | NONE |
| | | | | | | | Type:DRAWING | | | |
| | | | | | | | Ax Loc:COMPLIANCE | | | |
| | | | | | | | Circ Loc: | | | |
| | | | | | | | Length: | | | |
| IWF | FEEDWATER A | II | 2-1S1-48A | VT-3 | FWH-68/B | 90-078 | Results:N/A | | Results:NONE | NONE |
| IWF | FEEDWATER A | II | 2-1S1-48A | VT-3 | FWH-70/F | 90-079 | Results:NONE | | Results:NONE | NONE |
| IWF | MAIN STEAM A | II | 2-1S1-46B | VT-3 | MSH-32/M | 90-137 | Results:NONE | | Results:NONE | NONE |
| IWF | MAIN STEAM A | II | 2-1S1-46A | VT-3 | MSH-34/K | 90-076 | Results:N/A | | Results:NONE | NONE |
| IWF | MAIN STEAM A | II | 2-1S1-46B | VT-3 | MSH-81/Q | 90-140 | Results:IND | | Results:NONE | NONE |
| | | | | | | | Type:FLUID | | | |
| | | | | | | | Ax Loc:LEVEL | | | |
| | | | | | | | Circ Loc: | | | |
| | | | | | | | Length: | | | |
| IWF | MAIN STEAM A | II | 2-1S1-46B | VT-3 | RES'T 4A/O | 90-138 | Results:N/A | | Results:NONE | NONE |
| IWF | MAIN STEAM A | II | 2-1S1-46B | VT-3 | RES'T 7A/O | 90-139 | Results:N/A | | Results:NONE | NONE |
| IWF | MAIN STEAM B | II | 2-1S1-47B | VT-3 | MSH-1S/L | 90-141 | Results:IND | | Results:NONE | NONE |
| | | | | | | | Type:DRAWING | | | |
| | | | | | | | Ax Loc:COMPLIANCE | | | |
| | | | | | | | Circ Loc: | | | |
| | | | | | | | Length: | | | |
| IWF | MAIN STEAM B | II | 2-1S1-47A | VT-3 | MSH-37/I | 90-081 | Results:IND | | Results:NONE | NONE |
| | | | | | | | Type:BASE PLATE | | | |
| | | | | | | | Ax Loc:3/8" FROM | | | |
| | | | | | | | Circ Loc:WALL | | | |
| | | | | | | | Length: | | | |
| IWF | MAIN STEAM B | II | 2-1S1-47A | VT-3 | MSH-41/H | 90-077 | Results:NONE | | Results:NONE | NONE |
| IWF | MAIN STEAM B | II | 2-1S1-47A | VT-3 | MSH-46/C | 90-095 | Results:N/A | | Results:NONE | NONE |

NORTHERN STATES POWER COMPANY
PRAIRIE ISLAND UNIT II

TABLE S-II

Examination Comparison Summary

| SUB ITEM | SYSTEM | CLASS | ISO | METH | ITEM | REPORT | PREVIOUS RESULTS | SCAN | CURRENT RESULTS | LIMITATIONS |
|----------|--------------------|-------|-----------|------|-----------|---------|---|------|--|---------------------------|
| IWF | MAIN STEAM B | II | 2-1S1-47A | VT-3 | MSH-50/A1 | 90-061 | Results:N/A | | Results:IND Type:LOOSE NUT Ax Loc: Circ Loc: Length: | NONE |
| IWF | MAIN STEAM B | II | 2-1S1-47A | VT-3 | MSH-50/A1 | 90-061R | Results:N/A | | Results:NONE | NONE, REEXAM AFTER REPAIR |
| IWF | RHR HEAT EXCH 21 | II | 2-1S1-69 | VT-3 | SUPPORT A | 90-013 | Results:NONE | | Results:NONE | NONE |
| IWF | RHR PUMP 21 | II | 2-1S1-53 | VT-3 | BASE/G | 90-001 | Results:N/A | | Results:NONE | NONE |
| IWF | RHR PUMP DISCH A | II | 2-1S1-57 | VT-3 | RHRH-24/J | 90-011 | Results:N/A | | Results:NONE | NONE |
| IWF | RHR PUMP DISCH A | II | 2-1S1-57 | VT-3 | RHRH-25/G | 90-010 | Results:IND Type:LOOSE Ax Loc:CLAMP Circ Loc: Length: | | Results:NONE | NONE |
| IWF | RHR PUMP DISCH A | II | 2-1S1-57 | VT-3 | RHRH-31/E | 90-007 | Results:N/A | | Results:NONE | NONE |
| IWF | RHR PUMP DISCH A | II | 2-1S1-57 | VT-3 | RHRH-57/L | 90-171 | Results:NONE | | Results:NONE | NONE |
| IWF | RHR PUMP DISCH B | II | 2-1S1-55 | VT-3 | RHRH-35/A | 90-005 | Results:N/A | | Results:NONE | NONE |
| IWF | RHR PUMP DISCH B | II | 2-1S1-55 | VT-3 | RHRH-38/F | 90-006 | Results:NONE | | Results:NONE | NONE |
| IWF | RHR PUMP SUCTION A | II | 2-1S1-53 | VT-3 | RHRH-12/D | 90-004 | Results:N/A | | Results:NONE | NONE |
| IWF | RHR PUMP SUCTION B | II | 2-1S1-51 | VT-3 | RHRH-19/H | 90-024 | Results:IND Type:LOOSE Ax Loc:NUTS Circ Loc: Length: | | Results:NONE | NONE |
| IWF | RHR PUMP SUCTION B | II | 2-1S1-51 | VT-3 | RHRH-20/F | 90-025 | Results:IND Type:NO LOAD Ax Loc:MARKERS Circ Loc: Length: | | Results:NONE | NONE |
| IWF | RHR PUMP SUCTION B | II | 2-1S1-51 | VT-3 | RHRH-27/I | 90-002 | Results:N/A | | Results:NONE | NONE |
| IWF | RHR PUMP SUCTION B | II | 2-1S1-51 | VT-3 | RHRH-52/O | 90-003 | Results:N/A | | Results:NONE | NONE |
| IWF | RHR PUMP SUCTION B | II | 2-1S1-51 | VT-3 | RHRH-56/C | 90-161 | Results:NONE | | Results:NONE | NONE |
| IWF | RWST DISCHARGE | II | 2-1S1-67 | VT-3 | SIH-16/B | 90-017 | Results:NONE | | Results:NONE | NONE |
| IWF | RX SAFETY INJ'M A | II | 2-1S1-73 | VT-3 | RHRH-26/C | 90-172 | Results:N/A | | Results:NONE | NONE |
| IWF | RX SAFETY INJ'M A | II | 2-1S1-73 | VT-3 | RHRH-29/F | 90-174 | Results:N/A | | Results:NONE | NONE |

NORTHERN STATES POWER COMPANY
PRAIRIE ISLAND UNIT II

TABLE S-II

Examination Comparison Summary

| SUB-ITEM | SYSTEM | CLASS | ISO | METH | ITEM | REPORT | PREVIOUS RESULTS | SCAN | CURRENT RESULTS | LIMITATIONS |
|----------|-------------------|-------|----------|------|------------|--------|---|------|-----------------------------|-------------------------|
| IWF | RX SAFETY INJ'N A | II | 2-151-73 | VT-3 | RNRRH-31/H | 90-173 | Results:N/A | | Results:NONE | NONE |
| IWF | SI PUMP 21 | II | 2-151-60 | VT-3 | SUPPORT C | 90-008 | Results:N/A | | Results:NONE | NONE |
| IWF | SI PUMP 21 | II | 2-151-60 | VT-3 | SUPPORT D | 90-009 | Results:N/A | | Results:NONE | NONE |
| IWF | SI PUMP A SUCTION | II | 2-151-65 | VT-3 | SIH-22/D | 90-026 | Results:N/A | | Results:NONE | NONE |
| IWF | SI PUMP B SUCTION | II | 2-151-63 | VT-3 | SIH-29/B | 90-027 | Results:N/A | | Results:IND Type:NO LOAD | NONE, ENG. EVAL. ACCEPT |
| | | | | | | | | | Ax Loc: | |
| | | | | | | | | | Circ Loc:SCALE | |
| | | | | | | | | | Length: | |
| IWF | SI PUMP B SUCTION | II | 2-151-63 | VT-3 | SIH-30/A | 90-016 | Results:IND Type:LOX SE Ax Loc:NUTS Circ Loc: Length: | | Results:NONE | NONE |

APPENDIX E

TABLE I-PERSONNEL LISTING
TABLE II-ULTRASONIC CALIBRATION BLOCKS
TABLE III-PROCEDURE LISTING
TABLE IV-EQUIPMENT AND MATERIALS

PERSONNEL ROSTER

CONTRACTOR:
Lambert, MacGill, Thomas, Inc.

10/04/90
515 Aldo Ave.
Santa Clara, CA 95054

| NAME JOB TITLE | ET LEVEL RECERT | MT LEVEL RECERT | PT LEVEL RECERT | UT LEVEL RECERT | IGSCC QUAL? | VT-1 LVL RECERT | VT-3 LVL RECERT | VISION DUE DATE | REMARKS |
|---------------------------|--------------------|--------------------|--------------------|--------------------|----------------|--------------------|--------------------|--------------------|---------|
| M.D. Hahn TECH | / / | II 02/05/93 | II 02/02/93 | I 02/06/93 | | / / | / / | 02/21/91 | |
| D.A. Halling TECH | / / | II 02/13/93 | II 10/14/90 | II 06/05/92 | N | II 09/26/92 | II 09/25/92 | 02/08/91 | |
| J.M. Johnson TECH | / / | II 08/19/92 | II 08/21/92 | II 08/28/93 | N | / / | / / | 08/04/91 | |
| D.B. MacGill LMT SUPR. | / / | III 02/17/92 | III 02/16/92 | III 02/16/92 | N | / / | / / | 07/10/91 | |
| S.D. MacGill DATA MGMT | / / | / / | / / | / / | | / / | / / | 07/10/91 | |
| C.P. McElroy TECH | / / | II 02/05/93 | II 02/05/93 | II 09/26/92 | N | / / | / / | 02/13/91 | |
| E.J. PAVLIC TECH | / / | / / | / / | I 09/12/93 | | / / | / / | 09/07/91 | |
| W.R. Raymer TECH | / / | II 04/09/91 | II 04/09/91 | II 04/03/91 | N | II 04/08/91 | II 04/08/91 | 07/23/91 | |
| D.B. Richey TECH | / / | II 06/22/92 | III 06/16/92 | III 04/14/92 | Y | III 08/18/92 | III 08/18/92 | 09/05/91 | |
| G.J. Strait ISI FORMAN | / / | III 04/25/92 | III 05/11/93 | III 05/11/93 | N | III 09/20/92 | III 09/20/92 | 12/13/90 | |

PERSONNEL ROSTER

CONTRACTOR:
Lambert, MacGill, Thomas, Inc.

10/02/90
515 Aldo Ave.
Santa Clara, CA 95054

| NAME JOB TITLE | ET LEVEL RECERT | MT LEVEL RECERT | PT LEVEL RECERT | UT LEVEL RECERT | IGSCC QUAL? | VT-1 LVL RECERT | VT-3 LVL RECERT | VISION DUE DATE | REMARKS |
|-----------------------------|--------------------|--------------------|--------------------|--------------------|----------------|--------------------|--------------------|--------------------|---------|
| W.L. Thomas TECH | / / | I 03/08/92 | I 05/25/92 | II 05/16/93 | N | / / | / / | 02/13/91 | |
| A.S. Whealdon GEN FORMAN | / / | III 05/29/93 | III 05/29/93 | III 05/29/93 | N | II 10/14/92 | II 05/18/91 | 12/28/90 | |
| J.P. Wren TECH | / / | II 08/21/92 | II 08/21/92 | II 08/21/92 | N | II 09/25/92 | II 09/25/92 | 08/13/91 | |

CONTRACTOR:
Conam Inspection

PERSONNEL ROSTER

10/15/90
660 South 31st St.
Richmond, CA 94804

| NAME JOB TITLE | ET LEVEL RECERT | MT LEVEL RECERT | PT LEVEL RECERT | UT LEVEL RECERT | IGSCC QUAL? | VT-1 LVL RECERT | VT-3 LVL RECERT | VISION DUE DATE | REMARKS |
|---------------------------|--------------------|--------------------|--------------------|--------------------|----------------|--------------------|--------------------|--------------------|---------|
| D.M. CHAMBERS ANALYST | III 01/10/92 | / / | / / | / / | | / / | / / | 07/05/91 | |
| M.E. DOBSON ANALYST | IIA 08/23/91 | / / | / / | / / | | / / | / / | 12/19/90 | |
| G.D. DONOVAN OPERATOR | IIB 06/19/93 | / / | / / | / / | | / / | / / | 01/08/91 | |
| T.B. DONOVAN OPERATOR | I 06/06/93 | / / | / / | / / | | / / | / / | 06/07/91 | |
| C. DUKE OPERATOR | I 06/06/93 | / / | / / | / / | | / / | / / | 06/07/91 | |
| B.K. FERGUSON ANALYST | IIA 01/27/92 | / / | / / | / / | | / / | / / | 10/17/90 | |
| K.L. FILARSKI OPERATOR | I 06/06/93 | / / | / / | / / | | / / | / / | 06/07/91 | |
| J.J. FUNANICH ANALYST | III 07/28/92 | / / | / / | / / | | / / | / / | 07/19/91 | |
| G.K. GOYA OPERATOR | IIB 06/18/93 | / / | / / | / / | | / / | / / | 02/23/91 | |
| K.J. HALL ANALYST | IIA 08/14/92 | / / | / / | / / | | / / | / / | 07/23/91 | |

PERSONNEL ROSTER

CONTRACTOR:
Conam Inspection

10/15/90
660 South 31st St.
Richmond, CA 94804

| NAME JOB TITLE | ET LEVEL RECERT | MT LEVEL RECERT | PT LEVEL RECERT | UT LEVEL RECERT | IGSCC QUAL? | VT-1 LVL RECERT | VT-3 LVL RECERT | VISION DUE DATE | REMARKS |
|----------------------------|--------------------|--------------------|--------------------|--------------------|----------------|--------------------|--------------------|--------------------|---------|
| J.M. JANET OPERATOR | IIA 08/15/93 | / / | / / | / / | | / / | / / | 03/21/91 | |
| M.R. KENEIPP ANALYST | IIA 01/31/92 | / / | / / | / / | | / / | / / | 01/04/91 | |
| M.E. LANDIS ANALYST | IIA 03/11/91 | / / | / / | / / | | / / | / / | 10/12/90 | |
| J.E. MANN OPERATOR | IIB 06/18/93 | / / | / / | / / | | / / | / / | 02/23/91 | |
| B.D. MARLOW SUPERVISOR | IIB 03/10/92 | / / | / / | / / | | / / | / / | 02/20/91 | |
| R.H. MERRIMAN ANALYST | IIA 11/24/90 | / / | / / | / / | | / / | / / | 02/20/91 | |
| J.F. MITCHELL ANALYST | IIA 08/25/92 | / / | / / | / / | | / / | / / | 12/18/90 | |
| J.C. PIRE OPERATOR | I 06/06/93 | / / | / / | / / | | / / | / / | 06/07/91 | |
| F. POWELL, JR. OPERATOR | IIB 07/20/93 | / / | / / | / / | | / / | / / | 03/20/91 | |
| D.G. SMITH OPERATOR | I 06/06/93 | / / | / / | / / | | / / | / / | 06/07/91 | |

PERSONNEL ROSTER

CONTRACTOR:
Conam Inspection

10/15/90
660 South 31st St.
Richmond, CA 94804

| NAME JOB TITLE | ET LEVEL RECERT | MT LEVEL RECERT | PT LEVEL RECERT | UT LEVEL RECERT | IGSCC QUAL? | VT-1 LVL RECERT | VT-3 LVL RECERT | VISION DUE DATE | REMARKS |
|--------------------------|--------------------|--------------------|--------------------|--------------------|----------------|--------------------|--------------------|--------------------|---------|
| G.R. THOMPSON ANALYST | IIA 04/19/93 | / / | / / | / / | | / / | / / | 12/19/90 | |
| W.L. TOBIN OPERATOR | IIB 06/18/93 | / / | / / | / / | | / / | / / | 03/20/91 | |
| D.J. TORRES OPERATOR | IIA 08/17/93 | / / | / / | / / | | / / | / / | 08/23/91 | |
| R.J. WEBB OPERATOR | IIA 08/10/93 | / / | / / | / / | | / / | / / | 07/24/91 | |

PERSONNEL ROSTER

CONTRACTOR:
Zetec
1370 N. W. Mall

10/02/90
P. O. Box 140
Issaquah, WA 980270140

| NAME JOB TITLE | ET LEVEL RECERT | MT LEVEL RECERT | PT LEVEL RECERT | UT LEVEL RECERT | IGSCC QUAL? | VT-1 LVL RECERT | VT-2 LVL RECERT | VISION DUE DATE | REMARKS |
|----------------------------|--------------------|--------------------|--------------------|--------------------|----------------|--------------------|--------------------|--------------------|---------|
| J.E. COX ANALYST | III 08/24/91 | / / | / / | / / | | / / | / / | 03/19/91 | |
| N.J. FARENBAUGH ANALYST | IIA 02/12/91 | / / | / / | / / | | / / | / / | 08/17/91 | |
| W.A. GRAY ANALYST | III 07/08/91 | / / | / / | / / | | / / | / / | 12/06/90 | |
| L.D. HOVER ANALYST | IIA 01/03/92 | / / | / / | / / | | / / | / / | 01/24/91 | |
| D.H. IVES ANALYST | III 06/01/91 | / / | / / | / / | | / / | / / | 01/19/91 | |
| M.G. MANLEY ANALYST | IIA 03/17/92 | / / | / / | / / | | / / | / / | 08/15/91 | |
| C.M. MATHISON ANALYST | IIA 09/14/91 | / / | / / | / / | | / / | / / | 03/29/91 | |
| J.D. SIEGEL ANALYST | III 12/11/90 | / / | / / | / / | | / / | / / | 12/18/90 | |
| R.A. VOLLMER ANALYST | III 08/11/92 | / / | / / | / / | | / / | / / | 03/21/91 | |
| T.A. WOLLER ANALYST | III 06/01/91 | / / | / / | / / | | / / | / / | 03/14/91 | |

NORTHERN STATES POWER COMPANY
 PRAIRIE ISLAND UNIT II
 ULTRASONIC CALIBRATION BLOCKS

APPENDIX E
 TABLE II
 PAGE 1 OF 2

| NSP NO. | SIZE DIA. | PIPE SCHEDULE & THICKNESS | MATERIAL | SERIAL OR HEAT NO. | CALIBRATION REPORTS | DATE |
|---------|-----------|---------------------------|-------------|--------------------|--|--|
| 3 | 2" | 160 .344" | A312 TP-304 | 2P4659 | DBR-009 | 09-25-90 |
| 4 | 3" | 160 .438" | A376 TP-316 | M5900 | GJS-006 GJS-007 | 09-18-90 09-18-90 |
| 6 | 6" | 160 .718" | A376 TP-316 | M3715 | DBR-005 DBR-006 DBR-010 DBR-012 GJS-001 GJS-002 | 09-24-90 09-24-90 09-26-90 09-26-90 09-12-90 09-12-90 |
| 8 | 8" | 140 .812" | A376 TP-316 | J2338 | GJS-008 GJS-009 | 09-18-90 09-27-90 |
| 11 | 12" | 160 1.312" | A376 TP-316 | J2103 | DBR-011 DBR-013 | 09-26-90 09-26-90 |
| 15 | -- | --- 1.500" | A-351 CF8A | B2877 | DBR-003 DBR-004 | 09-23-90 09-23-90 |
| 16 | -- | --- 1.500" | SA-299 | PI222 | JPW-013 | 09-24-90 |
| 20 | 16" | 80 1.219" | A-106 GR B | N14868 | WLT-014 | 09-29-90 |
| 23 | 30" | --- 1.045" | A-515 GR 70 | 88526 | CPM-003 WLT-003 | 09-28-90 09-22-90 |
| 24 | 31" | --- 1.534" | A-515 GR 70 | 79114 | WLT-002 JPW-012 | 09-21-90 09-24-90 |

NORTHERN STATES POWER COMPANY
 PRAIRIE ISLAND UNIT II
 ULTRASONIC CALIBRATION BLOCKS

APPENDIX E
 TABLE II
 PAGE 2 OF 2

| NSP NO. | SIZE DIA. | PIPE SCHEDULE & THICKNESS | MATERIAL | SERIAL OR HEAT NO. | CALIBRATION REPORTS | DATE |
|---------|-----------|---------------------------|----------------|--------------------|---|--|
| 25A | BLOCK | --- 5.312" | A533 GR B CL 1 | C2220/1 | JPW-005 JPW-006 JPW-007 JPW-008 JPW-009 JPW-010 JPW-017 JPW-018 JPW-019 | 09-17-90 09-17-90 09-17-90 09-18-90 09-19-90 09-19-90 09-26-90 09-26-90 09-26-90 |
| 26 | BLOCK | --- 3.5" | A533 GR B CL 2 | 52391 | DBR-001 DBR-002 GJS-003 GJS-004 GJS-005 WLT-001 | 09-19-90 09-19-90 09-13-90 09-14-90 09-15-90 09-20-90 |
| 36 | 16" | 100 1.031" x .585" | A-106 GR C | 45124A | JPW-002 JPW-003 JPW-004 JPW-015 JPW-016 | 09-14-90 09-14-90 09-14-90 09-25-90 09-25-90 |
| Y-50 | 6.126" | --- 62" L | SA-540 B-24 | 82586 | JWP-011 | 09-20-90 |

NORTHERN STATES POWER COMPANY
 PRAIRIE ISLAND UNIT II
 PROCEDURE LISTING

APPENDIX E
 TABLE III
 PAGE 1 OF 2

| PROCEDURE NUMBER AND REVISION | FIELD CHANGE | PROCEDURE TITLE | PLANT APPROVAL DATE | CHANGE DESCRIPTION |
|-------------------------------|--------------|---|---------------------|--------------------|
| ISI-PT-1, REV. 0 | NONE | LIQUID PENETRANT EXAMINATION | 08-08-89 | |
| ISI-PT-2, REV. 0 | NONE | HIGH TEMPERATURE LIQUID PENETRANT EXAMINATION | 08-08-89 | |
| ISI-MT-1, REV. 0 | NONE | MAGNETIC PARTICLE EXAMINATION | 08-08-89 | |
| ISI-MT-2, REV. 0 | NONE | WET MAGNETIC PARTICLE EXAMINATION | 08-08-89 | |
| ISI-UT-1, REV. 1 | NONE | ULTRASONIC EXAMINATION OF PIPE WELDS | 08-20-90 | |
| ISI-UT-2, REV. 0 | NONE | AUTOMATIC DATA RECORDING | 08-08-89 | |
| ISI-UT-3, REV. 1 | NONE | ULTRASONIC EXAMINATION OF FERRITIC VESSELS | 08-20-90 | |
| ISI-UT-4, REV. 1 | NONE | ULTRASONIC EXAMINATION OF STUDS, BOLTS AND NUTS | 08-20-90 | |
| ISI-UT-4B, REV. 1 | NONE | AXIAL ULTRASONIC EXAMINATION OF STUDS AND BOLTS | 08-20-90 | |
| ISI-UT-11, REV. 1 | NONE | ULTRASONIC EXAMINATION OF CAST STAINLESS STEEL PIPING | 08-20-90 | |
| ISI-UT-12, REV. 1 | NONE | ULTRASONIC EXAMINATION OF REACTOR COOLANT PUMP FLYWHEELS | 08-20-90 | |
| ISI-UT-16, REV. 1 | NONE | ULTRASONIC EXAMINATION OF WELDS IN AUSTENITIC AND HIGH NICKEL ALLOY MATERIALS | 08-20-90 | |

NORTHERN STATES POWER COMPANY
 PRAIRIE ISLAND UNIT II
 PROCEDURE LISTING

| PROCEDURE NUMBER AND REVISION | FIELD CHANGE | PROCEDURE TITLE | PLANT REVIEW DATE | CHANGE DESCRIPTION |
|--|--------------|--|----------------------|---|
| ISI-VT-1.0, REV. 0 ISI-VT-2.0, REV. 0 | NONE NONE | VISUAL EXAMINATION VISUAL EXAMINATION OF HANGER ASSEMBLIES | 08-08-89 08-08-89 | |
| ISI-EI-1, REV. 1 | SUP. 1 | EDDY CURRENT DATA ANALYSIS GUIDELINES | 09-13-90 | |
| 42-EC-165 REV. 3 | FC 1 | MULTIFREQUENCY EDDY CURRENT PROCEDURE, WESTINGHOUSE SERIES 51 STEAM GENERATOR TUBING, MIZ 18 DIGITAL EDDY CURRENT SYSTEM, PRAIRIE ISLAND UNITS 1 & 2 | 01-24-90 | ALLOW FOR USE OF EDDYNET ANALYSIS SOFTWARE |
| 42-EC-168 REV. 1 | FC 1 | SPECIAL EXAMINATION PROCEDURE, WESTINGHOUSE SERIES 51 STEAM GENERATOR TUBING, MIZ-18 DIGITAL EDDY CURRENT SYSTEM, PRAIRIE ISLAND UNITS 1 & 2 | 01-24-90 | ALLOW FOR USE OF EDDYNET ANALYSIS SOFTWARE |
| 42-EC-168 REV. 1 | FC 2 | SPECIAL EXAMINATION PROCEDURE, WESTINGHOUSE SERIES 51 STEAM GENERATOR TUBING, MIZ-18 DIGITAL EDDY CURRENT SYSTEM, PRAIRIE ISLAND UNITS 1 & 2 | 09-14-90 | ALLOW FOR USE OF QUICK EDDY 360 PROBE HEAD FOR PLUG EXAMINATION |

PI UNIT II
TABLE IV: Equipment and Materials

| IV A: ULTRASONIC INSTRUMENTS | | | | |
|------------------------------|------------|---------------|----------------------|------------|
| MANUFACTURER | MODEL | SERIAL NUMBER | CALIBRATION DUE DATE | CONTRACTOR |
| NORTEC | 131/D | 111 | 11/01/90 | LMT |
| NORTEC | 131/D | 126 | 11/02/90 | LMT |
| NORTEC | 131/D | 287 | 10/27/90 | LMT |
| NORTEC | 131/D | 291 | 10/30/90 | LMT |
| PANAMETRIC | EPOCH 2002 | 377 | 10/13/90 | LMT |
| PANAMETRIC | EPOCH 2002 | 864 | 10/10/90 | LMT |

| IV C: ULTRASONIC REFERENCE STANDARDS | | | | |
|--------------------------------------|-----------|------------|---------------|------------|
| MANUFACTURER | TYPE | MATERIAL | SERIAL NUMBER | CONTRACTOR |
| DIMAC | IIW | ASTM A 108 | LMT-1 | LMT |
| ESCO CORP | STEPWEDGE | 304 | STP-5 | LMT |
| ESCO CORP | STEPWEDGE | 304 | STP-7 | LMT |
| DIMAC | STEPWEDGE | C/S | LMT-14 | LMT |
| DIMAC | STEPWEDGE | A 108 | STP-10 | LMT |
| DIMAC | ROMPAS | 304 | LMT-035 | LMT |
| DIMAC | ROMPAS | 304 | LMT-057 | LMT |
| DIMAC | ROMPAS | 4140 | LMT-065 | LMT |
| DIMAC | ROMPAS | 4140 | LMT-068 | LMT |

PI UNIT II
TABLE IV: Equipment and Materials

| IV C: EDDY CURRENT REFERENCE STANDARDS | | | | |
|--|------------|----------|---------------|------------|
| MANUFACTURER | TYPE | MATERIAL | SERIAL NUMBER | CONTRACTOR |
| ZETEC | STD, REF | INCONEL | Z-3457 | CONAM |
| ZETEC | STD, REF | INCONEL | Z-3458 | CONAM |
| ZETEC | STD, REF | INCONEL | Z-3513 | CONAM |
| ZETEC | STD, REF | INCONEL | Z-3908 | CONAM |
| ZETEC | STD, GUIDE | INCONEL | Z-6448 | CONAM |
| ZETEC | STD, GUIDE | INCONEL | Z-6449 | CONAM |
| ZETEC | STD, AVB | INCONEL | Z-7500 | CONAM |
| ZETEC | STD, AVB | INCONEL | Z-7501 | CONAM |
| ZETEC | STD, EXPAN | INCONEL | Z-7525 | CONAM |
| ZETEC | STD, EXPAN | INCONEL | Z-7526 | CONAM |
| ZETEC | STD, EXPAN | INCONEL | Z-7527 | CONAM |
| ZETEC | STD, EXPAN | INCONEL | Z-7528 | CONAM |
| ZETEC | STD, GUIDE | INCONEL | Z-8467 | CONAM |
| ZETEC | STD, GUIDE | INCONEL | Z-8468 | CONAM |
| ZETEC | STD, GUIDE | INCONEL | Z-8469 | CONAM |
| ZETEC | STD, GUIDE | INCONEL | Z-8470 | CONAM |
| ZETEC | STD, GUIDE | INCONEL | Z-8471 | CONAM |
| B & W | PLUG | INCONEL | 2848-2-271 | CONAM |
| B & W | PLUG | INCONEL | 2848-2-272 | CONAM |

| IV D: ULTRASONIC SEARCH UNITS | | | | | | |
|-------------------------------|-------|---------------|------------|-----------|---------------|------------|
| MANUFACTURER | MODEL | SERIAL NUMBER | SIZE | FREQUENCY | NOMINAL ANGLE | CONTRACTOR |
| KBI | AB | F26459 | 10 X 10 mm | 2.0 | 70° | LMT |
| AEROTECH | AB | H10142 | 0.5" | 1.5 | N/A | LMT |
| AEROTECH | AB | J05539 | 0.25" | 2.25 | N/A | LMT |
| AEROTECH | AB | J05540 | 0.25" | 2.25 | N/A | LMT |
| AUTOMATION | AB | J85257 | 0.5 X 0.5" | 2.25 | 60° | LMT |
| AUTOMATION | AB | J85296 | 0.5 X 0.5" | 2.25 | 60° | LMT |
| AEROTECH | AB | K17340 | 0.5" | 2.25 | N/A | LMT |
| AEROTECH | AB | K26863 | 0.25" | 5.0 | N/A | LMT |
| AUTOMATION | SB | K85135 | 0.38" DIA | 2.25 | 0° | LMT |
| AUTOMATION | SB | K85136 | 0.38" DIA | 2.25 | 0° | LMT |
| AUTOMATION | AB | K85211 | .38 X .38" | 2.25 | 45° | LMT |
| AUTOMATION | AB | K85212 | .38 X .38" | 2.25 | 45° | LMT |
| AUTOMATION | AB | L85219 | .38 X .38" | 1.5 | 45° | LMT |
| AUTOMATION | AB | L85220 | .38 X .38" | 1.5 | 45° | LMT |
| AUTOMATION | AB | L85221 | .38 X .38" | 1.5 | 45° | LMT |
| AUTOMATION | AB | L85222 | .38 X .38" | 1.5 | 45° | LMT |
| HARISONIC | AB | V10705 | 1.0 X 1.0" | 2.25 | N/A | LMT |
| HARISONIC | AB | V11195 | 0.38" | 1.5 | N/A | LMT |
| HARISONIC | AB | V11196 | 0.38" | 1.5 | N/A | LMT |

PI
TABLE IV: Equipment and materials

| IV D: ULTRASONIC SEARCH UNITS | | | | | | |
|-------------------------------|-------|---------------|-------------|-----------|---------------|------------|
| MANUFACTURER | MODEL | SERIAL NUMBER | SIZE | FREQUENCY | NOMINAL ANGLE | CONTRACTOR |
| SUSI | AB | 1378 | 0.5 X 0.5" | 1.0 | 55° | LMT |
| HARISONIC | AB | 1854 | .25 X .625" | 1.0 | 55° | LMT |
| HARISONIC | AB | 1855 | .25 X .625" | 1.5 | 55° | LMT |
| PANAMETRIC | SB | 5840 | 1.0" DIA | 1.0 | 0° | LMT |
| HARISONIC | SB | C264 | 1.0" DIA | 2.25 | 0 | LMT |
| HARISONIC | AB | L416 | .38 X .38" | 3.5 | N/A | LMT |
| HARISONIC | AB | L427 | .38 X .38" | 3.5 | N/A | LMT |
| HARISONIC | SB | N951 | 1.2" DIA | 1.0 | 0° | LMT |
| KBA | AB | 33295 | .375" DIA | 2.25 | N/A | LMT |
| KBI | AB | 56526 | 12 X 6 mm | 2.0 | 70° | LMT |
| AEROTECH | AB | 77204 | 0.38" DIA | 5.0 | N/A | LMT |
| AEROTECH | AB | 77223 | 0.38" DIA | 5.0 | N/A | LMT |
| HARISONIC | SB | 98872 | 1.0" | 2.25 | 0 | LMT |
| HARISONIC | SB | B6466 | 0.25" DIA | 5.0 | 0° | LMT |
| HARISONIC | SB | B7356 | 0.38" DIA | 5.0 | 0° | LMT |
| HARISONIC | AB | C4157 | .38 X .38" | 1.5 | 55° | LMT |
| HARISONIC | SB | D2609 | 0.25" DIA | 5.0 | 0° | LMT |
| HARISONIC | SB | D5050 | .38" DIA | 5.0 | 0° | LMT |
| HARISONIC | SB | N-979 | 1/2 X 1/2" | 2.25 | 0 | LMT |
| HARISONIC | AB | S2285 | 0.5 X 0.5" | 1.5 | N/A | LMT |
| HARISONIC | AB | S2286 | 0.5 X 0.5" | 1.5 | N/A | LMT |
| HARISONIC | AB | T4158 | 1.0 X 1.0" | 2.25 | N/A | LMT |
| HARISONIC | SB | V6271 | .750" | 2.25 | 0 | LMT |
| HARISONIC | AB | W1283 | 1.0 X 1.0" | 2.25 | N/A | LMT |
| AEROTECH | SB | 015963 | 0.5" DIA | 2.25 | 0° | LMT |
| KBA | AB | A21651 | 1.0" | 1.0 | N/A | LMT |
| KBA | AB | A21652 | 1.0" | 1.0 | N/A | LMT |
| AEROTECH | AB | A25417 | .18 X .18" | 2.25 | 60° | LMT |
| AEROTECH | AB | A25418 | .18 X .18" | 2.25 | 60° | LMT |
| AEROTECH | SB | A30160 | 0.5" DIA | 2.25 | 0° | LMT |
| AEROTECH | AB | B12133 | 1.0" | 2.25 | N/A | LMT |
| AEROTECH | AB | C15851 | 1.0" | 2.25 | N/A | LMT |
| AEROTECH | AB | C21837 | 0.5" | 2.25 | N/A | LMT |
| AUTOMATION | AB | C85188 | .38 X .38" | 2.25 | 60° | LMT |
| AUTOMATION | AB | C85190 | .38 X .38" | 2.25 | 60° | LMT |
| HARISONIC | SB | E11082 | 0.5" DIA | 2.25 | 0° | LMT |
| HARISONIC | SB | E11083 | 0.5" DIA | 2.25 | 0° | LMT |
| AT | AB | F13026 | 0.25" | 5.0 | N/A | LMT |
| KBA | AB | F15648 | 1.0" | 1.0 | N/A | LMT |
| KBA | AB | F15649 | 1.0" | 1.0 | N/A | LMT |

PI UNIT II
TABLE IV: Equipment and Materials

| IV E: LIQUID PENETRANT MATERIALS | | | | |
|----------------------------------|-----------|--------------|--------------|------------|
| MANUFACTURER | MATERIAL | TYPE | BATCH NUMBER | CONTRACTOR |
| MAGNAFLUX | CLEANER | SKC-NF/ZC-7B | 86M001 | LMT |
| MAGNAFLUX | CLEANER | SKC-NF | 89L01P | LMT |
| MAGNAFLUX | CLEANER | SKC-NF | 90A01S | LMT |
| SHERWIN | CLEANER | K019 | 329-D56 | LMT |
| MAGNAFLUX | DEVELOPER | SKD-NF/ZF-9B | 86A008 | LMT |
| MAGNAFLUX | DEVELOPER | SKD-NF/ZP-9B | 88C046 | LMT |
| MAGNAFLUX | DEVELOPER | SKD-NF/ZP-9B | 88H063 | LMT |
| SHERWIN | DEVELOPER | D-350 | 223-D71 | LMT |
| MAGNAFLUX | PENETRANT | SKL-HF/S | 83K027 | LMT |
| MAGNAFLUX | PENETRANT | SKL-HF/S | 85K050 | LMT |
| MAGNAFLUX | PENETRANT | SKL-HF/S | 85K076 | LMT |
| SHERWIN | PENETRANT | K017 | 329-D54 | LMT |

| IV F: MAGNETIC PARTICLE EQUIPMENT & MATERIALS | | | | |
|---|----------|------|--------------|------------|
| MANUFACTURER | MATERIAL | TYPE | BATCH NUMBER | CONTRACTOR |
| MAGNAFLUX | L-10 | | GTL-004 | LMT |
| PARKER | DA-200 | | 10282 | LMT |
| MAGNAFLUX | Y-6 | | GTL-005 | LMT |

PI UNIT II
TABLE IV: Equipment and Materials

IV G: MISCELLANEOUS EQUIPMENT & MATERIALS

| MANUFACTURER | MATERIAL | TYPE | BATCH NUMBER | CONTRACTOR |
|--------------|----------|----------|--------------|------------|
| ARDROX | J221 | BL METER | | LMT |
| PTC | 310F | TMP GAGE | 1128 | LMT |
| PTC | 310F | TMP GAGE | 1129 | LMT |
| PTC | 310F | TMP GAGE | 1130 | LMT |
| PTC | 310F | TMP GAGE | 1131 | LMT |
| PTC | 310F | TMP GAGE | 1132 | LMT |
| PTC | 310F | TMP GAGE | 1135 | LMT |
| PTC | 310F | TMP GAGE | 1136 | LMT |
| PTC | 310F | TMP GAGE | 1137 | LMT |
| PTC | 310F | TMP GAGE | 1138 | LMT |
| PTC | 310F | TMP GAGE | 1139 | LMT |

IV H: EDDY CURRENT COMPUTERS

| MANUFACTURER | MODEL | SERIAL NUMBER | CALIBRATION DUE DATE | CONTRACTOR |
|--------------|---------|---------------|----------------------|------------|
| ZETEC | MIZ-18A | 007 | 12/12/90 | CONAM |
| ZETEC | MIZ-18A | 012 | 12/11/90 | CONAM |
| ZETEC | MIZ-18A | 076 | 08/21/91 | CONAM |
| ZETEC | MIZ-18A | 148 | 09/06/91 | CONAM |
| ZETEC | MIZ-18A | 178 | 07/26/91 | CONAM |
| ZETEC | MIZ-18 | 193 | 01/19/91 | CONAM |

APPENDIX F
STEAM GENERATOR NO. 21
EDDY CURRENT TUBE SHEET MAPS AND CUMULATIVE DATA REPORTS

LEGEND OF FIELDS AND CODES

| <u>FIELD</u> | <u>EXPLANATION</u> |
|--------------|---|
| ROW | Row number of tube location |
| COL | Column number of tube location |
| LEG | Channel head tested from |
| BEG | Beginning extent of test |
| END | Ending extent of test |
| REM | Remarks |
| REEL | Reel number where data is located |
| PROBE | Probe size, manufacturer and type used |
| LOCATION | Location of call or date plug installed |
| VOLTS | Voltage of signal |
| DEG | Degree of signal |
| % | Measured percent through wall depth |
| CH | Channel used for measurement |

| <u>FIELD</u> | <u>CODE</u> | <u>EXPLANATION</u> |
|-----------------------|-------------|--|
| LEG | C | Cold leg |
| | H | Hot leg |
| PROBE | *** | Probe nominal diameter |
| | ZW | Wide groove ULC manufactured by Zetec |
| | ZU | Standard ULC manufactured by Zetec |
| | ZS | Spring flex ULC manufactured by Zetec |
| | ZR | Rotating pancake coil by Zetec |
| BEG, END, LOCATION | TEH | Tube end hot (primary face) |
| | TOR | Top of roll expansion |
| | TSH | Tube sheet hot (secondary face) |
| | 01H | First support plate on hot leg side |
| | *** | Second through sixth locations |
| | 07H | Seventh support plate on hot leg side |
| | NV1 | First new antivibration bar |
| | *** | Second and third locations |
| | NV4 | Fourth new antivibration bar |
| | 07C | Seventh support plate on cold leg side |
| | *** | Sixth through second locations |
| | 01C | First support plate on cold leg side |
| | TSC | Tube sheet cold (secondary face) |
| | TOR | Top of roll expansion |
| | TEC | Tube end cold (primary face) |
| REM | | Key supplied with each report |
| % | PLG | Plugged tube |
| | MBM | Manufacturing Burnish Mark |
| | VOL | Volumetric Indication |
| CH | ** | channel number |

CUMULATIVE INDICATIONS REPORT
PRAIRIE ISLAND, UNIT 2

Generator: 21
Leg.....: Hot and Cold legs
Release..: 2.0

Page: Title page
Date: 09/28/90
Time: 8:48

Report selection criteria :

0% TO 19% for the entire length
Supplemental data : All except NDDs included
Plugs : None included
Selected indications only are included
Groups : All groups included

Three column remarks field key :

Column 1=PID information
Column 2=Resolution file information
Column 3=Hold file information
"P" in Col 1=Positive identification retest condition exists
"S" In Col 1=Line contains supplemental data
"R" In Col 2=More data pending in resolution file
"H" In Col 3=More data pending in hold file

NSP

CUMULATIVE INDICATIONS REPORT
PRAIRIE ISLAND, UNIT 2

Generator: 21
Leg.....: Hot and Cold legs
Release...: 2.0
0% TO 19% for the entire length

Page: 1
Date: 09/28/90
Time: 8:49

| ROW | COL | LEG | EXTENT | | REM | REEL | PROBE | LOCATION | | CURRENT | | | |
|-----|-----|-----|--------|-----|-----|------|-------|----------|------|---------|-----|-----|----|
| | | | BEG | END | | | | | | VOLTS | DEG | % | CH |
| 18 | 5 | C | 07H | TEC | | 002 | 720ZU | 01C- | 0.2 | 3.12 | 149 | 2 | 17 |
| 23 | 7 | H | 07H | TEH | | 015 | 720ZW | 02H- | 0.2 | 1.14 | 123 | 7 | 17 |
| 29 | 13 | C | 07H | TEC | | 060 | 720ZS | 01C- | 0.2 | 2.24 | 141 | 4 | 17 |
| 33 | 17 | C | 07H | TEC | | 063 | 720ZU | 02C+ | 0.0 | 0.56 | 135 | 16 | 17 |
| 34 | 18 | C | 07H | TEC | | 006 | 720ZU | 01C- | 0.3 | 1.45 | 152 | 7 | 17 |
| 40 | 24 | C | 07H | TEC | | 009 | 720ZU | TSC+ | 4.3 | 0.59 | 172 | 10 | 1 |
| 28 | 26 | C | 07H | TEC | | 011 | 720ZU | 04C+ | 36.0 | 0.64 | 160 | 19 | 1 |
| 41 | 26 | C | 07H | TEC | | 011 | 720ZU | 01C+ | 0.0 | 1.76 | 140 | 7 | 17 |
| 41 | 27 | C | 07H | TEC | | 011 | 720ZU | 01C+ | 0.1 | 1.90 | 140 | 7 | 17 |
| 25 | 30 | C | 07H | TEC | | 013 | 720ZU | NV2+ | 0.9 | 0.55 | 0 | 16 | 18 |
| 45 | 42 | C | 07H | TEC | | 022 | 720ZW | 01C- | 0.2 | 1.88 | 146 | 13 | 17 |
| | | C | 07H | TEC | | 022 | 720ZW | 02C- | 0.1 | 3.03 | 150 | 8 | 17 |
| 46 | 45 | C | 07H | TEC | | 024 | 720ZU | 01C- | 0.0 | 0.69 | 136 | 17 | 17 |
| 45 | 50 | C | 07H | TEC | | 033 | 720ZU | 01C- | 0.1 | 0.61 | 137 | 2 | 17 |
| 43 | 57 | C | 07H | TEC | | 041 | 720ZU | 01C+ | 0.2 | 0.94 | 130 | 10 | 17 |
| 44 | 58 | C | 07H | TEC | | 060 | 720ZS | 02C- | 0.2 | 1.17 | 141 | 4 | 17 |
| 45 | 58 | C | 07H | TEC | | 060 | 720ZS | 01C+ | 0.0 | 2.40 | 135 | 16 | 17 |
| 43 | 60 | C | 07H | TEC | | 044 | 720ZU | 01C- | 0.0 | 1.05 | 157 | 7 | 17 |
| | | C | 02C | 02C | S | 093 | 720ZR | 02C- | 0.0 | 2.40 | 125 | VOL | 6 |
| 44 | 61 | C | 07H | TEC | | 044 | 720ZU | 02C- | 0.3 | 0.74 | 150 | 8 | 17 |
| 43 | 64 | C | 07H | TEC | | 048 | 720ZU | 01C- | 0.1 | 1.24 | 136 | 15 | 17 |
| 40 | 66 | C | 07H | TEC | | 049 | 720ZU | 02C+ | 0.0 | 2.05 | 127 | 19 | 17 |
| 39 | 69 | C | 07H | TEC | | 051 | 700ZS | 01C- | 0.3 | 0.56 | 148 | 7 | 17 |

NSP

CUMULATIVE INDICATIONS REPORT
PRAIRIE ISLAND, UNIT 2

Generator: 21
Leg.....: Hot and Cold legs
Release..: 2.0
0% TO 19% for the entire length

Page: 2
Date: 09/28/90
Time: 8:49

| ROW | COL | LEG | EXTENT | | REM | REEL | PROBE | LOCATION | | CURRENT | | | |
|-----|-----|-----|--------|-----|-----|------|-------|----------|-----|---------|-----|----|----|
| | | | BEG | END | | | | | | VOLTS | DEG | % | CH |
| 40 | 70 | C | 07H | TEC | | 053 | 720ZU | 02C- | 0.1 | 0.84 | 140 | 15 | 17 |
| 18 | 71 | C | 07H | TEC | | 053 | 720ZU | NV3+ | 0.2 | 0.40 | 0 | 9 | 18 |
| 40 | 71 | C | 07H | TEC | | 053 | 720ZU | 01C- | 0.3 | 0.85 | 142 | 11 | 17 |
| 36 | 72 | C | 07H | TEC | | 054 | 720ZU | 01C- | 0.2 | 2.31 | 138 | 16 | 17 |
| 37 | 75 | C | 07H | TEC | | 054 | 720ZU | 01C+ | 0.0 | 2.75 | 145 | 3 | 17 |
| 36 | 76 | C | 07H | TEC | | 087 | 700ZS | 01C+ | 0.0 | 1.09 | 140 | 9 | 17 |
| 33 | 77 | C | 06H | TEC | | 055 | 720ZU | 03C- | 0.3 | 1.26 | 141 | 9 | 17 |
| 31 | 80 | C | 07H | TEC | | 058 | 720ZU | 01C- | 0.1 | 0.52 | 142 | 11 | 17 |
| 30 | 81 | C | 07H | TEC | | 058 | 720ZU | 01C+ | 0.0 | 2.91 | 144 | 12 | 17 |
| 25 | 86 | C | 07H | TEC | | 059 | 720ZU | 01C- | 0.1 | 0.38 | 139 | 18 | 17 |
| 18 | 87 | C | 07H | TEC | | 059 | 720ZU | 01C+ | 0.0 | 1.96 | 140 | 15 | 17 |
| 17 | 89 | C | 07H | TEC | | 059 | 720ZU | 02C+ | 0.0 | 1.76 | 139 | 18 | 17 |
| 8 | 92 | C | 07H | TEC | | 083 | 700ZS | 01C+ | 0.0 | 0.84 | 142 | 11 | 17 |
| 14 | 92 | C | 07H | TEC | | 060 | 720ZS | 01C+ | 0.0 | 0.80 | 135 | 18 | 17 |
| 2 | 93 | C | 07H | TEC | | 071 | 700ZU | 01C- | 0.1 | 1.79 | 135 | 8 | 17 |
| | | C | 07H | TEC | | 071 | 700ZU | 02C+ | 0.0 | 0.55 | 131 | 15 | 17 |
| 4 | 93 | C | 07H | TEC | | 071 | 700ZU | 02C- | 0.2 | 0.44 | 146 | 6 | 17 |

NUMBER OF TUBES IN REPORT = 37

NSP

CUMULATIVE INDICATIONS REPORT
PRAIRIE ISLAND, UNIT 2

Generator: 21
Leg.....: Hot and Cold legs
Release..: 2.0

Page: Title page
Date: 09/28/90
Time: 10:14

Map selection criteria :

0% TO 19% for the entire length
Supplemental data : All except NDDs included
Plugs : None included
Selected indications only are included
Groups : All groups included

NSP

DATE: 09/28/90

TIME: 10:14

STEAM GENERATOR: 21

GROUPS: All groups included


0% TO 19% for the entire length

PRAIRIE ISLAND, UNIT 2

CUMULATIVE INDICATIONS REPORT-HOT AND COLD LEGS



0% TO 19% 37



CUMULATIVE INDICATIONS REPORT
PRAIRIE ISLAND, UNIT 2

Generator: 21
Leg.....: Hot and Cold legs
Release..: 2.0

Page: Title page
Date: 09/28/90
Time: 9:00

Report selection criteria :

20% TO 29% for the entire length
Supplemental data : All except NDDs included
Plugs : None included
Selected indications only are included
Groups : All groups included

Three column remarks field key :

Column 1=PID information
Column 2=Resolution file information
Column 3=Hold file information
"P" in Col 1=Positive identification retest condition exists
"S" In Col 1=Line contains supplemental data
"R" In Col 2=More data pending in resolution file
"H" In Col 3=More data pending in hold file

NSP

CUMULATIVE INDICATIONS REPORT
PRAIRIE ISLAND, UNIT 2

Generator: 21
Leg.....: Hot and Cold legs
Release...: 2.0
20% TO 29% for the entire length

Page: 1
Date: 09/28/90
Time: 9:00

| ROW | COL | LEG | EXTENT | | REM | REEL | PROBE | LOCATION | CURRENT | | | | |
|-----|-----|-----|--------|-----|-----|------|-------|----------|---------|------|-----|----|----|
| | | | BEG | END | | | | | VOLTS | DEG | % | CH | |
| 16 | 5 | C | 07H | TEC | | 002 | 720ZU | 02C- | 0.0 | 1.64 | 135 | 22 | 17 |
| 14 | 6 | C | 07H | TEC | | 002 | 720ZU | 01C- | 0.1 | 1.56 | 132 | 26 | 17 |
| 23 | 27 | C | 07H | TEC | | 011 | 720ZU | NV4+ | 4.4 | 1.15 | 0 | 24 | 18 |
| 18 | 28 | C | 07H | TEC | | 011 | 720ZU | NV2+ | 0.9 | 0.99 | 0 | 24 | 18 |
| 25 | 30 | C | 07H | TEC | | 013 | 720ZU | NV2+ | 20.0 | 1.27 | 0 | 28 | 18 |
| 39 | 30 | C | 07H | TEC | | 013 | 720ZU | NV4+ | 2.6 | 0.84 | 0 | 22 | 18 |
| 25 | 32 | C | 07H | TEC | | 014 | 720ZU | NV2+ | 0.6 | 1.10 | 0 | 23 | 18 |
| | | C | 07H | TEC | | 014 | 720ZU | NV2+ | 19.7 | 1.42 | 0 | 27 | 18 |
| 39 | 34 | C | 07H | TEC | | 016 | 720ZU | NV4+ | 2.8 | 1.33 | 0 | 26 | 18 |
| 44 | 34 | C | 07H | TEC | | 063 | 720ZU | 05C- | 0.1 | 0.98 | 129 | 26 | 17 |
| 18 | 36 | C | 07H | TEC | | 017 | 720ZU | NV4+ | 0.0 | 1.01 | 0 | 24 | 18 |
| 45 | 36 | C | 07H | TEC | | 063 | 720ZU | 01C+ | 0.0 | 1.10 | 130 | 24 | 17 |
| 23 | 37 | C | 07H | TEC | | 017 | 720ZU | NV2+ | 17.9 | 1.08 | 0 | 23 | 18 |
| 45 | 41 | C | 07H | TEC | | 021 | 720ZU | 02C+ | 0.0 | 2.07 | 141 | 20 | 17 |
| 44 | 42 | C | 07H | TEC | | 022 | 720ZW | 01C- | 0.3 | 0.79 | 135 | 27 | 17 |
| 36 | 43 | C | 07H | TEC | | 022 | 720ZW | NV2+ | 2.5 | 0.93 | 0 | 20 | 18 |
| | | C | 07H | TEC | | 022 | 720ZW | NV2+ | 2.6 | 0.98 | 0 | 21 | 18 |
| 18 | 44 | C | 07H | TEC | | 022 | 720ZW | NV2+ | 13.8 | 1.56 | 0 | 29 | 18 |
| 43 | 44 | C | 07H | TEC | | 024 | 720ZU | 01C+ | 0.0 | 3.19 | 134 | 20 | 17 |
| 44 | 44 | C | 07H | TEC | | 024 | 720ZU | 01C+ | 0.0 | 4.14 | 130 | 25 | 17 |
| 28 | 45 | C | 07H | TEC | | 024 | 720ZU | 07H+ | 29.2 | 1.12 | 0 | 24 | 18 |
| | | C | 07H | TEC | | 024 | 720ZU | NV2+ | 0.0 | 1.06 | 0 | 23 | 18 |
| | | C | 07H | TEC | | 024 | 720ZU | NV2+ | 22.4 | 0.90 | 0 | 20 | 18 |
| | | C | 07H | TEC | | 024 | 720ZU | NV4+ | 2.5 | 0.93 | 0 | 21 | 18 |

NSP

CUMULATIVE INDICATIONS REPORT
PRAIRIE ISLAND, UNIT 2

Generator: 21
Leg.....: Hot and Cold legs
Release...: 2.0
20% TO 29% for the entire length

Page: 2
Date: 09/28/90
Time: 9:00

| ROW | COL | LEG | EXTENT | | REM | REEL | PROBE | LOCATION | CURRENT | | | | |
|-----|-----|-----|--------|-----|-----|------|-------|----------|---------|------|-----|----|----|
| | | | BEG | END | | | | | VOLTS | DEG | % | CH | |
| 36 | 47 | C | 07H | TEC | | 029 | 720ZU | 07H+ | 32.5 | 1.44 | 0 | 28 | 18 |
| | | C | 07H | TEC | | 029 | 720ZU | NV2+ | 2.1 | 1.03 | 0 | 23 | 18 |
| | | C | 07H | TEC | | 029 | 720ZU | NV2+ | 32.4 | 0.86 | 0 | 20 | 18 |
| 39 | 47 | C | 07H | TEC | | 029 | 720ZU | NV2+ | 35.6 | 0.93 | 0 | 21 | 18 |
| | | C | 07H | TEC | | 029 | 720ZU | NV4+ | 3.1 | 1.07 | 0 | 23 | 18 |
| 35 | 48 | C | 07H | TEC | | 031 | 720ZU | NV2+ | 2.2 | 0.85 | 0 | 20 | 18 |
| 44 | 48 | C | 07H | TEC | | 031 | 720ZU | 01C- | 0.3 | 1.26 | 124 | 20 | 17 |
| 41 | 53 | C | 07H | TEC | | 037 | 720ZU | 01C- | 0.2 | 2.01 | 124 | 20 | 17 |
| 44 | 56 | C | 07H | TEC | | 041 | 720ZU | 01C- | 0.1 | 1.08 | 139 | 21 | 17 |
| 41 | 58 | C | 07H | TEC | | 060 | 720ZS | 01C- | 0.2 | 1.54 | 129 | 27 | 17 |
| 36 | 60 | C | 07H | TEC | | 044 | 720ZU | NV2+ | 2.7 | 1.03 | 0 | 25 | 18 |
| 21 | 61 | C | 07H | TEC | | 046 | 720ZU | NV2+ | 1.2 | 1.14 | 0 | 24 | 18 |
| | | C | 07H | TEC | | 046 | 720ZU | NV2+ | 16.2 | 0.90 | 0 | 21 | 18 |
| 23 | 61 | C | 07H | TEC | | 046 | 720ZU | NV2+ | 1.3 | 1.41 | 0 | 28 | 18 |
| | | C | 07H | TEC | | 046 | 720ZU | NV2+ | 18.1 | 0.95 | 0 | 22 | 18 |
| | | C | 07H | TEC | | 046 | 720ZU | NV4+ | 0.4 | 0.99 | 0 | 22 | 18 |
| 42 | 62 | C | 07H | TEC | | 046 | 720ZU | 01C+ | 0.0 | 1.35 | 125 | 21 | 17 |
| 42 | 63 | C | 07H | TEC | | 046 | 720ZU | 01C+ | 0.0 | 1.37 | 125 | 21 | 17 |
| 21 | 64 | C | 07H | TEC | | 048 | 720ZU | NV2+ | 16.9 | 1.15 | 0 | 25 | 18 |
| 26 | 69 | C | 07H | TEC | | 051 | 700ZS | 07H+ | 29.0 | 1.47 | 0 | 27 | 18 |
| | | C | 07H | TEC | | 051 | 700ZS | NV2+ | 23.2 | 1.34 | 0 | 26 | 18 |
| 18 | 71 | C | 07H | TEC | | 053 | 720ZU | 07H+ | 23.0 | 1.00 | 0 | 20 | 18 |
| | | C | 07H | TEC | | 053 | 720ZU | NV2+ | 13.4 | 1.09 | 0 | 22 | 18 |
| 26 | 72 | C | 07H | TEC | | 054 | 720ZU | NV2+ | 1.2 | 1.31 | 0 | 26 | 18 |
| 39 | 72 | C | 07H | TEC | | 054 | 720ZU | 01C+ | 0.0 | 2.62 | 135 | 21 | 17 |
| 34 | 76 | C | 07H | TEC | | 055 | 720ZU | 02C+ | 0.1 | 2.10 | 129 | 29 | 17 |

NSP

CUMULATIVE INDICATIONS REPORT
PRAIRIE ISLAND, UNIT 2

Generator: 21
Leg.....: Hot and Cold legs
Release..: 2.0
20% TO 29% for the entire length

Page: 3
Date: 09/28/90
Time: 9:01

| ROW | COL | LEG | EXTENT | | REM | REEL | PROBE | LOCATION | | CURRENT | | | |
|-----|-----|-----|--------|-----|-----|------|-------|----------|-----|---------|-----|-----|----|
| | | | BEG | END | | | | | | VOLTS | DEG | % | CH |
| 32 | 78 | C | 07H | TEC | | 057 | 720ZU | 02C+ | 0.0 | 3.04 | 133 | 25 | 17 |
| 29 | 84 | C | 07H | TEC | | 059 | 720ZU | 01C+ | 0.0 | 3.43 | 134 | 24 | 17 |
| 28 | 85 | C | 07H | TEC | | 059 | 720ZU | 02C+ | 0.0 | 2.45 | 131 | 28 | 17 |
| 12 | 90 | C | 07H | TEC | | 060 | 720ZS | 01C- | 0.2 | 2.24 | 132 | 21 | 17 |
| 9 | 92 | H | 01H | 01H | S | 092 | 720ZR | 01H+ | 0.3 | 4.05 | 151 | VOL | 4 |
| | | H | 07H | TEH | | 088 | 720ZW | 01H- | 0.1 | 0.55 | 126 | 23 | 17 |
| 14 | 92 | C | 07H | TEC | | 060 | 720ZS | NV1+ | 2.6 | 1.64 | 0 | 29 | 18 |
| 4 | 94 | C | 07H | TEC | | 071 | 700ZU | 02C- | 0.1 | 0.53 | 133 | 23 | 17 |
| 5 | 94 | C | 07H | TEC | | 071 | 700ZU | 01C+ | 0.0 | 1.68 | 124 | 27 | 17 |

NUMBER OF TUBES IN REPORT = 45

NSP

CUMULATIVE INDICATIONS REPORT
PRAIRIE ISLAND, UNIT 2

Generator: 21
Leg.....: Hot and Cold legs
Release...: 2.0

Page: Title page
Date: 09/28/90
Time: 10:17

Map selection criteria :

20% TO 29% for the entire length
Supplemental data : All except NDDs included
Plugs : None included
Selected indications only are included
Groups : All groups included

NSP

DATE: 09/28/90

TIME: 10:17

STEAM GENERATOR: 21

GROUPS: All groups included


20% TO 29% for the entire length

PRAIRIE ISLAND, UNIT 2

CUMULATIVE INDICATIONS REPORT-HOT AND COLD LEGS



20% TO 29% 45



CUMULATIVE INDICATIONS REPORT
PRAIRIE ISLAND, UNIT 2

Generator: 21
Leg.....: Hot and Cold legs
Release..: 2.0

Page: Title page
Date: 09/28/90
Time: 9:09

Report selection criteria :

30% TO 39% for the entire length
Supplemental data : All except NDDs included
Plugs : None included
Selected indications only are included
Groups : All groups included

Three column remarks field key :

Column 1=PID information
Column 2=Resolution file information
Column 3=Hold file information
"P" in Col 1=Positive identification retest condition exists
"S" In Col 1=Line contains supplemental data
"R" In Col 2=More data pending in resolution file
"H" In Col 3=More data pending in hold file

NSP

CUMULATIVE INDICATIONS REPORT
PRAIRIE ISLAND, UNIT 2

Generator: 21
Leg.....: Hot and Cold legs
Release..: 2.0
30% TO 39% for the entire length

Page: 1
Date: 09/28/90
Time: 9:09

| ROW | COL | LEG | EXTENT | | REM | REEL | PROBE | LOCATION | | CURRENT | | | |
|-----|-----|-----|--------|-----|-----|------|-------|----------|------|---------|-----|----|----|
| | | | BEG | END | | | | | | VOLTS | DEG | % | CH |
| 31 | 14 | C | 07H | TEC | | 060 | 720ZS | 01C+ | 0.0 | 2.78 | 124 | 34 | 17 |
| 35 | 17 | C | 07H | TEC | | 063 | 720ZU | 01C- | 0.2 | 4.10 | 121 | 38 | 17 |
| 25 | 33 | C | 07H | TEC | | 014 | 720ZU | NV2+ | 1.8 | 1.74 | 0 | 31 | 18 |
| | | C | 07H | TEC | | 014 | 720ZU | NV2+ | 20.8 | 1.71 | 0 | 31 | 18 |
| 45 | 36 | C | 07H | TEC | | 063 | 720ZU | 02C+ | 0.0 | 1.56 | 126 | 31 | 17 |
| 45 | 41 | C | 07H | TEC | | 021 | 720ZU | 01C- | 0.2 | 3.21 | 126 | 38 | 17 |
| 46 | 43 | C | 07H | TEC | | 022 | 720ZW | 01C- | 0.3 | 1.01 | 133 | 30 | 17 |
| 44 | 46 | C | 07H | TEC | | 029 | 720ZU | 01C+ | 0.0 | 6.23 | 125 | 37 | 17 |
| 35 | 48 | C | 07H | TEC | | 031 | 720ZU | 07H+ | 33.1 | 1.68 | 0 | 31 | 18 |
| 29 | 50 | C | 07H | TEC | | 033 | 720ZU | NV2+ | 1.3 | 1.69 | 0 | 33 | 18 |
| | | C | 07H | TEC | | 033 | 720ZU | NV2+ | 24.5 | 1.71 | 0 | 33 | 18 |
| 44 | 55 | C | 07H | TEC | | 039 | 720ZU | TSC+ | 5.8 | 2.40 | 137 | 39 | 1 |
| 43 | 58 | C | 07H | TEC | | 060 | 720ZS | 01C+ | 0.0 | 2.26 | 125 | 32 | 17 |
| 43 | 59 | C | 07H | TEC | | 060 | 720ZS | 01C+ | 0.0 | 2.54 | 125 | 32 | 17 |
| 39 | 71 | C | 07H | TEC | | 053 | 720ZU | 01C+ | 0.0 | 2.44 | 129 | 30 | 17 |
| 26 | 72 | C | 07H | TEC | | 054 | 720ZU | NV2+ | 21.9 | 1.76 | 0 | 31 | 18 |
| 38 | 74 | C | 07H | TEC | | 087 | 700ZS | 01C+ | 0.0 | 3.03 | 123 | 31 | 17 |
| 32 | 78 | C | 07H | TEC | | 057 | 720ZU | 01C- | 0.3 | 2.30 | 126 | 35 | 17 |
| 31 | 79 | C | 07H | TEC | | 057 | 720ZU | 01C+ | 0.0 | 4.06 | 124 | 38 | 17 |
| 6 | 80 | C | 07H | TEC | | 087 | 700ZS | TSC+ | 1.3 | 0.63 | 142 | 36 | 1 |
| 30 | 83 | C | 07H | TEC | | 058 | 720ZU | 01C- | 0.1 | 3.50 | 127 | 33 | 17 |
| 23 | 86 | C | 07H | TEC | | 059 | 720ZU | 01C+ | 0.0 | 2.86 | 129 | 31 | 17 |
| 24 | 86 | C | 07H | TEC | | 059 | 720ZU | 02C+ | 0.0 | 3.02 | 123 | 39 | 17 |

NSP

CUMULATIVE INDICATIONS REPORT
PRAIRIE ISLAND, UNIT 2

Generator: 21
 Leg.....: Hot and Cold legs
 Release..: 2.0
 30% TO 39% for the entire length

Page: 2
 Date: 09/28/90
 Time: 9:10

| ROW | COL | LEG | EXTENT | | REM | REEL | PROBE | LOCATION | | CURRENT | | | |
|-----|-----|-----|--------|-----|-----|------|-------|----------|-----|---------|-----|----|----|
| | | | BEG | END | | | | | | VOLTS | DEG | % | CH |
| 22 | 88 | C | 07H | TEC | | 059 | 720ZU | 01C+ | 0.0 | 1.97 | 123 | 39 | 17 |
| 7 | 91 | C | 07H | TEC | | 083 | 700ZS | 01C+ | 0.0 | 2.89 | 129 | 31 | 17 |
| 5 | 93 | C | 07H | TEC | | 071 | 700ZU | 01C+ | 0.1 | 1.25 | 125 | 32 | 17 |
| 6 | 93 | C | 07H | TEC | | 083 | 700ZS | 02C+ | 0.0 | 0.81 | 122 | 37 | 17 |
| 4 | 94 | C | 07H | TEC | | 071 | 700ZU | 01C- | 0.1 | 1.35 | 123 | 34 | 17 |
| 7 | 94 | C | 07H | TEC | | 083 | 700ZS | 01C+ | 0.1 | 0.92 | 127 | 34 | 17 |

NUMBER OF TUBES IN REPORT = 27

NSP

CUMULATIVE INDICATIONS REPORT
PRAIRIE ISLAND, UNIT 2

Generator: 21
Leg.....: Hot and Cold legs
Release..: 2.0

Page: Title page
Date: 09/28/90
Time: 10:34

Map selection criteria :

30% TO 39% for the entire length
Supplemental data : All except NDDs included
Plugs : None included
Selected indications only are included
Groups : All groups included

NSP

DATE: 09/28/90

TIME: 10:34

STEAM GENERATOR: 21

GROUPS: All groups included


30% TO 39% for the entire length

PRAIRIE ISLAND, UNIT 2

CUMULATIVE INDICATIONS REPORT-HOT AND COLD LEGS



Page 17 of 35



CUMULATIVE INDICATIONS REPORT
PRAIRIE ISLAND, UNIT 2

Generator: 21
Leg.....: Hot and Cold legs
Release..: 2.0

Page: Title page
Date: 09/28/90
Time: 9:17

Report selection criteria :

40% TO 100% for the entire length
Supplemental data : All except NDDs included
Plugs : None included
Selected indications only are included
Groups : All groups included

Three column remarks field key :

Column 1=PID information
Column 2=Resolution file information
Column 3=Hold file information
"P" in Col 1=Positive identification retest condition exists
"S" In Col 1=Line contains supplemental data
"R" In Col 2=More data pending in resolution file
"H" In Col 3=More data pending in hold file

NSP

CUMULATIVE INDICATIONS REPORT
PRAIRIE ISLAND, UNIT 2

Generator: 21
 Leg.....: Hot and Cold legs
 Release...: 2.0
 40% TO 100% for the entire length

Page: 1
 Date: 09/28/90
 Time: 9:17

| ROW | COL | LEG | EXTENT | | REM | REEL | PROBE | LOCATION | | CURRENT | | | |
|-----|-----|-----|--------|-----|-----|------|-------|----------|-----|---------|-----|----|----|
| | | | BEG | END | | | | | | VOLTS | DEG | % | CH |
| 30 | 12 | C | 07H | TEC | | 060 | 720ZS | 01C- | 0.2 | 4.29 | 116 | 45 | 17 |
| 30 | 13 | C | 07H | TEC | | 060 | 720ZS | 01C+ | 0.0 | 6.02 | 115 | 46 | 17 |
| 32 | 16 | C | 07H | TEC | | 060 | 720ZS | 01C+ | 0.0 | 4.96 | 110 | 51 | 17 |
| 35 | 18 | C | 07H | TEC | | 006 | 720ZU | 01C+ | 0.0 | 4.23 | 96 | 65 | 17 |
| 40 | 25 | C | 07H | TEC | | 011 | 720ZU | 01C+ | 0.0 | 3.43 | 86 | 65 | 17 |
| 45 | 38 | C | 07H | TEC | | 019 | 720ZU | 02C+ | 0.0 | 4.72 | 107 | 44 | 17 |
| 44 | 39 | C | 07H | TEC | | 019 | 720ZU | 01C- | 0.1 | 0.95 | 96 | 55 | 17 |
| 36 | 63 | C | 07H | TEC | | 048 | 720ZU | NV2+ | 2.7 | 2.78 | 0 | 40 | 18 |
| 37 | 72 | C | 07H | TEC | | 054 | 720ZU | 01C- | 0.2 | 4.83 | 120 | 42 | 17 |
| 36 | 76 | C | 07H | TEC | | 087 | 700ZS | 02C+ | 0.0 | 4.27 | 114 | 43 | 17 |
| 25 | 85 | C | 07H | TEC | | 059 | 720ZU | 01C- | 0.1 | 4.05 | 115 | 44 | 17 |
| 10 | 91 | C | 07H | TEC | | 060 | 720ZS | 01C+ | 0.0 | 2.66 | 116 | 44 | 17 |

NUMBER OF TUBES IN REPORT = 12

NSP

CUMULATIVE INDICATIONS REPORT
PRAIRIE ISLAND, UNIT 2

Generator: 21
Leg.....: Hot and Cold legs
Release..: 2.0

Page: Title page
Date: 09/28/90
Time: 10:38

Map selection criteria :

40% TO 100% for the entire length
Supplemental data : All except NDI's included
Plugs : None included
Selected indications only are included
Groups : All groups included

NSP



PRAIRIE ISLAND, UNIT 2


CUMULATIVE INDICATIONS REPORT-HOT AND COLD LEGS

DATE: 09/28/90
TIME: 10:38

STEAM GENERATOR: 21

GROUPS: All groups included

40% TO 100% for the entire length



MSSP-PPM

ISI-EI-1

CUMULATIVE INDICATIONS REPORT
PRAIRIE ISLAND, UNIT 2

Generator: 21
Leg.....: Hot and Cold legs
Release..: 2.0

Page: Title page
Date: 09/28/90
Time: 9:28

Report selection criteria :

Supplemental data : None included
Plugs : Only current included
Selected indications only are included
Groups : All groups included

Three column remarks field key :

Column 1=PID information
Column 2=Resolution file information
Column 3=Hold file information
"P" in Col 1=Positive identification retest condition exists
"S" In Col 1=Line contains supplemental data
"R" In Col 2=More data pending in resolution file
"H" In Col 3=More data pending in hold file

NSP

CUMULATIVE INDICATIONS REPORT
PRAIRIE ISLAND, UNIT 2

Generator: 21
 Leg.....: Hot and Cold legs
 Release...: 2.0
 See title page for report selection criteria.

Page: 1
 Date: 09/28/90
 Time: 9:28

| ROW | COL | LEG | EXTENT | | REM | REEL | PROBE | LOCATION | CURRENT | | | | |
|-----|-----|--------|--------|-----|-----|------|-------|----------------|---------|-----|---|------------|--|
| | | | BEG | END | | | | | VCLTS | DEG | % | CH | |
| 30 | 12 | H C | | | | | | 09/90 09/90 | | | | PLG PLG | |
| 30 | 13 | H C | | | | | | 09/90 09/90 | | | | PLG PLG | |
| 32 | 16 | H C | | | | | | 09/90 09/90 | | | | PLG PLG | |
| 35 | 18 | H C | | | | | | 09/90 09/90 | | | | PLG PLG | |
| 40 | 25 | H C | | | | | | 09/90 09/90 | | | | PLG PLG | |
| 45 | 38 | H C | | | | | | 09/90 09/90 | | | | PLG PLG | |
| 44 | 39 | H C | | | | | | 09/90 09/90 | | | | PLG PLG | |
| 44 | 53 | H | | | | | | 09/90 | | | | PLG | |
| 42 | 61 | H | | | | | | 09/90 | | | | PLG | |
| 37 | 72 | H C | | | | | | 09/90 09/90 | | | | PLG PLG | |
| 39 | 73 | H | | | | | | 09/90 | | | | PLG | |
| 36 | 76 | H C | | | | | | 09/90 09/90 | | | | PLG PLG | |
| 25 | 85 | H C | | | | | | 09/90 09/90 | | | | PLG PLG | |
| 21 | 88 | H | | | | | | 09/90 | | | | PLG | |
| 19 | 89 | H | | | | | | 09/90 | | | | PLG | |
| 14 | 90 | H | | | | | | 09/90 | | | | PLG | |
| 10 | 91 | H | | | | | | 09/90 | | | | PLG | |

NSP

CUMULATIVE INDICATIONS REPORT
PRAIRIE ISLAND, UNIT 2

Generator: 21
 Leg.....: Hot and Cold legs
 Release..: 2.0
 See title page for report selection criteria.

Page: 2
 Date: 09/28/90
 Time: 9:29

| ROW | COL | LEG | EXTENT | | REM | REEL | PROBE | LOCATION | CURRENT | | | |
|-----|-----|-----|--------|-----|-----|------|-------|----------|---------|-----|---|-----|
| | | | BEG | END | | | | | VOLTS | DEG | % | CH |
| 10 | 91 | C | | | | | | 19/90 | | | | FLG |

NUMBER OF TUBES IN REPORT = 17

NSP

CUMULATIVE INDICATIONS REPORT
PRAIRIE ISLAND, UNIT 2

Generator: 21
Leg.....: Hot and Cold legs
Release..: 2.0

Page: Title page
Date: 09/28/90
Time: 10:40

Map selection criteria :


Supplemental data : None included
Plugs : Only current included
Selected indications only are included
Groups : All groups included

NSP

DATE: 09/28/90
 TIME: 10:40
 STEAM GENERATOR: 21
 GROUPS: All groups included

PRAIRIE ISLAND, UNIT 2

CUMULATIVE INDICATIONS REPORT-HOT AND COLD LESS



CUMULATIVE INDICATIONS REPORT
PRAIRIE ISLAND, UNIT 2

Generator: 21
Leg.....: Hot and Cold legs
Release...: 2.0

Page: Title page
Date: 09/28/90
Time: 9:31

Report selection criteria :

Supplemental data : None included
Plugs : All included
Selected indications only are included
Groups : All groups included

Three column remarks field key :

Column 1=PID information
Column 2=Resolution file information
Column 3=Hold file information
"P" in Col 1=Positive identification retest condition exists
"S" In Col 1=Line contains supplemental data
"R" In Col 2=More data pending in resolution file
"H" In Col 3=More data pending in hold file

NSP

CUMULATIVE INDICATIONS REPORT
PRAIRIE ISLAND, UNIT 2

Generator: 21
 Leg.....: Hot and Cold legs
 Release...: 2.0
 See title page for report selection criteria.

Page: 1
 Date: 09/28/90
 Time: 9:31

| ROW | COL | LEG | EXTENT | | REM | REEL | PROBE | LOCATION | CURRENT | | | | |
|-----|-----|--------|--------|-----|-----|------|-------|----------------|---------|-----|---|------------|--|
| | | | BEG | END | | | | | VOLTS | DEG | % | CH | |
| 1 | 1 | H C | | | | | | 01/80 01/80 | | | | PLG PLG | |
| 23 | 8 | H C | | | | | | 06/82 06/82 | | | | PLG PLG | |
| 28 | 11 | H C | | | | | | 02/81 02/81 | | | | PLG PLG | |
| 30 | 12 | H C | | | | | | 09/90 09/90 | | | | PLG PLG | |
| 30 | 13 | H C | | | | | | 09/90 09/90 | | | | PLG PLG | |
| 32 | 16 | H C | | | | | | 09/90 09/90 | | | | PLG PLG | |
| 35 | 18 | H C | | | | | | 09/90 09/90 | | | | PLG PLG | |
| 36 | 19 | H C | | | | | | 08/83 08/83 | | | | PLG PLG | |
| 3 | 21 | H C | | | | | | 03/89 03/89 | | | | PLG PLG | |
| 13 | 23 | H C | | | | | | 06/82 06/82 | | | | PLG PLG | |
| 39 | 25 | H C | | | | | | 09/84 09/84 | | | | PLG PLG | |
| 40 | 25 | H C | | | | | | 09/90 09/90 | | | | PLG PLG | |
| 39 | 26 | H C | | | | | | 06/82 06/82 | | | | PLG PLG | |
| 40 | 26 | H C | | | | | | 09/85 09/85 | | | | PLG PLG | |
| 25 | 28 | H | | | | | | 06/82 | | | | PLG | |

NSP

CUMULATIVE INDICATIONS REPORT
PRAIRIE ISLAND, UNIT 2

Generator: 21
 Leg.....: Hot and Cold legs
 Release..: 2.0
 See title page for report selection criteria.

Page: 2
 Date: 09/28/90
 Time: 9:31

| ROW | COL | LEG | EXTENT | | REM | REEL | PROBE | LOCATION | CURRENT | | | | |
|-----|-----|--------|--------|-----|-----|------|-------|----------------|---------|-----|---|------------|--|
| | | | BEG | END | | | | | VOLTS | DEG | % | CH | |
| 25 | 28 | C | | | | | | 06/82 | | | | PLG | |
| 41 | 28 | H C | | | | | | 09/84 09/84 | | | | PLG PLG | |
| 42 | 28 | H C | | | | | | 09/84 09/84 | | | | PLG PLG | |
| 42 | 29 | H C | | | | | | 09/85 09/85 | | | | PLG PLG | |
| 41 | 30 | H C | | | | | | 09/85 09/85 | | | | PLG PLG | |
| 43 | 33 | H C | | | | | | 02/81 02/81 | | | | PLG PLG | |
| 25 | 34 | H C | | | | | | 09/84 09/84 | | | | PLG PLG | |
| 29 | 37 | H C | | | | | | 09/84 09/84 | | | | PLG PLG | |
| 45 | 37 | H C | | | | | | 09/84 09/84 | | | | PLG PLG | |
| 45 | 38 | H C | | | | | | 09/90 09/90 | | | | PLG PLG | |
| 44 | 39 | H C | | | | | | 09/90 09/90 | | | | PLG PLG | |
| 45 | 39 | H C | | | | | | 08/83 08/83 | | | | PLG PLG | |
| 45 | 40 | H C | | | | | | 09/84 09/84 | | | | PLG PLG | |
| 43 | 41 | H C | | | | | | 09/84 09/84 | | | | PLG PLG | |
| 43 | 42 | H | | | | | | 03/89 | | | | PLG | |

NSP

CUMULATIVE INDICATIONS REPORT
PRAIRIE ISLAND, UNIT 2

Generator: 21
Leg.....: Hot and Cold legs
Release...: 2.0
See title page for report selection criteria.

Page: 3
Date: 09/28/90
Time: 9:32

| ROW | COL | LEG | EXTENT | | REM | REEL | PROBE | LOCATION | CURRENT | | | |
|-----|-----|--------|--------|-----|-----|------|-------|----------------|---------|-----|---|------------|
| | | | BEG | END | | | | | VOLTS | DEG | % | CH |
| 43 | 42 | C | | | | | | 03/89 | | | | PLG |
| 44 | 43 | H C | | | | | | 09/85 09/85 | | | | PLG PLG |
| 36 | 44 | H C | | | | | | 09/84 09/84 | | | | PLG PLG |
| 45 | 44 | H C | | | | | | 08/83 08/83 | | | | PLG PLG |
| 29 | 45 | H C | | | | | | 06/82 06/82 | | | | PLG PLG |
| 23 | 46 | H C | | | | | | 06/82 06/82 | | | | PLG PLG |
| 45 | 46 | H C | | | | | | 09/84 09/84 | | | | PLG PLG |
| 29 | 48 | H C | | | | | | 06/82 06/82 | | | | PLG PLG |
| 45 | 49 | H C | | | | | | 06/82 06/82 | | | | PLG PLG |
| 44 | 52 | H C | | | | | | 09/84 09/84 | | | | PLG PLG |
| 45 | 52 | H C | | | | | | 06/82 06/82 | | | | PLG PLG |
| 46 | 52 | H C | | | | | | 02/81 02/81 | | | | PLG PLG |
| 44 | 53 | C H | | | | | | 01/88 09/90 | | | | PLG PLG |
| 46 | 53 | H C | | | | | | 06/82 06/82 | | | | PLG PLG |
| 44 | 54 | H | | | | | | 09/84 | | | | PLG |

NSP

CUMULATIVE INDICATIONS REPORT
PRAIRIE ISLAND, UNIT 2

Generator: 21
 Leg.....: Hot and Cold legs
 Release...: 2.0
 See title page for report selection criteria.

Page: 4
 Date: 09/28/90
 Time: 9:32

| ROW | COL | LEG | EXTENT | | REM | REEL | PROBE | LOCATION | CURRENT | | | CH |
|-----|-----|--------|--------|-----|-----|------|-------|----------------|---------|-----|---|------------|
| | | | BEG | END | | | | | VOLTS | DEG | % | |
| 44 | 54 | C | | | | | | 09/84 | | | | PLG |
| 45 | 54 | H C | | | | | | 09/84 09/84 | | | | PLG PLG |
| 44 | 57 | H C | | | | | | 08/83 08/83 | | | | PLG PLG |
| 25 | 58 | H C | | | | | | 06/82 06/82 | | | | PLG PLG |
| 44 | 59 | H C | | | | | | 02/81 02/81 | | | | PLG PLG |
| 45 | 59 | H C | | | | | | 03/89 03/89 | | | | PLG PLG |
| 44 | 60 | H C | | | | | | 06/82 06/82 | | | | PLG PLG |
| 42 | 61 | H C | | | | | | 09/90 10/86 | | | | PLG PLG |
| 43 | 62 | H C | | | | | | 09/84 09/84 | | | | PLG PLG |
| 43 | 63 | H C | | | | | | 08/83 08/83 | | | | PLG PLG |
| 41 | 67 | H C | | | | | | 09/84 09/84 | | | | PLG PLG |
| 27 | 69 | H C | | | | | | 09/84 09/84 | | | | PLG PLG |
| 40 | 69 | H C | | | | | | 09/84 09/84 | | | | PLG PLG |
| 39 | 70 | H C | | | | | | 06/82 06/82 | | | | PLG PLG |
| 37 | 72 | H | | | | | | 09/90 | | | | PLG |

NSP

CUMULATIVE INDICATIONS REPORT
PRAIRIE ISLAND, UNIT 2

Generator: 21
Leg.....: Hot and Cold legs
Release..: 2.0
See title page for report selection criteria.

Page: 5
Date: 09/28/90
Time: 9:32

| ROW | COL | LEG | EXTENT | | REM | REEL | PROBE | LOCATION | CURRENT | | | |
|-----|-----|--------|--------|-----|-----|------|-------|----------------|---------|-----|------------|----|
| | | | BEG | END | | | | | VOLTS | DEG | % | CH |
| 37 | 72 | C | | | | | | 09/90 | | | PLG | |
| 39 | 73 | H C | | | | | | 09/90 10/86 | | | PLG PLG | |
| 36 | 76 | H C | | | | | | 09/90 09/90 | | | PLG PLG | |
| 37 | 76 | H C | | | | | | 09/84 09/84 | | | PLG PLG | |
| 35 | 78 | H C | | | | | | 01/80 01/80 | | | PLG PLG | |
| 1 | 79 | H C | | | | | | 09/85 09/85 | | | PLG PLG | |
| 32 | 79 | H C | | | | | | 06/82 06/82 | | | PLG PLG | |
| 21 | 85 | H C | | | | | | 09/85 09/85 | | | PLG PLG | |
| 25 | 85 | H C | | | | | | 09/90 09/90 | | | PLG PLG | |
| 20 | 87 | H C | | | | | | 09/84 09/84 | | | PLG PLG | |
| 21 | 88 | C H | | | | | | 01/88 09/90 | | | PLG PLG | |
| 18 | 89 | H C | | | | | | 09/85 09/85 | | | PLG PLG | |
| 19 | 89 | H C | | | | | | 09/90 10/86 | | | PLG PLG | |
| 14 | 90 | H C | | | | | | 09/90 10/86 | | | PLG PLG | |
| 9 | 91 | H | | | | | | 06/82 | | | PLG | |

NSP

CUMULATIVE INDICATIONS REPORT
PRAIRIE ISLAND, UNIT 2

Generator: 21
 Leg.....: Hot and Cold legs
 Release...: 2.0
 See title page for report selection criteria.

Page: 6
 Date: 09/28/90
 Time: 9:32

| ROW | COL | LEG | EXTENT | | REM | REEL | PROBE | LOCATION | CURRENT | | | | |
|-----|-----|-----|--------|-----|-----|------|-------|----------|---------|-----|---|-----|--|
| | | | BEG | END | | | | | VOLTS | DEG | % | CH | |
| 9 | 91 | C | | | | | | 06/82 | | | | PLG | |
| 10 | 91 | H | | | | | | 09/90 | | | | PLG | |
| | | C | | | | | | 09/90 | | | | PLG | |
| 1 | 94 | H | | | | | | 01/80 | | | | PLG | |
| | | C | | | | | | 01/80 | | | | PLG | |

NUMBER OF TUBES IN REPORT = 73

NSP

CUMULATIVE INDICATIONS REPORT
PRAIRIE ISLAND, UNIT 2

Generator: 21
Leg.....: Hot and Cold legs
Release..: 2.0

Page: Title page
Date: 08/28/90
Time: 10:43

Map selection criteria :

Supplemental data : None included
Plugs : All included
Selected indications only are included
Groups : All groups included

NSP



PRAIRIE ISLAND, UNIT 2


CUMULATIVE INDICATIONS REPORT-HOT AND COLD LEGS

DATE: 09/28/90

TIME: 10:43

STEAM GENERATOR: 21

GROUPS: All groups included



APPENDIX G

STEAM GENERATOR NO. 22

EDDY CURRENT TUBE SHEET MAPS AND CUMULATIVE DATA REPORTS

LEGEND OF FIELDS AND CODES

| <u>FIELD</u> | <u>EXPLANATION</u> |
|--------------|---|
| ROW | Row number of tube location |
| COL | Column number of tube location |
| LEG | Channel head tested from |
| BEG | Beginning extent of test |
| END | Ending extent of test |
| REM | Remarks |
| REEL | Reel number where data is located |
| PROBE | Probe size, manufacturer and type used |
| LOCATION | Location of call or date plug installed |
| VOLTS | Voltage of signal |
| DEG | Degree of signal |
| % | Measured percent through wall depth |
| CH | Channel used for measurement |

| <u>FIELD</u> | <u>CODE</u> | <u>EXPLANATION</u> |
|-----------------------|-------------|--|
| LEG | C | Cold leg |
| | H | Hot leg |
| PROBE | *** | Probe nominal diameter |
| | ZW | Wide groove ULC manufactured by Zetec |
| | ZU | Standard ULC manufactured by Zetec |
| | ZS | Spring flex ULC manufactured by Zetec |
| | ZR | Rotating pancake coil by Zetec |
| BEG, END, LOCATION | TEH | Tube end hot (primary face) |
| | TOR | Top of roll expansion |
| | TSH | Tube sheet hot (secondary face) |
| | O1H | First support plate on hot leg side |
| | *** | Second through sixth locations |
| | O7H | Seventh support plate on hot leg side |
| | NV1 | First new antivibration bar |
| | *** | Second and third locations |
| | NV4 | Fourth new antivibration bar |
| | O7C | Seventh support plate on cold leg side |
| | *** | Sixth through second locations |
| | O1C | First support plate on cold leg side |
| | TSC | Tube sheet cold (secondary face) |
| | TOR | Top of roll expansion |
| | TEC | Tube end cold (primary face) |
| REM | | Key supplied with each report |
| % | PLG | Plugged tube |
| | MBM | Manufacturing Burnish Mark |
| | VOL | Volumetric Indication |
| CH | ** | channel number |

CUMULATIVE INDICATIONS REPORT
PRAIRIE ISLAND, UNIT 2

Generator: 22
Leg.....: Hot and Cold legs
Release..: 2.0

Page: Title page
Date: 09/28/90
Time: 9:37

Report selection criteria :

0% TO 19% for the entire length
Supplemental data : All except NDDs included
Plugs : None included
Selected indications only are included
Groups : All groups included

Three column remarks field key :

Column 1=PID information
Column 2=Resolution file information
Column 3=Hold file information
"P" in Col 1=Positive identification retest condition exists
"S" In Col 1=Line contains supplemental data
"R" In Col 2=More data pending in resolution file
"H" In Col 3=More data pending in hold file

NSP

CUMULATIVE INDICATIONS REPORT
PRAIRIE ISLAND, UNIT 2

Generator: 22
 Leg.....: Hot and Cold legs
 Release..: 2.0
 0% TO 19% for the entire length

Page: 1
 Date: 09/28/90
 Time: 9:37

| ROW | COL | LEG | EXTENT | | REM | REEL | PROBE | LOCATION | | CURRENT | | | |
|-----|-----|-----|--------|-----|-----|------|-------|----------|-----|---------|-----|-----|----|
| | | | BEG | END | | | | | | VOLTS | DEG | % | CH |
| 17 | 5 | C | 07H | TEC | | 001 | 720ZU | 01C+ | 0.1 | 1.31 | 145 | 11 | 17 |
| 19 | 6 | C | 07H | TEC | | 001 | 720ZU | 02C+ | 0.1 | 1.47 | 147 | 16 | 17 |
| 21 | 7 | C | 07H | TEC | | 003 | 720ZU | 01C+ | 0.0 | 1.15 | 145 | 11 | 17 |
| | | C | 01C | 01C | S | 101 | 720ZR | 01C- | 0.0 | 1.39 | 159 | VOL | 1 |
| | | C | 07H | TEC | | 003 | 720ZU | 02C+ | 0.0 | 1.30 | 145 | 18 | 17 |
| | | C | 02C | 02C | S | 101 | 720ZR | 02C+ | 0.2 | 1.65 | 140 | VOL | 1 |
| 28 | 11 | C | 07H | TEC | | 003 | 720ZU | 02C+ | 0.1 | 0.80 | 149 | 18 | 17 |
| 29 | 12 | H | TSC | TEH | | 106 | 700ZS | 02C+ | 0.2 | 0.64 | 139 | 7 | 17 |
| 34 | 17 | C | 07H | TEC | | 056 | 720ZU | 01C- | 0.1 | 1.85 | 138 | 12 | 17 |
| 30 | 19 | C | 07H | TEC | | 056 | 720ZU | 01C- | 0.2 | 1.15 | 143 | 2 | 17 |
| 31 | 19 | C | 01C | 01C | S | 101 | 720ZR | 01C+ | 0.1 | 1.48 | 143 | VOL | 1 |
| | | C | 07H | TEC | | 056 | 720ZU | 01C- | 0.3 | 1.82 | 139 | 10 | 17 |
| 39 | 25 | H | TSC | TEH | | 106 | 700ZS | 01C+ | 0.3 | 1.94 | 148 | 9 | 17 |
| 39 | 29 | C | 07H | TEC | | 056 | 720ZU | 02C+ | 0.0 | 0.81 | 136 | 15 | 17 |
| | | C | 02C | 02C | S | 101 | 720ZR | 02C+ | 0.0 | 0.67 | 119 | VOL | 1 |
| 19 | 34 | C | 07H | TEC | | 014 | 720ZU | NV1+ | 0.0 | 0.54 | 0 | 14 | 18 |
| 44 | 36 | C | 07H | TEC | | 016 | 720ZU | 02C- | 0.3 | 1.27 | 135 | 10 | 17 |
| 44 | 38 | C | 07H | TEC | | 018 | 720ZU | 02C+ | 0.0 | 2.72 | 135 | 14 | 17 |
| 45 | 38 | C | 01C | 01C | S | 103 | 720ZR | 01C+ | 0.0 | 2.24 | 175 | VOL | 2 |
| | | C | 07H | TEC | | 018 | 720ZU | 02C- | 0.2 | 0.74 | 145 | 2 | 17 |
| 44 | 39 | C | 07H | TEC | | 018 | 720ZU | 02C- | 0.1 | 0.92 | 136 | 18 | 17 |
| 45 | 41 | C | 07H | TEC | | 020 | 720ZU | 01C- | 0.1 | 1.71 | 135 | 8 | 17 |
| | | C | 07H | TEC | | 020 | 720ZU | 02C+ | 0.0 | 0.72 | 134 | 10 | 17 |
| 44 | 42 | C | 07H | TEC | | 021 | 720ZU | 02C- | 0.1 | 4.62 | 137 | 2 | 17 |
| 46 | 42 | C | 07H | TEC | | 021 | 720ZU | 02C- | 0.1 | 4.05 | 132 | 15 | 17 |

NSP

CUMULATIVE INDICATIONS REPORT
PRAIRIE ISLAND, UNIT 2

Generator: 22
Leg.....: Hot and Cold legs
Release...: 2.0

Page: 2
Date: 09/28/90
Time: 9:37

0% TO 19% for the entire length

| ROW | COL | LEG | EXTENT | | REM | REEL | PROBE | LOCATION | | CURRENT | | | |
|-----|-----|-----|--------|-----|-----|------|-------|----------|------|---------|-----|-----|----|
| | | | BEG | END | | | | | | VOLTS | DEG | % | CH |
| 38 | 46 | C | 07H | TEC | | 024 | 720ZU | NV4+ | 3.0 | 0.98 | 0 | 19 | 18 |
| 44 | 48 | C | 07H | TEC | | 025 | 720ZU | 01C- | 0.0 | 1.35 | 153 | 18 | 17 |
| 45 | 54 | C | 07H | TEC | | 032 | 720ZU | 01C+ | 0.0 | 1.22 | 143 | 15 | 17 |
| | | C | 07H | TEC | | 032 | 720ZU | 02C+ | 0.0 | 0.89 | 145 | 11 | 17 |
| 42 | 56 | C | 07H | TEC | | 034 | 720ZU | 02C- | 0.0 | 0.78 | 139 | 16 | 17 |
| 43 | 57 | C | 07H | TEC | | 034 | 720ZU | 01C- | 0.2 | 0.74 | 146 | 12 | 17 |
| 45 | 57 | C | 07H | TEC | | 034 | 720ZU | 01C- | 0.1 | 1.10 | 146 | 9 | 17 |
| 41 | 60 | C | 07H | TEC | | 037 | 720ZU | 02C- | 0.0 | 1.56 | 127 | 18 | 17 |
| 42 | 60 | C | 07H | TEC | | 037 | 720ZU | 01C- | 0.1 | 1.26 | 157 | 12 | 17 |
| | | C | 07H | TEC | | 037 | 720ZU | 02C- | 0.2 | 1.35 | 145 | 11 | 17 |
| 43 | 63 | C | 07H | TEC | | 038 | 720ZU | 02C- | 0.3 | 1.46 | 145 | 19 | 17 |
| 40 | 66 | C | 07H | TEC | | 039 | 720ZU | 02C+ | 0.1 | 1.64 | 145 | 17 | 17 |
| 38 | 71 | C | 07H | TEC | | 044 | 720ZU | 02C- | 0.1 | 0.57 | 137 | 4 | 17 |
| 36 | 72 | C | 07H | TEC | | 045 | 720ZU | 02C- | 0.1 | 0.52 | 139 | 7 | 17 |
| 32 | 76 | C | 07H | TEC | | 047 | 720ZU | 02C+ | 0.0 | 0.21 | 139 | 2 | 17 |
| 33 | 76 | C | 07H | TEC | | 047 | 720ZU | 01C+ | 0.0 | 1.85 | 133 | 15 | 17 |
| 30 | 79 | C | 07H | TEC | | 048 | 720ZU | 01C+ | 0.0 | 1.41 | 131 | 10 | 17 |
| 17 | 83 | H | 07H | TEH | | 091 | 720ZW | 04H+ | 44.5 | 1.47 | 158 | 15 | 1 |
| | | H | 05H | 04H | S | 102 | 720ZR | 04H+ | 44.5 | 2.95 | 295 | MBM | 4 |
| 24 | 85 | C | 07H | TEC | | 052 | 720ZU | 01C- | 0.1 | 0.72 | 142 | 14 | 17 |
| 14 | 88 | C | 07H | TEC | | 054 | 720ZU | 02C+ | 0.0 | 1.65 | 139 | 12 | 17 |
| 22 | 88 | C | 07H | TEC | | 054 | 720ZU | 02C+ | 0.0 | 2.31 | 137 | 14 | 17 |
| 17 | 89 | C | 07H | TEC | | 054 | 720ZU | 01C- | 0.1 | 1.69 | 143 | 2 | 17 |

NSP

CUMULATIVE INDICATIONS REPORT
PRAIRIE ISLAND, UNIT 2

Generator: 22
 Leg.....: Hot and Cold legs
 Release...: 2.0 *
 0% TO 19% for the entire length

Page: 3
 Date: 09/28/90
 Time: 9:37

| ROW | COL | LEG | EXTENT | | REM | REEL | PROBE | LOCATION | | CURRENT | | | |
|-----|-----|-----|--------|-----|-----|------|-------|----------|-----|---------|-----|----|----|
| | | | BEG | END | | | | | | VOLTS | DEG | % | CH |
| 16 | 90 | C | 07H | TEC | | 054 | 720ZU | 01C+ | 0.0 | 1.61 | 135 | 18 | 17 |
| 1 | 91 | C | 07C | TEC | | 081 | 700ZS | 01C+ | 0.1 | 1.08 | 141 | 1 | 17 |
| 12 | 91 | C | 07H | TEC | | 054 | 720ZU | 01C+ | 0.1 | 1.27 | 144 | 2 | 17 |
| 1 | 92 | C | 07C | TEC | | 081 | 700ZS | 01C+ | 0.1 | 0.92 | 142 | 6 | 17 |
| 6 | 92 | C | 07H | TEC | | 079 | 700ZW | 02C+ | 0.0 | 1.62 | 142 | 9 | 17 |

NUMBER OF TUBES IN REPORT = 43

NSP

CUMULATIVE INDICATIONS REPORT
PRAIRIE ISLAND, UNIT 2

Generator: 22
Leg.....: Hot and Cold legs
Release..: 2.0

Page: Title page
Date: 09/28/90
Time: 10:10

Map selection criteria :

0% TO 19% for the entire length
Supplemental data : All except NDDs included
Plugs : None included
Selected indications only are included
Groups : All groups included

NSP

DATE: 09/28/90

TIME: 10:10

STEAM GENERATOR: 22

GROUPS: All groups included

0% TO 19% for the entire length


PRAIRIE ISLAND, UNIT 2

CUMULATIVE INDICATIONS REPORT-HOT AND COLD LEGS



0% TO 19% 45

Page 7 of 44



CUMULATIVE INDICATIONS REPORT
PRAIRIE ISLAND, UNIT 2

Generator: 22
Leg.....: Hot and Cold legs
Release..: 2.0

Page: Title page
Date: 09/28/90
Time: 9:40

Report selection criteria :

20% TO 29% for the entire length
Supplemental data : All except NDDs included
Plugs : None included
Selected indications only are included
Groups : All groups included

Three column remarks field key :

Column 1=PID information
Column 2=Resolution file information
Column 3=Hold file information
"P" in Col 1=Positive identification retest condition exists
"S" In Col 1=Line contains supplemental data
"R" In Col 2=More data pending in resolution file
"H" In Col 3=More data pending in hold file

NSP

CUMULATIVE INDICATIONS REPORT
PRAIRIE ISLAND, UNIT 2

Generator: 22
Leg.....: Hot and Cold legs
Release..: 2.0
20% TO 29% for the entire length

Page: 1
Date: 09/28/90
Time: 9:40

| ROW | COL | LEG | EXTENT | | REM | REEL | PROBE | LOCATION | | CURRENT | | | |
|-----|-----|-----|--------|-----|-----|------|-------|----------|------|---------|-----|-----|----|
| | | | BEG | END | | | | | | VOLTS | DEG | % | CH |
| 12 | 3 | C | 06H | TEC | | 001 | 720ZU | 02C+ | 0.0 | 2.45 | 143 | 20 | 17 |
| 16 | 4 | C | 07H | TEC | | 001 | 720ZU | 01C+ | 0.1 | 2.38 | 136 | 20 | 17 |
| 20 | 6 | C | 07H | TEC | | 001 | 720ZU | 01C+ | 0.1 | 1.59 | 132 | 29 | 17 |
| 20 | 10 | C | 07H | TEC | | 003 | 720ZU | 01C- | 0.0 | 1.43 | 138 | 29 | 17 |
| 28 | 12 | C | 07H | TEC | | 003 | 720ZU | 01C- | 0.1 | 1.06 | 140 | 27 | 17 |
| 29 | 13 | C | 07H | TEC | | 056 | 720ZU | 01C+ | 0.0 | 1.03 | 130 | 25 | 17 |
| 31 | 13 | C | 07H | TEC | | 056 | 720ZU | 01C+ | 0.0 | 2.07 | 132 | 22 | 17 |
| 34 | 16 | C | 07H | TEC | | 005 | 720ZU | 02C+ | 0.0 | 1.14 | 147 | 20 | 17 |
| | | C | 02C | 02C | S | 101 | 720ZR | 02C- | 0.0 | 1.25 | 146 | VOL | 1 |
| 34 | 17 | C | 07H | TEC | | 056 | 720ZU | 02C- | 0.1 | 0.83 | 127 | 29 | 17 |
| 30 | 21 | C | 07H | TEC | | 007 | 720ZU | 01C+ | 0.1 | 1.01 | 139 | 24 | 17 |
| | | C | 01C | 01C | S | 101 | 720ZR | 01C- | 0.0 | 1.10 | 146 | VOL | 1 |
| 37 | 24 | C | 07H | TEC | | 007 | 720ZU | 01C- | 0.2 | 1.44 | 135 | 29 | 17 |
| | | C | 01C | 01C | S | 101 | 720ZR | 01C- | 0.2 | 1.68 | 131 | VOL | 1 |
| 38 | 25 | C | 07H | TEC | | 009 | 720ZU | 01C+ | 0.1 | 1.27 | 141 | 23 | 17 |
| 40 | 26 | C | 07H | TEC | | 010 | 720ZU | 01C+ | 0.1 | 1.72 | 139 | 29 | 17 |
| 38 | 27 | C | 07H | TEC | | 010 | 720ZU | 02C- | 0.1 | 0.39 | 144 | 26 | 17 |
| 38 | 36 | C | 07H | TEC | | 016 | 720ZU | NV2+ | 2.3 | 1.00 | 0 | 23 | 18 |
| | | C | 07H | TEC | | 016 | 720ZU | NV2+ | 31.9 | 0.80 | 0 | 20 | 18 |
| 45 | 39 | C | 07H | TEC | | 018 | 720ZU | 02C+ | 0.0 | 3.15 | 129 | 26 | 17 |
| 24 | 41 | C | 07H | TEC | | 020 | 720ZU | 07H+ | 22.7 | 1.13 | 0 | 22 | 18 |
| 37 | 43 | C | 07H | TEC | | 021 | 720ZU | NV2+ | 32.8 | 1.70 | 0 | 29 | 18 |
| | | C | 07H | TEC | | 021 | 720ZU | NV4+ | 3.7 | 1.37 | 0 | 25 | 18 |
| 38 | 46 | C | 07H | TEC | | 024 | 720ZU | 07H+ | 36.2 | 1.16 | 0 | 22 | 18 |

NSP

CUMULATIVE INDICATIONS REPORT
PRAIRIE ISLAND, UNIT 2

Generator: 22
 Leg.....: Hot and Cold legs
 Release..: 2.0
 20% TO 29% for the entire length

Page: 2
 Date: 09/28/90
 Time: 9:40

| ROW | COL | LEG | EXTENT | | REM | REEL | PROBE | LOCATION | | CURRENT | | | |
|-----|-----|-----|--------|-----|-----|------|-------|----------|------|---------|-----|-----|----|
| | | | BEG | END | | | | | | VOLTS | DEG | % | CH |
| 37 | 47 | C | 07H | TEC | | 024 | 720ZU | NV4+ | 3.2 | 1.61 | 0 | 28 | 18 |
| 40 | 47 | C | 07H | TEC | | 024 | 720ZU | 07H+ | 35.2 | 1.08 | 0 | 21 | 18 |
| | | C | 07H | TEC | | 024 | 720ZU | NV2+ | 3.0 | 1.19 | 0 | 22 | 18 |
| | | C | 07H | TEC | | 024 | 720ZU | NV2+ | 36.4 | 1.30 | 0 | 24 | 18 |
| 38 | 48 | C | 07H | TEC | | 025 | 720ZU | NV2+ | 2.1 | 1.20 | 0 | 24 | 18 |
| 33 | 50 | C | 07H | TEC | | 028 | 720ZU | NV2+ | 27.6 | 1.10 | 0 | 22 | 18 |
| 37 | 51 | C | 07H | TEC | | 028 | 720ZU | NV2+ | 2.1 | 0.83 | 0 | 21 | 18 |
| | | C | 07H | TEC | | 028 | 720ZU | NV2+ | 32.6 | 0.88 | 0 | 22 | 18 |
| 46 | 51 | C | 07H | TEC | | 028 | 720ZU | 01C- | 0.2 | 0.68 | 134 | 26 | 17 |
| 36 | 54 | C | 07H | TEC | | 032 | 720ZU | NV4+ | 3.5 | 1.34 | 0 | 26 | 18 |
| 39 | 54 | C | 07H | TEC | | 032 | 720ZU | 07H+ | 36.3 | 1.05 | 0 | 25 | 18 |
| 39 | 55 | C | 01C | 01C | S | 103 | 720ZR | 01C+ | 0.0 | 3.21 | 340 | VOL | 4 |
| | | C | 07H | TEC | | 032 | 720ZU | 07H+ | 35.8 | 0.76 | 0 | 20 | 18 |
| | | C | 07H | TEC | | 032 | 720ZU | NV2+ | 3.8 | 0.99 | 0 | 24 | 18 |
| 43 | 55 | C | 07H | TEC | | 032 | 720ZU | 02C+ | 0.0 | 1.04 | 135 | 24 | 17 |
| 36 | 56 | C | 07H | TEC | | 034 | 720ZU | NV2+ | 33.0 | 1.10 | 0 | 21 | 18 |
| 35 | 58 | C | 07H | TEC | | 035 | 720ZU | 07H+ | 34.4 | 1.16 | 0 | 22 | 18 |
| 43 | 58 | C | 07H | TEC | | 035 | 720ZU | 01C+ | 0.0 | 1.72 | 146 | 24 | 17 |
| 40 | 59 | C | 07H | TEC | | 035 | 720ZU | 07H+ | 37.1 | 0.98 | 0 | 20 | 18 |
| 43 | 60 | C | 07H | TEC | | 037 | 720ZU | 02C+ | 0.0 | 1.11 | 143 | 23 | 17 |
| 42 | 61 | H | 01C | TEH | | 106 | 700ZS | 01C+ | 0.1 | 0.58 | 130 | 23 | 17 |
| | | H | 01C | TEH | | 106 | 700ZS | 02C+ | 0.0 | 1.02 | 130 | 23 | 17 |
| 32 | 64 | C | 07H | TEC | | 038 | 720ZU | NV2+ | 2.9 | 1.73 | 0 | 29 | 18 |
| 38 | 64 | C | 07H | TEC | | 038 | 720ZU | NV2+ | 33.4 | 1.61 | 0 | 28 | 18 |
| 41 | 65 | C | 07H | TEC | | 039 | 720ZU | 01C+ | 0.0 | 1.97 | 136 | 29 | 17 |

NSP

CUMULATIVE INDICATIONS REPORT
PRAIRIE ISLAND, UNIT 2

Generator: 22
 Leg.....: Hot and Cold legs
 Release..: 2.0
 20% TO 29% for the entire length

Page: 3
 Date: 09/28/90
 Time: 9:40

| ROW | COL | LEG | EXTENT | | REM | REEL | PROBE | LOCATION | | CURRENT | | | |
|-----|-----|-----|--------|-----|-----|------|-------|----------|------|---------|-----|----|----|
| | | | BEG | END | | | | | | VOLTS | DEG | % | CH |
| 42 | 65 | C | 07H | TEC | | 039 | 720ZU | 02C- | 0.1 | 1.35 | 140 | 24 | 17 |
| 43 | 65 | C | 07H | TEC | | 039 | 720ZU | 02C+ | 0.0 | 4.41 | 138 | 27 | 17 |
| 32 | 67 | C | 07H | TEC | | 041 | 720ZU | NV2+ | 28.5 | 1.47 | 0 | 26 | 18 |
| 40 | 69 | C | 07H | TEC | | 041 | 720ZU | 02C- | 0.1 | 2.88 | 140 | 22 | 17 |
| 41 | 69 | C | 07H | TEC | | 041 | 720ZU | 02C- | 0.1 | 1.16 | 140 | 22 | 17 |
| 40 | 71 | C | 07H | TEC | | 044 | 720ZU | 02C- | 0.2 | 4.53 | 127 | 29 | 17 |
| 39 | 72 | H | 01C | TEH | | 106 | 700ZS | 02C+ | 0.2 | 2.87 | 130 | 23 | 17 |
| 36 | 73 | C | 07H | TEC | | 045 | 720ZU | NV2+ | 32.5 | 1.45 | 0 | 26 | 18 |
| 37 | 74 | C | 07H | TEC | | 047 | 720ZU | 02C- | 0.1 | 1.46 | 127 | 20 | 17 |
| 36 | 75 | C | 07H | TEC | | 047 | 720ZU | 02C+ | 0.0 | 2.58 | 129 | 22 | 17 |
| 37 | 76 | H | 01C | TEH | | 106 | 700ZS | 01C+ | 0.1 | 1.25 | 130 | 23 | 17 |
| 30 | 81 | C | 07H | TEC | | 050 | 720ZU | 01C+ | 0.0 | 3.10 | 137 | 21 | 17 |
| 28 | 85 | C | 07H | TEC | | 052 | 720ZU | 01C- | 0.0 | 2.03 | 131 | 29 | 17 |
| 26 | 86 | C | 07H | TEC | | 052 | 720ZU | 02C- | 0.1 | 2.16 | 136 | 23 | 17 |
| 16 | 89 | C | 07H | TEC | | 054 | 720ZU | 02C+ | 0.0 | 2.06 | 133 | 22 | 17 |
| 19 | 89 | C | 07H | TEC | | 054 | 720ZU | 01C+ | 0.0 | 2.37 | 129 | 28 | 17 |
| 7 | 91 | C | 07H | TEC | | 079 | 700ZW | 01C+ | 0.1 | 1.49 | 131 | 26 | 17 |
| 12 | 92 | C | 07H | TEC | | 054 | 720ZU | 02C- | 0.1 | 0.50 | 132 | 23 | 17 |
| 1 | 93 | C | 06H | TEC | | 081 | 700ZS | 01C+ | 0.0 | 4.57 | 130 | 29 | 17 |
| 3 | 93 | C | 07H | TEC | | 081 | 700ZS | 01C+ | 0.0 | 2.04 | 131 | 27 | 17 |
| 4 | 93 | C | 07H | TEC | | 081 | 700ZS | 02C+ | 0.0 | 0.79 | 132 | 21 | 17 |
| 5 | 93 | C | 07H | TEC | | 081 | 700ZS | 01C+ | 0.0 | 1.34 | 131 | 27 | 17 |

NUMBER OF TUBES IN REPORT = 60

NSP

CUMULATIVE INDICATIONS REPORT
PRAIRIE ISLAND, UNIT 2

Generator: 22
Leg.....: Hot and Cold legs
Release..: 2.0

Page: Title page
Date: 09/28/90
Time: 9:41

Map selection criteria :

20% TO 29% for the entire length
Supplemental data : All except NDDs included
Plugs : None included
Selected indications only are included
Groups : All groups included

NSP

DATE: 09/28/90

TIME: 9:40

STEAM GENERATOR: 22

GROUPS: All groups included


20% TO 29% for the entire length

PRAIRIE ISLAND, UNIT 2

CUMULATIVE INDICATIONS REPORT-HGT AND COLD LEGS



20% TO 29% 60



Page 13 of 44

CUMULATIVE INDICATIONS REPORT
PRAIRIE ISLAND, UNIT 2

Generator: 22
Leg.....: Hot and Cold legs
Release..: 2.0

Page: Title page
Date: 09/28/90
Time: 9:44

Report selection criteria :

30% TO 39% for the entire length
Supplemental data : All except NDDs included
Plugs : None included
Selected indications only are included
Groups : All groups included

Three column remarks field key :

Column 1=PID information
Column 2=Resolution file information
Column 3=Hold file information
"P" in Col 1=Positive identification retest condition exists
"S" In Col 1=Line contains supplemental data
"R" In Col 2=More data pending in resolution file
"H" In Col 3=More data pending in hold file

NSP

CUMULATIVE INDICATIONS REPORT
PRAIRIE ISLAND, UNIT 2

Generator: 22
 Leg.....: Hot and Cold legs
 Release..: 2.0
 30% TO 39% for the entire length

Page: 1
 Date: 09/28/90
 Time: 9:44

| ROW | COL | LEG | EXTENT | | REM | REEL | PROBE | LOCATION | | CURRENT | | | |
|-----|-----|-----|--------|-----|-----|------|-------|----------|------|---------|-----|-----|----|
| | | | BEG | END | | | | | | VOLTS | DEG | % | CH |
| 25 | 9 | C | 07H | TEC | | 003 | 720ZU | 01C- | 0.1 | 2.85 | 128 | 38 | 17 |
| 27 | 11 | C | 07H | TEC | | 003 | 720ZU | 02C+ | 0.1 | 0.61 | 137 | 30 | 17 |
| 29 | 14 | C | 07H | TEC | | 056 | 720ZU | 01C+ | 0.0 | 4.22 | 121 | 37 | 17 |
| 30 | 15 | C | 07H | TEC | | 005 | 720ZU | 01C- | 0.0 | 2.66 | 132 | 35 | 17 |
| 36 | 19 | C | 07H | TEC | | 056 | 720ZU | 01C+ | 0.0 | 1.71 | 125 | 32 | 17 |
| | | C | 01C | 01C | S | 101 | 720ZR | 01C+ | 0.0 | 1.99 | 140 | VOL | 1 |
| 36 | 22 | C | 07H | TEC | | 007 | 720ZU | 02C+ | 0.1 | 0.89 | 127 | 39 | 17 |
| 39 | 23 | C | 01C | 01C | S | 101 | 720ZR | 01C+ | 0.0 | 3.13 | 115 | VOL | 1 |
| | | C | 02C | 02C | S | 101 | 720ZR | 02C+ | 0.1 | 1.88 | 132 | VOL | 1 |
| | | C | 07H | TEC | | 007 | 720ZU | 02C- | 0.0 | 0.74 | 127 | 39 | 17 |
| 38 | 25 | C | 07H | TEC | | 009 | 720ZU | 02C- | 0.1 | 1.44 | 135 | 30 | 17 |
| 44 | 40 | C | 07H | TEC | | 020 | 720ZU | 02C+ | 0.0 | 4.63 | 128 | 31 | 17 |
| 45 | 44 | C | 07H | TEC | | 023 | 720ZU | 02C+ | 0.1 | 1.60 | 131 | 32 | 17 |
| 37 | 47 | C | 07H | TEC | | 024 | 720ZU | NV2+ | 32.6 | 2.75 | 0 | 38 | 18 |
| 40 | 47 | C | 07H | TEC | | 024 | 720ZU | NV4+ | 0.0 | 1.87 | 0 | 30 | 18 |
| 45 | 48 | C | 07H | TEC | | 025 | 720ZU | 01C+ | 0.2 | 1.34 | 136 | 36 | 17 |
| | | C | 07H | TEC | | 025 | 720ZU | 02C- | 0.1 | 2.21 | 141 | 31 | 17 |
| 45 | 50 | C | 07H | TEC | | 028 | 720ZU | 01C+ | 0.0 | 2.42 | 139 | 36 | 17 |
| 45 | 52 | C | 07H | TEC | | 030 | 720ZU | 01C+ | 0.1 | 1.06 | 128 | 33 | 17 |
| 40 | 53 | C | 07H | TEC | | 030 | 720ZU | 01C+ | 0.1 | 1.10 | 131 | 30 | 17 |
| 44 | 53 | C | 07H | TEC | | 030 | 720ZU | 01C+ | 0.1 | 2.03 | 127 | 32 | 17 |
| 45 | 55 | C | 07H | TEC | | 032 | 720ZU | 02C+ | 0.0 | 3.27 | 131 | 33 | 17 |
| 43 | 56 | C | 07H | TEC | | 034 | 720ZU | 01C- | 0.0 | 2.31 | 125 | 38 | 17 |
| 42 | 59 | C | 07H | TEC | | 035 | 720ZU | 02C+ | 0.0 | 3.10 | 125 | 36 | 17 |

NSP

CUMULATIVE INDICATIONS REPORT
PRAIRIE ISLAND, UNIT 2

Generator: 22
Leg.....: Hot and Cold legs
Release...: 2.0
30% TO 39% for the entire length

Page: 2
Date: 09/28/90
Time: 9:44

| ROW | COL | LEG | EXTENT | | REM | REEL | PROBE | LOCATION | | CURRENT | | | |
|-----|-----|-----|--------|-----|-----|------|-------|----------|------|---------|-----|----|----|
| | | | BEG | END | | | | | | VOLTS | DEG | % | CH |
| 32 | 64 | C | 07H | TEC | | 038 | 720ZU | NV2+ | 27.0 | 1.80 | 0 | 30 | 18 |
| 39 | 64 | C | 07H | TEC | | 038 | 720ZU | 02C+ | 0.1 | 1.56 | 131 | 34 | 17 |
| 42 | 64 | C | 07H | TEC | | 038 | 720ZU | 02C+ | 0.0 | 3.25 | 132 | 33 | 17 |
| 41 | 66 | C | 07H | TEC | | 039 | 720ZU | 02C+ | 0.0 | 4.38 | 128 | 39 | 17 |
| 36 | 70 | C | 07H | TEC | | 044 | 720ZU | NV2+ | 5.0 | 2.52 | 0 | 37 | 18 |
| | | C | 07H | TEC | | 044 | 720ZU | NV2+ | 32.7 | 2.80 | 0 | 39 | 18 |
| 38 | 71 | C | 07H | TEC | | 044 | 720ZU | 01C- | 0.1 | 3.06 | 125 | 33 | 17 |
| 38 | 72 | H | 01C | TEH | | 100 | 700ZS | 02C+ | 0.0 | 2.92 | 123 | 34 | 17 |
| 37 | 73 | C | 07H | TEC | | 045 | 720ZU | 02C+ | 0.0 | 3.98 | 125 | 34 | 17 |
| 39 | 73 | H | 01C | TEH | | 106 | 700ZS | 02C+ | 0.2 | 3.43 | 124 | 32 | 17 |
| 37 | 74 | C | 07H | TEC | | 047 | 720ZU | 01C+ | 0.1 | 1.14 | 103 | 39 | 17 |
| 33 | 75 | C | 07H | TEC | | 047 | 720ZU | 01C+ | 0.0 | 2.04 | 124 | 30 | 17 |
| 35 | 75 | C | 07H | TEC | | 047 | 720ZU | 01C+ | 0.0 | 1.68 | 123 | 31 | 17 |
| 30 | 79 | C | 07H | TEC | | 048 | 720ZU | 02C+ | 0.2 | 1.63 | 121 | 33 | 17 |
| 29 | 82 | C | 07H | TEC | | 050 | 720ZU | 02C- | 0.2 | 3.32 | 125 | 37 | 17 |
| 30 | 82 | C | 07H | TEC | | 050 | 720ZU | 02C- | 0.2 | 2.65 | 129 | 32 | 17 |
| 29 | 83 | C | 07H | TEC | | 050 | 720ZU | 01C+ | 0.0 | 2.68 | 125 | 37 | 17 |
| 10 | 91 | C | 07H | TEC | | 054 | 720ZU | 01C+ | 0.0 | 1.56 | 124 | 35 | 17 |
| 11 | 91 | C | 07H | TEC | | 054 | 720ZU | 02C+ | 0.0 | 2.33 | 121 | 39 | 17 |
| 4 | 93 | C | 07H | TEC | | 081 | 700ZS | 01C+ | 0.1 | 2.61 | 127 | 30 | 17 |

NUMBER OF TUBES IN REPORT = 39

NSP

CUMULATIVE INDICATIONS REPORT
PRAIRIE ISLAND, UNIT 2

Generator: 22
Leg.....: Hot and Cold legs
Release...: 2.0

Page: Title page
Date: 09/28/90
Time: 9:44

Map selection criteria :

30% TO 39% for the entire length
Supplemental data : All except NDDs included
Plugs : None included
Selected indications only are included
Groups : All groups included

NSP

DATE: 09/28/90

TIME: 9:44


STEAM GENERATOR: 22

GROUPS: All groups included

30% TO 39% for the entire length

PRAIRIE ISLAND, UNIT 2

CUMULATIVE INDICATIONS REPORT-HOT AND COLD LEGS



Page 18 of 44

CUMULATIVE INDICATIONS REPORT
PRAIRIE ISLAND, UNIT 2

Generator: 22
Leg.....: Hot and Cold legs
Release..: 2.0

Page: Title page
Date: 09/28/90
Time: 9:55

Report selection criteria :

40% TO 100% for the entire length
Supplemental data : All except NDDs included
Plugs : None included
Selected indications only are included
Groups : All groups included

Three column remarks field key :

Column 1=PID information
Column 2=Resolution file information
Column 3=Hold file information
"P" in Col 1=Positive identification retest condition exists
"S" In Col 1=Line contains supplemental data
"R" In Col 2=More data pending in resolution file
"H" In Col 3=More data pending in hold file

NSP

CUMULATIVE INDICATIONS REPORT
PRAIRIE ISLAND, UNIT 2

Generator: 22
Leg.....: Hot and Cold legs
Release.: 2.0
40% TO 100% for the entire length

Page: 1
Date: 09/28/90
Time: 9:55

| ROW | COL | LEG | EXTENT | | REM | REEL | PROBE | LOCATION | | CURRENT | | | |
|-----|-----|-----|--------|-----|-----|------|-------|----------|-----|---------|-----|-----|----|
| | | | BEG | END | | | | | | VOLTS | DEG | % | CH |
| 29 | 12 | H | TSC | TEH | P | 106 | 700ZS | 01C+ | 0.0 | 2.41 | 108 | 56 | 17 |
| 28 | 13 | H | TSC | TEH | P | 106 | 700ZS | 01C+ | 0.0 | 3.57 | 114 | 49 | 17 |
| 30 | 14 | H | TSC | TEH | P | 106 | 700ZS | 01C+ | 0.0 | 2.92 | 108 | 56 | 17 |
| 31 | 15 | C | 07H | TEC | | 005 | 720ZU | 01C- | 0.2 | 2.49 | 115 | 48 | 17 |
| | | C | 01C | 01C | S | 101 | 720ZR | 01C- | 0.3 | 1.61 | 115 | VOL | 1 |
| 30 | 16 | H | TSC | TEH | P | 106 | 700ZS | 01C+ | 0.0 | 3.38 | 108 | 56 | 17 |
| 32 | 16 | C | 02C | 02C | S | 101 | 720ZR | 02C+ | 0.0 | 5.15 | 106 | VOL | 1 |
| | | C | 07H | TEC | | 005 | 720ZU | 02C- | 0.1 | 4.04 | 95 | 70 | 17 |
| 33 | 17 | C | 07H | TEC | | 056 | 720ZU | 01C- | 0.1 | 2.25 | 116 | 43 | 17 |
| 35 | 17 | H | TSC | TEH | P | 106 | 700ZS | 01C+ | 0.0 | 2.78 | 101 | 63 | 17 |
| 37 | 22 | C | 07H | TEC | | 007 | 720ZU | 02C- | 0.2 | 4.11 | 126 | 40 | 17 |
| 39 | 23 | C | 01C | 01C | S | 101 | 720ZR | 01C+ | 0.0 | 3.13 | 115 | VOL | 1 |
| | | C | 07H | TEC | | 007 | 720ZU | 01C- | 0.1 | 2.19 | 119 | 47 | 17 |
| | | C | 02C | 02C | S | 101 | 720ZR | 02C+ | 0.1 | 1.88 | 132 | VOL | 1 |
| 38 | 24 | C | 02C | 02C | S | 101 | 720ZR | 02C+ | 0.0 | 1.52 | 124 | VOL | 1 |
| | | C | 07H | TEC | | 007 | 720ZU | 02C- | 0.1 | 1.58 | 112 | 54 | 17 |
| 39 | 24 | H | TSC | TEH | P | 106 | 700ZS | 02C+ | 0.0 | 2.78 | 115 | 48 | 17 |
| 39 | 25 | H | TSC | TEH | P | 106 | 700ZS | 02C+ | 0.0 | 5.41 | 114 | 49 | 17 |
| 40 | 25 | C | 07H | TEC | | 009 | 720ZU | 01C+ | 0.0 | 1.44 | 121 | 45 | 17 |
| | | C | 01C | 01C | S | 101 | 720ZR | 01C- | 0.0 | 1.94 | 288 | VOL | 1 |
| | | C | 07H | TEC | | 009 | 720ZU | 02C+ | 0.0 | 3.70 | 126 | 40 | 17 |
| | | C | 02C | 02C | S | 101 | 720ZR | 02C+ | 0.1 | 3.99 | 122 | VOL | 1 |
| 41 | 27 | H | TSC | TEH | P | 106 | 700ZS | 02C+ | 0.0 | 4.03 | 106 | 58 | 17 |
| 43 | 36 | H | TSC | TEH | P | 106 | 700ZS | 02C+ | 0.0 | 5.84 | 102 | 62 | 17 |
| 45 | 42 | H | TSC | TEH | P | 106 | 700ZS | 01C+ | 0.0 | 3.67 | 113 | 50 | 17 |
| 44 | 43 | C | 07H | TEC | | 021 | 720ZU | 02C+ | 0.0 | 0.70 | 119 | 41 | 17 |

NSP

CUMULATIVE INDICATIONS REPORT
PRAIRIE ISLAND, UNIT 2

Generator: 22
Leg.....: Hot and Cold legs
Release...: 2.0
40% TO 100% for the entire length

Page: 2
Date: 09/28/90
Time: 9:55

| ROW | COL | LEG | EXTENT | | REM | REEL | PROBE | LOCATION | | CURRENT | | | |
|-----|-----|-----|--------|-----|-----|------|-------|----------|-----|---------|-----|-----|----|
| | | | BEG | END | | | | | | VOLTS | DEG | % | CH |
| 44 | 43 | C | 02C | 02C | S | 103 | 720ZR | 02C+ | 0.0 | 1.23 | 348 | VOL | 1 |
| 46 | 45 | H | TSC | TEH | P | 106 | 700ZS | 01C+ | 0.0 | 4.32 | 111 | 53 | 17 |
| 44 | 47 | H | TSC | TEH | P | 106 | 700ZS | 01C+ | 0.0 | 1.70 | 80 | 79 | 17 |
| 45 | 49 | C | 07H | TEC | | 025 | 720ZU | 01C+ | 0.0 | 2.54 | 126 | 46 | 17 |
| 46 | 49 | H | TSC | TEH | P | 106 | 700ZS | 01C+ | 0.0 | 3.81 | 110 | 54 | 17 |
| 45 | 53 | H | 01C | TEH | P | 106 | 700ZS | 01C+ | 0.0 | 1.50 | 116 | 43 | 17 |
| 42 | 55 | C | 07H | TEC | | 032 | 720ZU | 01C+ | 0.0 | 2.97 | 126 | 40 | 17 |
| 44 | 55 | C | 07H | TEC | | 032 | 720ZU | 01C+ | 0.0 | 3.55 | 110 | 54 | 17 |
| | | C | 07H | TEC | | 032 | 720ZU | 02C+ | 0.0 | 1.70 | 120 | 43 | 17 |
| 45 | 56 | C | 07H | TEC | | 034 | 720ZU | 02C+ | 0.0 | 2.67 | 118 | 47 | 17 |
| | | C | 02C | 02C | S | 103 | 720ZR | 02C+ | 0.0 | 2.76 | 131 | VOL | 1 |
| 43 | 55 | C | 07H | TEC | | 035 | 720ZU | 02C- | 0.1 | 2.34 | 130 | 40 | 17 |
| 42 | 61 | H | 01C | TEH | P | 106 | 700ZS | 01C- | 0.1 | 1.88 | 113 | 47 | 17 |
| 39 | 66 | H | 01C | TEH | P | 106 | 700ZS | 02C- | 0.1 | 1.25 | 108 | 53 | 17 |
| 41 | 68 | H | 01C | TEH | P | 106 | 700ZS | 02C+ | 0.0 | 3.30 | 113 | 47 | 17 |
| 39 | 70 | C | 02C | 02C | S | 103 | 720ZR | 02C+ | 0.0 | 5.08 | 306 | VOL | 1 |
| | | C | 07H | TEC | | 044 | 720ZU | 02C- | 0.1 | 4.70 | 99 | 67 | 17 |
| 38 | 72 | H | 01C | TEH | P | 106 | 700ZS | 01C+ | 0.0 | 3.22 | 110 | 51 | 17 |
| 39 | 72 | H | 01C | TEH | P | 106 | 700ZS | 02C- | 0.2 | 5.56 | 109 | 52 | 17 |
| 37 | 73 | C | 07H | TEC | | 045 | 720ZU | 01C- | 0.1 | 2.88 | 113 | 50 | 17 |
| 39 | 73 | H | 01C | TEH | P | 106 | 700ZS | 02C- | 0.1 | 4.53 | 112 | 48 | 17 |
| 37 | 76 | H | 01C | TEH | P | 106 | 700ZS | 02C+ | 0.1 | 4.56 | 114 | 46 | 17 |
| 29 | 83 | C | 07H | TEC | | 050 | 720ZU | 02C- | 0.1 | 5.77 | 101 | 60 | 17 |

NSP

CUMULATIVE INDICATIONS REPORT
PRAIRIE ISLAND, UNIT 2

Generator: 22
 Leg.....: Hct and Cold legs
 Release...: 2.0
 40% TO 100% for the entire length

Page: 3
 Date: 09/28/90
 Time: 9:55

| ROW | COL | LEG | EXTENT | | REM | REEL | PROBE | LOCATION | | CURRENT | | | |
|-----|-----|-----|--------|-----|-----|------|-------|----------|-----|---------|-----|----|----|
| | | | BEG | END | | | | | | VOLTS | DEG | % | CH |
| 23 | 85 | C | 07H | TEC | | 052 | 720ZU | 02C+ | 0.0 | 3.24 | 111 | 51 | 17 |
| 23 | 87 | C | 07H | TEC | | 052 | 720ZU | 01C- | 0.1 | 1.97 | 116 | 46 | 17 |

NUMBER OF TUBES IN REPORT 39

NSP

CUMULATIVE INDICATIONS REPORT
PRAIRIE ISLAND, UNIT 2

Generator: 22
Leg.....: Hot and Cold legs
Release..: 2.0

Page: Title page
Date: 09/28/90
Time: 9:55

Map selection criteria :

40% TO 100% for the entire length
Supplemental data : All except NDDs included
Plugs : None included
Selected indications only are included
Groups : All groups included

NSP

DATE: 09/28/90

TIME: 9:55


STEAM GENERATOR: 22

GROUPS: All groups included

40% TO 100% for the entire length

PRAIRIE ISLAND, UNIT 2

CUMULATIVE INDICATIONS REPORT-HOT AND COLD LEGS



M&SP-PPM

ISI-ET-1

CUMULATIVE INDICATIONS REPORT
PRAIRIE ISLAND, UNIT 2

Generator: 22
Leg.....: Hot and Cold legs
Release..: 2.0

Page: Title page
Date: 09/28/90
Time: 10:02

Report selection criteria :

Supplemental data : None included
Plugs : Only current included
Selected indications only are included
Groups : All groups included

Three column remarks field key :

Column 1=PID information
Column 2=Resolution file information
Column 3=Hold file information
"P" in Col 1=Positive identification retest condition exists
"S" In Col 1=Line contains supplemental data
"R" In Col 2=More data pending in resolution file
"H" In Col 3=More data pending in hold file

NSP

CUMULATIVE INDICATIONS REPORT
PRAIRIE ISLAND, UNIT 2

Generator: 22
 Leg.....: Hot and Cold legs
 Release...: 2.0
 See title page for report selection criteria.

Page: 1
 Date: 09/28/90
 Time: 10:02

| ROW | COL | LEG | EXTENT | | REM | REEL | PROBE | LOCATION | CURRENT | | | | |
|-----|-----|--------|--------|-----|-----|------|-------|----------------|---------|-----|---|------------|--|
| | | | BEG | END | | | | | VOLTS | DEG | % | CH | |
| 29 | 12 | H | | | | | | 09/90 | | | | PLG | |
| 28 | 13 | H | | | | | | 09/90 | | | | PLG | |
| 30 | 14 | H | | | | | | 09/90 | | | | PLG | |
| 31 | 15 | H C | | | | | | 09/90 09/90 | | | | PLG PLG | |
| 30 | 16 | H | | | | | | 09/90 | | | | PLG | |
| 32 | 16 | H C | | | | | | 09/90 09/90 | | | | PLG PLG | |
| 33 | 17 | H C | | | | | | 09/90 09/90 | | | | PLG PLG | |
| 35 | 17 | H | | | | | | 09/90 | | | | PLG | |
| 37 | 22 | H C | | | | | | 09/90 09/90 | | | | PLG PLG | |
| 39 | 23 | H C | | | | | | 09/90 09/90 | | | | PLG PLG | |
| 38 | 24 | H C | | | | | | 09/90 09/90 | | | | PLG PLG | |
| 39 | 24 | H | | | | | | 09/90 | | | | PLG | |
| 39 | 25 | H | | | | | | 09/90 | | | | PLG | |
| 40 | 25 | H C | | | | | | 09/90 09/90 | | | | PLG PLG | |
| 41 | 27 | H | | | | | | 09/90 | | | | PLG | |
| 43 | 36 | H | | | | | | 09/90 | | | | PLG | |
| 43 | 41 | H | | | | | | 09/90 | | | | PLG | |
| 45 | 42 | H | | | | | | 09/90 | | | | PLG | |

NSP

CUMULATIVE INDICATIONS REPORT
PRAIRIE ISLAND, UNIT 2

Generator: 22
 Leg.....: Hot and Cold legs
 Release...: 2.0
 See title page for report selection criteria.

Page: 2
 Date: 09/28/90
 Time: 10:02

| ROW | COL | LEG | EXTENT | | REM | REEL | PROBE | LOCATION | CURRENT | | | |
|-----|-----|--------|--------|-----|-----|------|-------|----------------|---------|-----|---|------------|
| | | | BEG | END | | | | | VOLTS | DEG | % | CH |
| 44 | 43 | H C | | | | | | 09/90 09/90 | | | | PLG PLG |
| 46 | 45 | H | | | | | | 09/90 | | | | PLG |
| 44 | 47 | H | | | | | | 09/90 | | | | PLG |
| 45 | 49 | H C | | | | | | 09/90 09/90 | | | | PLG PLG |
| 46 | 49 | H | | | | | | 09/90 | | | | PLG |
| 45 | 53 | H | | | | | | 09/90 | | | | PLG |
| 42 | 55 | H C | | | | | | 09/90 09/90 | | | | PLG PLG |
| 44 | 55 | H C | | | | | | 09/90 09/90 | | | | PLG PLG |
| 45 | 56 | H C | | | | | | 09/90 09/90 | | | | PLG PLG |
| 43 | 59 | H C | | | | | | 09/90 09/90 | | | | PLG PLG |
| 42 | 61 | H | | | | | | 09/90 | | | | PLG |
| 39 | 66 | H | | | | | | 09/90 | | | | PLG |
| 41 | 68 | H | | | | | | 09/90 | | | | PLG |
| 39 | 70 | H C | | | | | | 09/90 09/90 | | | | PLG PLG |
| 38 | 72 | H | | | | | | 09/90 | | | | PLG |
| 39 | 72 | H | | | | | | 09/90 | | | | PLG |
| 37 | 73 | H C | | | | | | 09/90 09/90 | | | | PLG PLG |
| 38 | 73 | H | | | | | | 09/90 | | | | PLG |

NSP

CUMULATIVE INDICATIONS REPORT
PRAIRIE ISLAND, UNIT 2

Generator: 22
 Leg.....: Hot and Cold legs
 Release...: 2.0
 See title page for report selection criteria.

Page: 3
 Date: 09/28/90
 Time: 10:02

| ROW | COL | LEG | EXTENT | | REM | REEL | PROBE | LOCATION | CURRENT | | | | |
|-----|-----|-----|--------|-----|-----|------|-------|----------|---------|-----|---|-----|--|
| | | | BEG | END | | | | | VOLTS | DEG | % | CH | |
| 39 | 73 | H | | | | | | 09/90 | | | | PLG | |
| 37 | 76 | H | | | | | | 09/90 | | | | PLG | |
| 29 | 83 | H | | | | | | 09/90 | | | | PLG | |
| | | C | | | | | | 09/90 | | | | PLG | |
| 23 | 85 | H | | | | | | 09/90 | | | | PLG | |
| | | C | | | | | | 09/90 | | | | PLG | |
| 23 | 87 | H | | | | | | 09/90 | | | | PLG | |
| | | C | | | | | | 09/90 | | | | PLG | |

NUMBER OF TUBES IN REPORT = 41

NSP

CUMULATIVE INDICATIONS REPORT
PRAIRIE ISLAND, UNIT 2

Generator: 22
Leg.....: Hot and Cold legs
Release...: 2.0

Page: Title page
Date: 09/28/90
Time: 10:02

Map selection criteria :

Supplemental data : None included
Plugs : Only current included
Selected indications only are included
Groups : All groups included

NSP



PRAIRIE ISLAND, UNIT 2


CUMULATIVE INDICATIONS REPORT-HOT AND COLD LEGS

DATE: 09/28/90

TIME: 10:02

STEAM GENERATOR: 22

GROUPS: All groups included



CUMULATIVE INDICATIONS REPORT
PRAIRIE ISLAND, UNIT 2

Generator: 22
Leg.....: Hot and Cold legs
Release..: 2.0

Page: Title page
Date: 09/28/90
Time: 10:06

Report selection criteria :

Supplemental data : None included
Plugs : All included
Selected indications only are included
Groups : All groups included

Three column remarks field key :

Column 1=PID information
Column 2=Resolution file information
Column 3=Hold file information
"P" in Col 1=Positive identification retest condition exists
"S" In Col 1=Line contains supplemental data
"R" In Col 2=More data pending in resolution file
"H" In Col 3=More data pending in hold file

NSP

CUMULATIVE INDICATIONS REPORT
PRAIRIE ISLAND, UNIT 2

Generator: 22
 Leg.....: Hot and Cold legs
 Release...: 2.0
 See title page for report selection criteria.

Page: 1
 Date: 09/28/90
 Time: 10:06

| ROW | COL | LEG | EXTENT | | REM | REEL | PROBE | LOCATION | CURRENT | | | CH |
|-----|-----|--------|--------|-----|-----|------|-------|----------------|---------|-----|---|------------|
| | | | BEG | END | | | | | VOLTS | DEG | % | |
| 1 | 1 | H C | | | | | | 01/80 01/80 | | | | PLG PLG |
| 25 | 11 | H C | | | | | | 09/85 09/85 | | | | PLG PLG |
| 26 | 11 | H C | | | | | | 09/84 09/84 | | | | PLG PLG |
| 29 | 12 | H C | | | | | | 09/90 10/86 | | | | PLG PLG |
| 30 | 12 | H C | | | | | | 09/85 09/85 | | | | PLG PLG |
| 28 | 13 | H C | | | | | | 09/90 10/86 | | | | PLG PLG |
| 30 | 13 | H C | | | | | | 09/83 09/83 | | | | PLG PLG |
| 30 | 14 | H C | | | | | | 09/90 10/86 | | | | PLG PLG |
| 28 | 15 | H C | | | | | | 09/85 09/85 | | | | PLG PLG |
| 31 | 15 | H C | | | | | | 09/90 09/90 | | | | PLG PLG |
| 30 | 16 | H C | | | | | | 09/90 10/86 | | | | PLG PLG |
| 31 | 16 | H C | | | | | | 09/84 09/84 | | | | PLG PLG |
| 32 | 16 | H C | | | | | | 09/90 09/90 | | | | PLG PLG |
| 33 | 16 | H C | | | | | | 09/84 09/84 | | | | PLG PLG |
| 32 | 17 | H | | | | | | 03/81 | | | | PLG |

NSP

CUMULATIVE INDICATIONS REPORT
PRAIRIE ISLAND, UNIT 2

Generator: 22
 Leg.....: Hot and Cold legs
 Release..: 2.0
 See title page for report selection criteria.

Page: 2
 Date: 09/28/90
 Time: 10:06

| ROW | COL | LEG | EXTENT | | REM | REEL | PROBE | LOCATION | CURRENT | | | | |
|-----|-----|-----|--------|-----|-----|------|-------|----------|---------|-----|---|-----|--|
| | | | BEG | END | | | | | VOLTS | DEG | % | CH | |
| 32 | 17 | C | | | | | | 03/81 | | | | PLG | |
| 33 | 17 | H | | | | | | 09/90 | | | | PLG | |
| | | C | | | | | | 09/90 | | | | PLG | |
| 35 | 17 | H | | | | | | 09/90 | | | | PLG | |
| | | C | | | | | | 10/86 | | | | PLG | |
| 32 | 18 | H | | | | | | 09/84 | | | | PLG | |
| | | C | | | | | | 09/84 | | | | PLG | |
| 34 | 18 | H | | | | | | 01/80 | | | | PLG | |
| | | C | | | | | | 01/80 | | | | PLG | |
| 35 | 18 | H | | | | | | 09/84 | | | | PLG | |
| | | C | | | | | | 09/84 | | | | PLG | |
| 36 | 18 | H | | | | | | 03/81 | | | | PLG | |
| | | C | | | | | | 03/81 | | | | PLG | |
| 26 | 19 | H | | | | | | 06/82 | | | | PLG | |
| | | C | | | | | | 06/82 | | | | PLG | |
| 32 | 19 | H | | | | | | 09/83 | | | | PLG | |
| | | C | | | | | | 09/83 | | | | PLG | |
| 35 | 19 | H | | | | | | 03/81 | | | | PLG | |
| | | C | | | | | | 03/81 | | | | PLG | |
| 34 | 20 | H | | | | | | 03/81 | | | | PLG | |
| | | C | | | | | | 03/81 | | | | PLG | |
| 36 | 20 | H | | | | | | 09/84 | | | | PLG | |
| | | C | | | | | | 09/84 | | | | PLG | |
| 37 | 21 | H | | | | | | 03/81 | | | | PLG | |
| | | C | | | | | | 03/81 | | | | PLG | |
| 37 | 22 | H | | | | | | 09/90 | | | | PLG | |
| | | C | | | | | | 09/90 | | | | PLG | |
| 38 | 22 | H | | | | | | 06/82 | | | | PLG | |

NSP

CUMULATIVE INDICATIONS REPORT
PRAIRIE ISLAND, UNIT 2

Generator: 22
 Leg.....: Hot and Cold legs
 Release...: 2.0
 See title page for report selection criteria.

Page: 3
 Date: 09/28/90
 Time: 10:06

| ROW | COL | LEG | EXTENT | | REM | REEL | PROBE | LOCATION | CURRENT | | | | |
|-----|-----|--------|--------|-----|-----|------|-------|----------------|---------|-----|---|------------|--|
| | | | BEG | END | | | | | VOLTS | DEG | % | CH | |
| 38 | 22 | C | | | | | | 06/82 | | | | PLG | |
| 13 | 23 | H C | | | | | | 02/83 09/83 | | | | PLG PLG | |
| 38 | 23 | H C | | | | | | 09/84 09/84 | | | | PLG PLG | |
| 39 | 23 | H C | | | | | | 09/90 09/90 | | | | PLG PLG | |
| 38 | 24 | H C | | | | | | 09/90 09/90 | | | | PLG PLG | |
| 39 | 24 | H C | | | | | | 09/90 10/86 | | | | PLG PLG | |
| 40 | 24 | H C | | | | | | 06/82 06/82 | | | | PLG PLG | |
| 39 | 25 | H C | | | | | | 09/90 10/86 | | | | PLG PLG | |
| 40 | 25 | H C | | | | | | 09/90 09/90 | | | | PLG PLG | |
| 39 | 27 | H C | | | | | | 06/82 06/82 | | | | PLG PLG | |
| 40 | 27 | H C | | | | | | 09/85 09/85 | | | | PLG PLG | |
| 41 | 27 | H C | | | | | | 09/90 10/86 | | | | PLG PLG | |
| 39 | 28 | H C | | | | | | 03/81 03/81 | | | | PLG PLG | |
| 41 | 28 | H C | | | | | | 09/83 09/83 | | | | PLG PLG | |
| 42 | 32 | H | | | | | | 09/83 | | | | PLG | |

NSP

CUMULATIVE INDICATIONS REPORT
PRAIRIE ISLAND, UNIT 2

Generator: 22
 Leg.....: Hot and Cold legs
 Release...: 2.0
 See title page for report selection criteria.

Page: 4
 Date: 09/28/90
 Time: 10:06

| ROW | COL | LEG | EXTENT | | REM | REEL | PROBE | LOCATION | CURRENT | | | | |
|-----|-----|--------|--------|-----|-----|------|-------|----------------|---------|-----|---|------------|--|
| | | | BEG | END | | | | | VOLTS | DEG | % | CH | |
| 42 | 32 | C | | | | | | 09/83 | | | | PLG | |
| 42 | 33 | H C | | | | | | 03/81 03/81 | | | | PLG PLG | |
| 44 | 33 | H C | | | | | | 06/82 06/82 | | | | PLG PLG | |
| 42 | 34 | H C | | | | | | 01/80 01/80 | | | | PLG PLG | |
| 36 | 35 | H C | | | | | | 03/81 03/81 | | | | PLG PLG | |
| 44 | 35 | H C | | | | | | 03/81 03/81 | | | | PLG PLG | |
| 37 | 36 | H C | | | | | | 03/81 03/81 | | | | PLG PLG | |
| 43 | 36 | H C | | | | | | 09/90 10/86 | | | | PLG PLG | |
| 45 | 36 | H C | | | | | | 03/81 03/81 | | | | PLG PLG | |
| 43 | 37 | H C | | | | | | 01/80 01/80 | | | | PLG PLG | |
| 44 | 37 | H C | | | | | | 01/80 01/80 | | | | PLG PLG | |
| 45 | 37 | H C | | | | | | 01/80 01/80 | | | | PLG PLG | |
| 43 | 41 | H C | | | | | | 09/90 10/86 | | | | PLG PLG | |
| 44 | 41 | H C | | | | | | 01/80 01/80 | | | | PLG PLG | |
| 46 | 41 | H | | | | | | 09/84 | | | | PLG | |

NSP

CUMULATIVE INDICATIONS REPORT
PRAIRIE ISLAND, UNIT 2

Generator: 22
 Leg.....: Hot and Cold legs
 Release..: 2.0
 See title page for report selection criteria.

Page: 5
 Date: 09/28/90
 Time: 10:06

| ROW | COL | LEG | EXTENT | | REM | REEL | PROBE | LOCATION | CURRENT | | | | |
|-----|-----|--------|--------|-----|-----|------|-------|----------------|---------|-----|---|------------|--|
| | | | BEG | END | | | | | VOLTS | DEG | % | CH | |
| 46 | 41 | C | | | | | | 09/84 | | | | PLG | |
| 45 | 42 | C H | | | | | | 01/88 09/90 | | | | PLG PLG | |
| 44 | 43 | H C | | | | | | 09/90 09/90 | | | | PLG PLG | |
| 46 | 43 | H C | | | | | | 03/81 03/81 | | | | PLG PLG | |
| 46 | 45 | H C | | | | | | 09/90 10/86 | | | | PLG PLG | |
| 33 | 46 | H C | | | | | | 03/81 03/81 | | | | PLG PLG | |
| 37 | 46 | H C | | | | | | 03/81 03/81 | | | | PLG PLG | |
| 17 | 47 | H C | | | | | | 11/77 11/77 | | | | PLG PLG | |
| 44 | 47 | H C | | | | | | 09/90 10/86 | | | | PLG PLG | |
| 33 | 48 | H C | | | | | | 09/85 09/85 | | | | PLG PLG | |
| 36 | 48 | H C | | | | | | 09/85 09/85 | | | | PLG PLG | |
| 46 | 48 | H C | | | | | | 01/80 01/80 | | | | PLG PLG | |
| 33 | 49 | H C | | | | | | 03/81 03/81 | | | | PLG PLG | |
| 37 | 49 | H C | | | | | | 03/81 03/81 | | | | PLG PLG | |
| 45 | 49 | H | | | | | | 09/90 | | | | PLG | |

NSP

CUMULATIVE INDICATIONS REPORT
PRAIRIE ISLAND, UNIT 2

Generator: 22
 Leg.....: Hot and Cold legs
 Release..: 2.0
 See title page for report selection criteria.

Page: 6
 Date: 09/28/90
 Time: 10:06

| ROW | COL | LEG | EXTENT | | REM | REEL | PROBE | LOCATION | CURRENT | | | CH |
|-----|-----|--------|--------|-----|-----|------|-------|----------------|---------|-----|------------|----|
| | | | BEG | END | | | | | VOLTS | DEG | % | |
| 45 | 49 | C | | | | | | 09/90 | | | PLG | |
| 46 | 49 | H C | | | | | | 09/90 10/86 | | | PLG PLG | |
| 36 | 50 | H C | | | | | | 09/84 09/84 | | | PLG PLG | |
| 46 | 50 | H C | | | | | | 09/85 09/85 | | | PLG PLG | |
| 36 | 51 | H C | | | | | | 03/81 03/81 | | | PLG PLG | |
| 40 | 51 | H C | | | | | | 03/81 03/81 | | | PLG PLG | |
| 45 | 51 | H C | | | | | | 03/89 03/89 | | | PLG PLG | |
| 36 | 52 | H C | | | | | | 03/81 03/81 | | | PLG PLG | |
| 43 | 52 | H C | | | | | | 09/84 09/84 | | | PLG PLG | |
| 36 | 53 | H C | | | | | | 01/81 01/81 | | | PLG PLG | |
| 38 | 53 | H C | | | | | | 01/81 01/81 | | | PLG PLG | |
| 43 | 53 | H C | | | | | | 01/81 01/81 | | | PLG PLG | |
| 45 | 53 | H C | | | | | | 09/90 10/86 | | | PLG PLG | |
| 40 | 54 | H C | | | | | | 09/84 09/84 | | | PLG PLG | |
| 44 | 54 | H | | | | | | 06/82 | | | PLG | |

NSP

CUMULATIVE INDICATIONS REPORT
PRAIRIE ISLAND, UNIT 2

Generator: 22
 Leg.....: Hot and Cold legs
 Release...: 2.0
 See title page for report selection criteria.

Page: 7
 Date: 09/28/90
 Time: 10:06

| ROW | COL | LEG | EXTENT | | REM | REEL | PROBE | LOCATION | CURRENT | | | |
|-----|-----|--------|--------|-----|-----|------|-------|----------------|---------|-----|------------|----|
| | | | BEG | END | | | | | VOLTS | DEG | % | CH |
| 44 | 54 | C | | | | | | 06/82 | | | PLG | |
| 46 | 54 | H C | | | | | | 06/82 06/82 | | | PLG PLG | |
| 38 | 55 | H C | | | | | | 03/81 03/81 | | | PLG PLG | |
| 42 | 55 | H C | | | | | | 09/90 09/90 | | | PLG PLG | |
| 44 | 55 | H C | | | | | | 09/90 09/90 | | | PLG PLG | |
| 33 | 56 | H C | | | | | | 03/81 03/81 | | | PLG PLG | |
| 40 | 56 | H C | | | | | | 03/89 03/89 | | | PLG PLG | |
| 44 | 56 | H C | | | | | | 09/83 09/83 | | | PLG PLG | |
| 45 | 56 | H C | | | | | | 09/90 09/90 | | | PLG PLG | |
| 33 | 57 | H C | | | | | | 03/81 03/81 | | | PLG PLG | |
| 44 | 57 | H C | | | | | | 09/83 09/83 | | | PLG PLG | |
| 38 | 58 | H C | | | | | | 03/81 03/81 | | | PLG PLG | |
| 44 | 58 | H C | | | | | | 09/83 09/83 | | | PLG PLG | |
| 33 | 59 | H C | | | | | | 03/81 03/81 | | | PLG PLG | |
| 43 | 59 | H | | | | | | 09/90 | | | PLG | |

NSP

CUMULATIVE INDICATIONS REPORT
PRAIRIE ISLAND, UNIT 2

Generator: 22
 Leg.....: Hot and Cold legs
 Release...: 2.0
 See title page for report selection criteria.

Page: 8
 Date: 09/28/90
 Time: 10:06

| ROW | COL | LEG | EXTENT | | REM | REEL | PROBE | LOCATION | CURRENT | | | |
|-----|-----|--------|--------|-----|-----|------|-------|----------------|---------|-----|------------|----|
| | | | BEG | END | | | | | VOLTS | DEG | % | CH |
| 43 | 59 | C | | | | | | 09/90 | | | PLG | |
| 44 | 59 | H C | | | | | | 06/82 06/82 | | | PLG PLG | |
| 36 | 60 | H C | | | | | | 03/81 03/81 | | | PLG PLG | |
| 38 | 60 | H C | | | | | | 09/85 09/85 | | | PLG PLG | |
| 40 | 60 | H C | | | | | | 03/81 03/81 | | | PLG PLG | |
| 44 | 60 | H C | | | | | | 09/84 09/84 | | | PLG PLG | |
| 40 | 61 | H C | | | | | | 03/81 03/81 | | | PLG PLG | |
| 42 | 61 | C H | | | | | | 01/88 09/90 | | | PLG PLG | |
| 32 | 62 | H C | | | | | | 03/81 03/81 | | | PLG PLG | |
| 33 | 62 | H C | | | | | | 09/85 09/85 | | | PLG PLG | |
| 43 | 62 | H C | | | | | | 09/84 09/84 | | | PLG PLG | |
| 32 | 63 | H C | | | | | | 03/81 03/81 | | | PLG PLG | |
| 32 | 65 | H C | | | | | | 06/82 06/82 | | | PLG PLG | |
| 39 | 66 | C H | | | | | | 01/88 09/90 | | | PLG PLG | |
| 33 | 67 | H | | | | | | 03/81 | | | PLG | |

NSP

CUMULATIVE INDICATIONS REPORT
PRAIRIE ISLAND, UNIT 2

Generator: 22
 Leg.....: Hot and Cold legs
 Release...: 2.0
 See title page for report selection criteria.

Page: 9
 Date: 09/28/90
 Time: 10:07

| ROW | COL | LEG | EXTENT | | REM | REEL | PROBE | LOCATION | CURRENT | | | |
|-----|-----|--------|--------|-----|-----|------|-------|----------------|---------|-----|---|------------|
| | | | BEG | END | | | | | VOLTS | DEG | % | CH |
| 33 | 67 | C | | | | | | 03/81 | | | | PLG |
| 39 | 67 | H C | | | | | | 03/81 03/81 | | | | PLG PLG |
| 40 | 67 | H C | | | | | | 03/89 03/89 | | | | PLG PLG |
| 41 | 67 | H C | | | | | | 09/83 09/83 | | | | PLG PLG |
| 42 | 67 | H C | | | | | | 03/89 03/89 | | | | PLG PLG |
| 39 | 68 | H C | | | | | | 03/81 03/81 | | | | PLG PLG |
| 41 | 68 | H C | | | | | | 09/90 10/86 | | | | PLG PLG |
| 39 | 70 | H C | | | | | | 09/90 09/90 | | | | PLG PLG |
| 38 | 72 | H C | | | | | | 09/90 10/86 | | | | PLG PLG |
| 39 | 72 | H C | | | | | | 09/90 10/86 | | | | PLG PLG |
| 37 | 73 | H C | | | | | | 09/90 09/90 | | | | PLG PLG |
| 38 | 73 | H C | | | | | | 09/90 10/86 | | | | PLG PLG |
| 39 | 73 | H C | | | | | | 09/90 10/86 | | | | PLG PLG |
| 38 | 74 | H C | | | | | | 01/80 01/80 | | | | PLG PLG |
| 37 | 75 | H | | | | | | 06/82 | | | | PLG |

NSP

CUMULATIVE INDICATIONS REPORT
PRAIRIE ISLAND, UNIT 2

Generator: 22
 Leg.....: Hot and Cold legs
 Release...: 2.0
 See title page for report selection criteria.

Page: 10
 Date: 09/28/90
 Time: 10:07

| ROW | COL | LEG | EXTENT | | REM | REEL | PROBE | LOCATION | CURRENT | | | | |
|-----|-----|--------|--------|-----|-----|------|-------|----------------|---------|-----|---|------------|--|
| | | | BEG | END | | | | | VOLTS | DEG | % | CH | |
| 37 | 75 | C | | | | | | 06/82 | | | | PLG | |
| 34 | 76 | H C | | | | | | 01/80 01/80 | | | | PLG PLG | |
| 36 | 76 | H C | | | | | | 03/81 03/81 | | | | PLG PLG | |
| 37 | 76 | H C | | | | | | 09/90 10/86 | | | | PLG PLG | |
| 32 | 77 | H C | | | | | | 09/83 09/83 | | | | PLG PLG | |
| 34 | 77 | H C | | | | | | 06/82 06/82 | | | | PLG PLG | |
| 35 | 77 | H C | | | | | | 09/83 09/83 | | | | PLG PLG | |
| 36 | 77 | H C | | | | | | 09/85 09/85 | | | | PLG PLG | |
| 31 | 78 | H C | | | | | | 03/81 03/81 | | | | PLG PLG | |
| 33 | 78 | H C | | | | | | 01/80 01/80 | | | | PLG PLG | |
| 35 | 78 | H C | | | | | | 01/80 01/80 | | | | PLG PLG | |
| 31 | 79 | H C | | | | | | 09/83 09/83 | | | | PLG PLG | |
| 32 | 79 | H C | | | | | | 03/81 03/81 | | | | PLG PLG | |
| 33 | 79 | H C | | | | | | 01/80 01/80 | | | | PLG PLG | |
| 34 | 79 | H | | | | | | 01/80 | | | | PLG | |

NSP

CUMULATIVE INDICATIONS REPORT
PRAIRIE ISLAND, UNIT 2

Generator: 22
 Leg.....: Hot and Cold legs
 Release...: 2.0
 See title page for report selection criteria.

Page: 11
 Date: 09/28/90
 Time: 10:07

| ROW | COL | LEG | EXTENT | | REM | REEL | PROBE | LOCATION | CURRENT | | | |
|-----|-----|--------|--------|-----|-----|------|-------|----------------|---------|-----|---|------------|
| | | | BEG | END | | | | | VOLTS | DEG | % | CH |
| 34 | 79 | C | | | | | | 01/80 | | | | PLG |
| 31 | 80 | H C | | | | | | 09/85 09/85 | | | | PLG PLG |
| 31 | 61 | H C | | | | | | 06/82 06/82 | | | | PLG PLG |
| 31 | 82 | H C | | | | | | 09/84 09/84 | | | | PLG PLG |
| 29 | 83 | H C | | | | | | 09/90 09/90 | | | | PLG PLG |
| 23 | 85 | H C | | | | | | 09/90 09/90 | | | | PLG PLG |
| 25 | 85 | H C | | | | | | 09/83 09/83 | | | | PLG PLG |
| 22 | 86 | H C | | | | | | 09/85 09/85 | | | | PLG PLG |
| 23 | 87 | H C | | | | | | 09/90 09/90 | | | | PLG PLG |
| 18 | 90 | H C | | | | | | 09/83 09/83 | | | | PLG PLG |
| 15 | 91 | H C | | | | | | 03/89 03/89 | | | | PLG PLG |
| 17 | 91 | H C | | | | | | 09/83 09/83 | | | | PLG PLG |
| 1 | 94 | H C | | | | | | 01/80 01/80 | | | | PLG PLG |

NUMBER OF TUBES IN REPORT = 153

NSP

CUMULATIVE INDICATIONS REPORT
PRAIRIE ISLAND, UNIT 2

Generator: 22
Leg.....: Hot and Cold legs
Release..: 2.0

Page: Title page
Date: 09/28/90
Time: 10:07

Map selection criteria :

Supplemental data : None included
Plugs : All included
Selected indications only are included
Groups : All groups included

NEP

DATE: 09/28/90

TIME: 10:07

STEAM GENERATOR: 22


GROUPS: All groups included

PRAIRIE 1 AND, UNIT 2

CUMULATIVE INDICATIONS REPORT-HOT AND COLD LEGS



Page 44 of 44



M
A
N
W
A
Y

N
O
Z
Z
L
E

M&SP-PPM

ISI-ET-1

APPENDIX H

NIS-1 FORM

FORM NIS-1, OWNERS DATA REPORT FOR INSERVICE INSPECTION

FORM NIS-1 OWNER'S DATA REPORT FOR INSERVICE INSPECTIONS
(As required by the Provision of the ASME Code Rules)

- 1.) Owner: Northern States Power Company
Address: 414 Nicollet Mall, Minneapolis, Minnesota 55401
- 2.) Plant: PRAIRIE ISLAND NUCLEAR GENERATING PLANT
Address: WELCH, MINNESOTA
- 3.) Plant Unit : II 4.) Owner (Certificate of Authorization): --
- 5.) Commercial Service Date: 12-20-74 6.) National Board NO. for Unit: --

7.) Components Inspected:

| <u>Component or Appurtenance</u> | <u>Manufacturer or Installer</u> | <u>Manufacturer or Installer Serial No.</u> | <u>State or Province No.</u> | <u>National Board No.</u> |
|--|----------------------------------|---|------------------------------|---------------------------|
| <u>ASME CLASS I</u> | (See Appendix A) | | | |
| <u>REACTOR VESSEL</u> | CREUSOT-LOIRE | 687 | MINN 200-51 | --- |
| <u>PRESSURIZER</u> | WESTINGHOUSE | 1191 | --- | 68-57 |
| <u>STEAM GENERATOR NUMBER 21</u> | WESTINGHOUSE | 1181 | --- | 68-39 |
| <u>STEAM GENERATOR NUMBER 22</u> | WESTINGHOUSE | 1182 | --- | 68-40 |
| <u>REACTOR COOLANT PUMP 21</u> | WESTINGHOUSE | W510 | --- | --- |
| <u>REACTOR COOLANT PUMP NUMBER 22</u> | WESTINGHOUSE | W515 | --- | --- |
| <u>ASME CLASS II</u> | (See Appendix B) | | | |
| <u>ACCUMULATOR TANK 21</u> | DELTA SOUTHERN | 41037-69-1 | --- | 2575 |
| <u>ACCUMULATOR TANK 22</u> | DELTA SOUTHERN | 41037-69-1 | --- | 2576 |
| <u>RHR HEAT EXCHANGER 21</u> | JOSEPH OATS & SONS | 1817-1C | --- | 342 |
| <u>RHR HEAT EXCHANGER 22</u> | JOSEPH OATS & SONS | 1817-1D | --- | 343 |
| <u>SAFETY INJECTION PUMP NUMBER 21</u> | BINGHAM | --- | --- | --- |
| <u>SAFETY INJECTION PUMP NUMBER 22</u> | BINGHAM | --- | --- | --- |

FORM NIS-1 OWNER'S DATA REPORT FOR INSERVICE INSPECTIONS
 (As required by the Provision of the ASME Code Rules)

Form 17-0000

1.) Owner: Northern States Power Company

Address: 414 Nicollet Mall, Minneapolis, Minnesota 55401

2.) Plant: PRAIRIE ISLAND NUCLEAR GENERATING PLANT

Address: WELCH, MINNESOTA

3.) Plant Unit : II 4.) Owner (Certificate of Authorization): --

5.) Commercial Service Date: 12-20-74 6.) National Board NO. for Unit: --

7.) Components Inspected:

| <u>Component or Appurtenance</u> | <u>Manufacturer or Installer</u> | <u>Manufacturer or Installer Serial No.</u> | <u>State or Province No.</u> | <u>National Board No.</u> |
|----------------------------------|----------------------------------|---|------------------------------|---------------------------|
| <u>ASME CLASS II</u> | (Continued) | | | |
| <u>RHR PUMP 21</u> | BYRON JACKSON | --- | --- | --- |
| <u>RHR PUMP 22</u> | BYRON JACKSON | --- | --- | --- |

ESAR (See Appendix C)

ASME CLASS I COMPONENT SUPPORTS (See Appendix D)

ASME CLASS II COMPONENT SUPPORTS (See Appendix D)

STEAM GENERATOR TUBES

STEAM GENERATOR NUMBER 21

(See Appendix F)

STEAM GENERATOR NUMBER 22

(See Appendix G)

FORM NIS-1 (back)

- 8.) Examination Dates: 09-04-90 to 10-02-90
 9.) Inspection Interval: 12-16-83 to 12-16-93
 10.) Abstract of Examinations: Include a list of examination and a statement concerning status of work required for current interval.

This report is a summary of the examinations performed during the 14th inservice inspection at the Prairie Island Nuclear Generating Plant - Unit 2. This was the last inspection conducted for inspection period two of the plant's 2nd ten year interval. The examinations were performed during the plant's 14th refueling outage. These examinations completed 100% of the required examination on the pressure retaining components and supports of the reactor coolant and associated systems classified as ASME Class 1 and ASME Class 2; the FSAR Augmented examinations of main steam and feedwater system transversing the Auxillary building. Eddy current examination requirements for steam generator tubes were also completed during this outage in accordance with Prairie Island Technical Specification, Section T.S.4.12

11.) Abstract of Conditions Noted:

The Eddy Current inspection revealed 121 and 181 tubes with tube wall degredation in Steam Generator 21 and 22 respectively.

Other than steam generator (S.G.) tubes, there were no signs of degradation to systems scheduled for examination.

The following is a list of anomalies detected:

| <u>SYSTEM</u> | <u>ITEM ID</u> | <u>TYPE AND NUMBER EXAM METHOD</u> | <u>OF INDICATIONS</u> |
|--------------------------------|---|------------------------------------|--------------------------------------|
| SI PUMP SUCTION | SIH-29/B | VT | NO LOAD SCALE |
| RTD TAKE OFF COLD B | 1?? 2KTD-2/B | VT | BOLT ENGAGEMENT |
| REATOR VESSEL | W-6 | UT | INCLUSION |
| FEEDWATER A | FWH-68/B FW-136 | MT MT | COLD LAP LINEAR |
| STEAM GENERATOR NO. 21 | COL. 2 PIN W-F | UT UT | LINEAR SLAG INCLUSION |
| STEAM GENERATOR NO. 22 | COL. 3 PIN PAD 4 UPPER RING COL. 2 | UT VT UT | LINEAR LOOSE NUT LINEAR |
| PRESSURIZER SURGE MAIN STEAM A | RCRH-50/F MS-48 MS-56 | VT VT VT | BOTTOMED OUT ARC STRIKE GOUGES |

11.) Abstract of Conditions Noted: (Cont'd)

| SYSTEM | ITEM ID | TYPE AND NUMBER | | OF INDICATIONS |
|--------------------|------------|-----------------|--|-----------------|
| | | EXAM METHOD | | |
| MAIN STEAM B | MS-82 | MT | | LINEARS |
| | MSH-50/A1 | VT | | LOOSE NUT |
| | MSH-46/C | MT | | ARC STRIKE |
| RHR TAKE OFF HOT A | 9-2RHR-7/C | VT | | FLAME CUT HOLES |
| RHR TAKE OFF HOT B | W-F | PT | | LINEARS |

12.) Abstract of Corrective Measures Recommended and Taken:

To assure continued integrity of the steam generators (S.G.), a total of 12 new tubes in S.G. 21 and 18 new tubes in S.G. 22 were mechanically plugged, in addition 6 tubes in S.G. 21 and 23 tubes in S.G. 22 were replugged based on NRC Bulliten 89-01.

All anomalies were either corrected or an engineering evaluation was performed to accept "as is" conditions. The PT,MT and VT indication for linears, cold lap, gouges and arc strikes were removed by light hand grinding and blending the area smooth; the loose nuts and bolt engagement were tightened; the hanger with no load scale and the hanger that was bottomed out were evaluated and found acceptable by an engineering evaluation; the hanger with flame cut holes was re-worked to remove the HAZ by grinding; some items with linear or inclusion indications were accepted based on Section XI IWB-3514.2.

We certify that the statements made in this report are correct and the examinations and corrective measures taken conform to the rules of the ASME Code, Section XI.

Date Oct 16 1990 Signed Westwood States Power Company By [Signature]
Owner

Certificate of Authorization no. (if applicable) N/A Expiration Date N/A

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State of Providence of ILLINOIS and employed by HARTFORD STEAM BOILER INSPECTION & INSURANCE COMPANY of HARTFORD, CONNECTICUT have inspected the components described in this Owner's Data Report during the period 9-4-90 to 10-2-90, and state that to the best of my knowledge and belief, the Owner has preformed examinations and taken corrective measures described in this Owner's Data Report in accordance with the requirements of the ASME Code, Section XI.

By signing the certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Data Report. Futhermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or loss of any kind arising from or connected with this inspection.

Date Oct 16 19 90

Samuel C. Miller
Inspector's Signature

Commissions NB 10274, MIN 90-174
National Board, State, Providence & No.