

FOR USE IN UNIT II ONLY

1054.2
Revision 2

- 3.17 Any near or onsite toxic or flammable gas or liquid release which affects the habitability required for normal operations. Shift Foreman's/Emergency Director's judgement.
- 3.18 Known explosion damage to any permanent plant structure. Shift Foreman's/Emergency Director's judgement.
- 3.19 An ongoing security compromise. Shift Foreman's/Emergency Director's judgement based on advice of plant security.
- 3.20 Other plant conditions in progress or have occurred which may involve an actual or potential substantial degradation of the level of safety of the plant. Shift Foreman's/Emergency Director's Judgement

NOTE: In exercising the judgment as to the need for declaring an Alert, uncertainty considering safety status of the plant, the length of time the uncertainty exists, the prospects for early resolution of ambiguities, and the potential for substantial degradation of the level of safety of the plant should be considered; i.e., uncertainty as to the the existence of substantial degradation of the level of safety of the plant extending beyond a reasonable time period is a sufficient basis for declaring an Alert.

4.0 EMERGENCY ACTIONS

Initials

- 4.1 Upon recognition that any of the Emergency Action Levels of section 3.0 above have been reached or exceeded, the Shift Foreman shall announce or have announced, the following message over the public address sytem: (NOTE: TURN ON WHELEN SIREN SWITCH.)

"ATTENTION ALL PERSONNEL; ATTENTION ALL PERSONNEL: AN ALERT HAS BEEN DECLARED IN UNIT 2. ALL MEMBERS OF THE

8211110100 821102
PDR ADOCK 05000320
F PDR

4.0

FOR USE IN UNIT II ONLY