

9101140115 910107
 PDR ADDOCK 05000459
 PDR

RIVER BEND - UNIT 1

3/4 6-41

TABLE 3.6.4-1 (Continued)

CONTAINMENT AND DRYWELL ISOLATION VALVES

<u>SYSTEM</u>	<u>VALVE NUMBER</u>	<u>PENETRATION NUMBER</u>	<u>SECONDARY CONTAINMENT BYPASS PATH (Yes/No)</u>
b. Manual Isolation Valves			
2. Drywell^(k)			
Service Air Supply	1SAS*V489	1DRB*Z45	No
Instrument Air Supply	1IAS*V79	1DRB*Z47	No
Service Water Supply	1HVN*V542	1DRB*Z54	No
Service Water Supply <i>Service Water Return</i>	1SWP*V205 ← 1HVN*V543	1DRB*Z54 ← 1DRB*Z55	No ← No
Service Water Supply <i>Return</i>	1SWP*V206	1DRB*Z55	No
Air Sup. for Main Steam SRV	1SVV*V50	1DRB*Z107	No
Air Sup. for Main Steam SRV	1SVV*V53	1DRB*Z112	No
Cont Atmos. Monitor Probe	1CMS*SOV34A ^(e)	1DRB*Z500	No
Cont Atmos. Monitor Probe	1CMS*SOV34B ^(e)	1DRB*Z430	No
Cont Atmos. Monitor Probe	1CMS*SOV34C ^(e)	1DRB*Z499	No
Cont Atmos. Monitor Probe	1CMS*SOV34D ^(e)	1DRB*Z428	No
Cont Atmos. Monitor Probe	1CMS*SOV32A ^(e)	1DRB*Z333	No
Cont Atmos. Monitor Probe	1CMS*SOV32G ^(e)	1DRB*Z335	No
c. Other Isolation Valves			
1. Primary Containment^(a)			
Feedwater Line	1B21*A0VF032A ^(c)	1KJB*Z3A	Yes ^(f)
Feedwater Line	1B21*VF010A ^(b)	1KJB*Z3A	Yes ^(f)
Feedwater Line	1B21*A0VF032B ^(c)	1KJB*Z3B	Yes ^(f)
Feedwater Line	1B21*VF010B ^(b)	1KJB*Z3B	Yes ^(f)