NRC FORM 366 (7-77)

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

UPDATE REPORT
PREVIOUS REPORT DATE: 9/15/82

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

Field	Value
01 LICENSEE CODE (2)	I L D R S 2
LICENSE NUMBER (3)	0 0 - 0 0 0 0 0 - 0 0
LICENSE TYPE (4)	4 1 1 1 1
CAT (5)	
CON'T 01 REPORT SOURCE (6)	L
DOCKET NUMBER (7)	0 5 0 0 0 2 3 7
EVENT DATE (8)	0 8 3 0 8 2
REPORT DATE (9)	1 0 2 1 8 2

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 While performing Torus-Drywell Vacuum Breaker Operability Test (DOS-1600-9), valve
03 2-1601-33A exhibited binding during movement (T.S.3.7.A.4.a). All other valves were
04 operable. This event is of minimum safety significance since the valve was secured
05 (wired) closed as required by T.S.3.7.A.4.b. There was no effect on public health or
06 safety. Past occurrence reported by R. O. 81-38 on Docket 50-237.
07
08

09	Value
SYSTEM CODE (11)	S A
CAUSE CODE (12)	E
CAUSE SUBCODE (13)	B
COMPONENT CODE (14)	V A L V E X
COMP. SUBCODE (15)	C
VALVE SUBCODE (16)	C

(17) LER/RO REPORT NUMBER	Value
EVENT YEAR	8 2
—	—
SEQUENTIAL REPORT NO.	0 4 0
/	/
OCCURRENCE CODE	0 3
REPORT TYPE	X
—	—
REVISION NO.	1

Field	Value
ACTION TAKEN (18)	B
FUTURE ACTION (19)	Z
EFFECT ON PLANT (20)	Z
SHUTDOWN METHOD (21)	Z
HOURS (22)	0 0 0 0
ATTACHMENT SUBMITTED (23)	N
NPRD-4 FORM SUB. (24)	N
PRIME COMP. SUPPLIER (25)	N
COMPONENT MANUFACTURER (26)	A 5 8 5

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 The cause was determined to be excess packing grease in the Chevron packing seal.
11 Some packing grease was bled out and the valve was tested and proven operable. DOS
12 1600-9 will continue to be performed monthly.
13
14

15	Value
FACILITY STATUS (28)	E
% POWER (29)	0 8 7
OTHER STATUS (30)	N/A
METHOD OF DISCOVERY (31)	B
DISCOVERY DESCRIPTION (32)	Routine Surveillance

16	Value
ACTIVITY RELEASED (33)	Z
CONTENT OF RELEASE (34)	Z
AMOUNT OF ACTIVITY (35)	N/A
LOCATION OF RELEASE (36)	N/A

17 PERSONNEL EXPOSURES	Value
NUMBER (37)	0 0 0
TYPE (38)	Z
DESCRIPTION (39)	N/A

18 PERSONNEL INJURIES	Value
NUMBER (40)	0 0 0
DESCRIPTION (41)	N/A

19 LOSS OF OR DAMAGE TO FACILITY (43)	Value
TYPE (42)	Z
DESCRIPTION	N/A

8211110157 821021
PDR ADOCK 05000237
S PDR

20 PUBLICITY	Value
ISSUED (44)	N
DESCRIPTION (45)	

NRC USE ONLY

NAME OF PREPARER David Tang Wee

PHONE: 815-942-2920, X-422

GPO 917-926