

LICENSEE EVENT REPORT

CONTROL BLOCK: _____ (1)

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

(01) WIKNPL1 (2) 00-000000-000 (3) 41111 (4) _____ (5)
7 8 9 14 13 25 26 30 57 CAT 58

CON'T (01) REPORT SOURCE L (6) 05000305 (7) 100482 (8) 110382 (9)
7 8 60 61 68 69 74 75 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)
02 | During surveillance testing it was discovered that the outer door of the personnel
03 | airlock exceeded leak rate specifications. This places the facility under T.S. 3.6.a
04 | and is reportable per T.S. 6.9.2.b(2). Since the inner airlock door remained tight,
05 | containment integrity was lost only momentarily as personnel entered through the inner
06 | door, hence, there was no effect on public safety or plant operation.
07 | _____
08 | _____

(09) SYSTEM CODE SA (11) CAUSE CODE E (12) CAUSE SUBCODE B (13) COMPONENT CODE PENE TR (14) COMP. SUBCODE A (15) VALVE SUBCODE Z (16)
7 8 9 10 11 12 13 18 19 20
(17) LER NO. REPORT NUMBER (18) 82 (19) _____ (20) _____ (21) _____ (22) _____ (23) 03 (24) _____ (25) L (26) _____ (27) _____ (28) 03 (29) _____ (30) _____ (31) _____ (32) 0 (33) F (34) Z (35) Z (36) Z (37) 0000 (38) 0000 (39) N (40) Y (41) N (42) Y (43) A (44) C310 (45) 0 (46) _____ (47) _____

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)
10 | A one-sixteenth inch thick shim was installed under the outer seal and the door was
11 | retested satisfactory. No further action is required.
12 | _____
13 | _____
14 | _____

(15) FACILITY STATUS E (28) % POWER 100 (29) NA OTHER STATUS (30) METHOD OF DISCOVERY B (31) Surveillance Testing (32)
7 8 9 10 11 12 13 44 45 46 80
(16) ACTIVITY CONTENT Z (33) Z (34) NA AMOUNT OF ACTIVITY (35) LOCATION OF RELEASE (36) NA
7 8 9 10 11 44 45 80
(17) PERSONNEL EXPOSURES NUMBER 000 (37) Z (38) NA DESCRIPTION (39)
7 8 9 11 12 13 80
(18) PERSONNEL INJURIES NUMBER 000 (40) NA DESCRIPTION (41)
7 8 9 11 12 80
(19) LOSS OF OR DAMAGE TO FACILITY TYPE Z (42) NA DESCRIPTION (43)
7 8 9 10 80

(20) PUBLICITY ISSUED N (44) NA DESCRIPTION (45) 8211110240 821103 PDR ADOCK 05000305 S PDR
7 8 9 10 80

NAME OF PREPARER: S. L. Bernhoft PHONE: (414) 388-2560 Ext. 340