

ILLINOIS POWER

CLINTON POWER STATION, P.O. BOX 678, CLINTON, ILLINOIS 61727-0678, TELEPHONE (217) 935-8881

U-601775
L30-91(01-08)-LP
8E.100c

January 8, 1991

10CFR50.36

Docket No. 50-461


U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555

Subject: Clinton Power Station, Unit 1
December 1990 Monthly Operating Report NPF-62

Dear Sir:

Please find in Attachment 1 the Monthly Operating Report for Clinton Power Station, Unit 1, for the period ending December 31, 1990.

Sincerely yours,



F. A. Spangenberg, III
Manager - Licensing and Safety

ISA/ah

Attachment

cc: NRC Region III Regional Administrator
NRC Resident Office

9101140270 901231
PDR ADOCK 05000461
R PDR

IE24
11

CHALLENGES TO MAIN STEAM SAFETY/RELIEF VALVES

Month December, 1990

None

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-461

UNIT Clinton 1

DATE 12/31/90

COMPLETED BY F. A. Spangenberg, III

TELEPHONE (217) 935-8881 X3400

MONTH December 1990

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

1	<u>0</u>
2	<u>0</u>
3	<u>0</u>
4	<u>0</u>
5	<u>0</u>
6	<u>0</u>
7	<u>0</u>
8	<u>0</u>
9	<u>0</u>
10	<u>0</u>
11	<u>0</u>
12	<u>0</u>
13	<u>0</u>
14	<u>0</u>
15	<u>0</u>
16	<u>0</u>

17	<u>0</u>
18	<u>0</u>
19	<u>0</u>
20	<u>0</u>
21	<u>0</u>
22	<u>0</u>
23	<u>0</u>
24	<u>0</u>
25	<u>0</u>
26	<u>0</u>
27	<u>0</u>
28	<u>0</u>
29	<u>0</u>
30	<u>0</u>
31	<u>0</u>

OPERATING DATA REPORT

DOCKET NO. 50-461

UNIT Clinton 1

DATE 12/31/90

COMPLETED BY F. A. Spangenberg, III

TELEPHONE (217) 935-8881 X3400

OPERATING STATUS

1. REPORTING PERIOD: December 1990 GROSS HOURS IN REPORTING PERIOD: 744
2. CURRENTLY AUTHORIZED POWER LEVEL (MWt): 2894 MAX. DEPEND. CAPACITY (MDC) (MWe-Net): 930 DESIGN ELECTRICAL RATING (MWe-Net): 933
3. POWER LEVEL TO WHICH RESTRICTED (IF ANY) (MWe-Net): None
4. REASONS FOR RESTRICTION (IF ANY): N/A

	THIS MONTH	YR TO DATE	CUMULATIVE
5. NUMBER OF HOURS REACTOR WAS CRITICAL...	<u>0.0</u>	<u>4826.8</u>	<u>17,368.8</u>
6. REACTOR RESERVE SHUTDOWN HOURS.....	<u>0.0</u>	<u>0.0</u>	<u>0.0</u>
7. HOURS GENERATOR ON LINE.....	<u>0.0</u>	<u>4605.6</u>	<u>16,700.2</u>
8. UNIT RESERVE SHUTDOWN HOURS.....	<u>0.0</u>	<u>0.0</u>	<u>0.0</u>
9. GROSS THERMAL ENERGY GENERATED (MWH)...	<u>0.0</u>	<u>11,539,744</u>	<u>41,596,909</u>
10. GROSS ELECTRICAL ENERGY GENERATED (MWH)	<u>0.0</u>	<u>3,817,720</u>	<u>13,746,084</u>
11. NET ELECTRICAL ENERGY GENERATED (MWH)...	<u>0.0</u>	<u>3,596,622</u>	<u>13,003,371</u>
12. REACTOR SERVICE FACTOR.....	<u>0%</u>	<u>55.1%</u>	<u>63.9%</u>
13. REACTOR AVAILABILITY FACTOR.....	<u>0%</u>	<u>55.1%</u>	<u>63.9%</u>
14. UNIT SERVICE FACTOR.....	<u>0%</u>	<u>52.6%</u>	<u>61.4%</u>
15. UNIT AVAILABILITY FACTOR.....	<u>0%</u>	<u>52.6%</u>	<u>61.4%</u>
16. UNIT CAPACITY FACTOR (Using MDC).....	<u>0%</u>	<u>44.1%</u>	<u>51.4%</u>
17. UNIT CAPACITY FACTOR (Using Design MWe)	<u>0%</u>	<u>44.0%</u>	<u>51.2%</u>
18. UNIT FORCED OUTAGE RATE.....	<u>0%</u>	<u>19.2%</u>	<u>17.0%</u>

19. SHUTDOWNS SCHEDULED OVER NEXT SIX MONTHS (TYPE, DATE, DURATION OF EACH):

None

20. IF SHUT DOWN AT END OF REPORT PERIOD, ESTIMATED DATE OF STARTUP:

February 5, 1991

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50-461
UNIT Clinton 1
DATE 12/31/90
COMPLETED BY F. A. Spangenberg, III
TELEPHONE (217) 935-8881 X3400

REPORT MONTH December 1990

NO.	DATE	TYPE		DURATION (HOURS)	REASON(1)	METHOD OF SHUTTING DOWN	
		F: FORCED	S: SCHEDULED			THE REACTOR OR REDUCING POWER(2)	CORRECTIVE ACTIONS /COMMENTS
90-08	901014		S	720	C: Second Refueling Outage	4:	Continued shutdown 90-08

(1) Reason
A-Equipment Failure (explain), B-Maintenance or Test, C-Refueling, D-Regulatory Restriction,
E-Operator Training & License Examination, F-Administrative, G-Operational Error (explain),
H-Other

(2) Method
1-Manual, 2-Manual Scram, 3-Auto Scram, 4-Continued