

January 4, 1991

Docket No. 50-213

Docket 510

DISTRIBUTION

~~Docket File~~
NRC & Local PDRs
PDI-4 File
SNorris
SVarga
EGreenman
OGC
JCalvo
GPA/PA

AWang
DHagan
GSchwenk
EJordan
GHill (4)
Wanda Jones
ACRS (10)
OC/LFMB

Mr. Edward J. Mroczka
Senior Vice President
Nuclear Engineering and Operations
Connecticut Yankee Atomic Power Company
Northeast Nuclear Energy Company
P. O. Box 270
Hartford, Connecticut 06141-0270

Dear Mr. Mroczka:

SUBJECT: ISSUANCE OF AMENDMENT (TAC NO. 77049)

The Commission has issued the enclosed Amendment No. 134 to Facility Operating License No. DPR-61 for the Haddam Neck Plant, in response to your application dated June 25, 1990 and supplemented on July 19, 1990.

The amendment would establish a new Technical Specification 3/4.4.12, "Failed Fuel Rods," with a limit of 160 failed fuel rods during operation of cycles 16 and 17. The proposed limit of 160 failed fuel rods is consistent with the dose equivalent iodine limit of 1.0 microcurie/gram in the current Technical Specifications.

A copy of the related Safety Evaluation is also enclosed. Also enclosed is the Notice of Issuance which has been forwarded to the Office of the Federal Register for publication.

Sincerely,

Original signed by

Alan B. Wang, Project Manager
Project Directorate I-4
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Enclosures:

1. Amendment No. 134 to DPR-61
2. Safety Evaluation
3. Notice

cc w/enclosures:
See next page

9101140320 910104
PDR ADDCK 05000213
P PDR

OFF	: PDI-4:LA	: PDI-4:PM	: PDI-4:D	: OGC <i>Wang</i>	:
NAME	: SNorris	: AWang/Bah <i>Bah</i>	: JStolz	: <i>myoung</i>	:
DATE	: 12/5/90	: 12/6/90	: 01/03/91	: 12/12/90	:

OFFICIAL RECORD COPY
Document Name: AMEND 77049

JFOI '11

Mr. Edward J. Mroczka
Connecticut Yankee Atomic Power Company

Haddam Neck Plant

cc:

Gerald Garfield, Esquire
Day, Gerry and Howard
Counselors at Law
City Place
Hartford, Connecticut 06103-3499

R. M. Kacich, Manager
Generation Facilities Licensing
Northeast Utilities Service Company
Post Office Box 270
Hartford, Connecticut 06141-0270

W. D. Romberg, Vice President
Nuclear Operations
Northeast Utilities Service Company
Post Office Box 270
Hartford, Connecticut 06141-0270

D. O. Nordquist
Director of Quality Services
Northeast Utilities Service Company
Post Office Box 270
Hartford, Connecticut 06141-0270

Kevin McCarthy, Director
Radiation Control Unit
Department of Environmental Protection
State Office Building
Hartford, Connecticut 06106

Regional Administrator
Region I
U. S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, Pennsylvania 19406

Bradford S. Chase, Under Secretary
Energy Division
Office of Policy and Management
80 Washington Street
Hartford, Connecticut 06106

Board of Selectmen
Town Hall
Haddam, Connecticut 06103

J. P. Stetz, Nuclear Station Director
Haddam Neck Plant
Connecticut Yankee Atomic Power Company
RFD 1, Post Office Box 127E
East Hampton, Connecticut 06424

J. T. Shedlosky, Resident Inspector
Haddam Neck Plant
c/o U. S. Nuclear Regulatory Commission
Post Office Box 116
East Haddam Post Office
East Haddam, Connecticut 06423

G. H. Bouchard, Nuclear Unit Director
Haddam Neck Plant
Connecticut Yankee Atomic Power Company
RFD 1, Post Office Box 127E
East Hampton, Connecticut 06424