

NOTICE OF VIOLATION

Commonwealth Edison Company
Zion Nuclear Power Station
Units 1 and 2

Docket Nos. 50-295; 50-304
Licenses No. DPR-39; . DPR-48

As a result of the inspection conducted December 17 through 21, 1990, and in accordance with the "General Policy and Procedure for NRC Enforcement Actions," 10 CFR Part 2, Appendix C (1990), the following violation was identified:

Appendix B, Criterion III of 10 CFR 50 as implemented by Topical Report CE-1-A, Commonwealth Edison Company Quality Assurance Program for Nuclear Generating Stations dated January 1976, requires that "Measures shall be established to assure that . . . the design basis . . . for . . . structures, systems and components to which this appendix applies are correctly translated into specifications, drawings, procedures and instructions. These measures shall include revisions to assure that . . . deviations from such standards are controlled."

Contrary to the above, as of the Diagnostic Evaluation Team (DET) inspection on June 4, 1990, the licensee had failed to control deviations from the torque switch settings at which motor operated valves (MOVs) in the IE Bulletin 85-03 program were tested to demonstrate operability.

This is a Severity Level IV violation (Supplement I.D.3).

The inspection showed that actions had been taken to correct the identified violation and to prevent recurrence. Consequently, no reply to the violation is required and we have no further questions regarding this matter.

8/11/91
Dated _____

M. A. Ring
M. A. Ring, Chief
Engineering Branch

9101150077 910111
PDR ADDCK C5000295
Q PDR