General Offices . Selden Street, Berlin, Connecticut

P.O. BOX 270 HARTFORD, CONNECTICUT 06141-0270 (203) 665-5000

> January 8, 1991 MP-91-15

Re: 10CFR50.71(a)

U.S. Nuclear Regulatory Commission Document Control Desk Washington, D.C. 20555

Reference: Facility Operating License No. NPF-49 Docket No. 50-423

Dear Sh:

In accordance with reporting requirements of technical specifications Section 6.9.1.5, the Millstone Nuclear Power Station - Unit 3 Monthly Operating Report 91-01 covering operation for the month of December is hereby forwarded.

The Gross Thermal Energy Generated for the Year to Date and the Cumulative to Date deviate from the previous month's total and the present month's Month reading by 370,862.4 MWH. This is due to an adjustment to the burnup calculation and the gross thermal generation caused by ventur, fouling effects.

Very truly yours,

NORTHEAST NUCLEAR ENERGY COMPANY

> Stephen E. Scace Director, Millstone Station

Attachment.

cc: T.T. Martin, Region I Administrator
W.J. Raymond, Senior Resident Inspector, Millstone Unit Nos. 1.2 & 3
D.H. Jaffe, NRC Project Manager, Millstone Unit No. 3

9101150255 910108 PDR ADOCK 05000423 R PDR IF24