



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

TENNESSEE VALLEY AUTHORITY
DOCKET NO. 50-328
SEQUOYAH NUCLEAR PLANT, UNIT 2
AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 137
License No. DPR-79

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Tennessee Valley Authority (the licensee) dated May 4, 1990, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter 1;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

2. Accordingly, the license is amended by charges to the Technical Specifications as indicated in the attachment to this license amendment and paragraph 2.C.(2) of Facility Operating License No. DFR-79 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 137, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of its date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Frederick J. Heddon, Director
Project Directorate II-4
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Attachment:
Charges to the Technical
Specifications

Date of Issuance: December 10, 1990

ATTACHMENT TO LICENSE AMENDMENT NO. 132

FACILITY OPERATING LICENSE NO. DPR-79

DOCKET NO. 50-328

Revise the Apperdx A Technical Specifications by removing the pages identified below and inserting the enclosed pages. The revised pages are identified by the captioned amendment number and certain marginal lines indicating the area of change.

REMOVE

3/4 3-63

INSERT

3/4 3-63

TABLE 3.3-11 (Continued)

FIRE DETECTION INSTRUMENTS

FIRE ZONE	INSTRUMENT LOCATION	MINIMUM INSTRUMENTS OPERABLE			
		Ionization	Photoelectric	Thermal	Infrared
118	New Fuel Storage Area, El. 706	2			
119	New Fuel Storage Area, El. 706	2			
120	ABGTS Filter, El. 714		1	1	
121	ABGTS Filter, El. 714		1	1	
122	Add. Eqpt. Bldg., El. 706 & 717.5	6			
124	Add. Equip. Bldg. El. 706	6			
126	ABGTS Rm., El. 714	2			
127	ABGTS Rm., El. 714	2			
128	ABGTS Rm., El. 714	2			
129	ABGTS Rm., El. 714	2			
130	Vent. & Purge Air Rm., El. 714	3			
131	Vent. & Purge Air Rm., El. 714	3			
132	Vent. & Purge Air Rm., El. 714	3			
133	Vent. & Purge Air Rm., El. 714	3			
134	Aux. Bldg. A5-A11, Col. U-W, El. 714	7			
135	Aux. Bldg. A5-A11, Col. V-W, El. 714	7			
136	Heat. & Vent. Rm., El. 714	4			
137	Heat. & Vent. Rm., El. 714	4			
138	Heat. & Vent. Rm., El. 714	4			
139	Heat. & Vent. Rm., El. 714	4			
140	Above Hot Instr. Rm., El. 714	1			
141	Above Hot Instr. Rm., El. 714	1			
142	Aux. Bldg. A1-A8, Col. Q-U, El. 714	12			
143	Aux. Bldg. A1-A8, Col. Q-U, El. 714	12			
144	Aux. Bldg. A8-A15, Col. Q-U, El. 714	9			
145	Aux. Bldg. A8-A15, Col. Q-U, El. 714	9			
146	N ₂ Storage Area, El. 706	4			
147	ABGTS Filter, El. 714		1	1	
148	ABGTS Filter, El. 714		1	1	
149	Cable Spreading Rm. C3-C7, El. 706	15			
150	Cable Spreading Rm. C3-C7, El. 706	15			
151	VCT Room 2A, El. 690	1	1		
152	VCT Room 2A, El. 690	1	1		

SEQUOYAH - UNIT 2

3/4 3-63

Amendment No. 86
Correction Letter of 5-1-89
Amendment 137