



John R. McKernan, Jr.
Governor

Rollin Ives
Commissioner

STATE OF MAINE
DEPARTMENT OF HUMAN SERVICES
AUGUSTA, MAINE 04333

January 11, 1991

United States Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D.C. 20555

Subject: Maine Yankee Atomic Power Company - Proposed Change
No. 157 - ECCS Pump Surveillance Requirements

Gentlemen:

In accordance with 10 CFR 50.91(b) the State of Maine has reviewed the proposed Technical Specification change modifying the ECCS pump surveillance frequency from monthly to quarterly testing. The State has no objections to the proposed change as the operational readiness of the ECCS pumps is already being demonstrated by the plant's quarterly inservice testing of these pumps under Technical Specification 4.7 .

Respectfully yours,

Patrick J. Dostie
State Nuclear Safety Inspector
Office of Nuclear Safety
Division of Health Engineering

cc:
Clough Toppan, State of Maine
Steve Nichols, Maine Yankee

*Adol
1/10*

9101160258 910111
PDR ADOCK 05000309
P PDR