

LICENSEE EVENT REPORT

CONTROL BLOCK: _____ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 | M I D C C 1 | 2 0 0 - 0 0 0 0 0 0 - 0 0 | 3 4 1 1 1 1 | 4 | 5
7 8 9 14 15 25 26 30 37 38

CON'T
0 1 | L | 6 0 5 0 0 0 3 1 5 | 7 1 0 0 7 8 2 | 3 | 1 1 0 5 8 2 | 9
7 8 9 14 15 25 26 30 37 38

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)
0 2 | DURING NORMAL OPERATION, THE WEST CCW HEAT EXCHANGER ESW DISCHARGE VALVE, WMO-737,
0 3 | WAS REMOVED FROM SERVICE BECAUSE IT WAS LEAKING BY. ISOLATION OF THE VALVE FOR
0 4 | REPAIRS RESULTED IN CONDITIONS CONTRARY TO T.S. 3.7.4.1 AND T.S. 3.5.2. THE ACTION
0 5 | REQUIREMENTS WERE MET. PUBLIC HEALTH AND SAFETY WERE NOT AFFECTED. THE VALVE AND
0 6 | MOTOR WERE REPLACED. SIMILAR OCCURRENCES WERE RO-050-315/82-048 AND RO-050-316
0 7 | /82-080.

0 8 | _____
7 8 9 14 15 25 26 30 37 38

0 9 | SYSTEM CODE: W A (11) CAUSE CODE: E (12) CAUSE SUBCODE: B (13) COMPONENT CODE: V A L V E X (14) COMP. SUBCODE: B (15) VALVE SUBCODE: D (16)
17 LER RO REPORT NUMBER: 8 2 (21) SEQUENTIAL REPORT NO.: 0 9 4 (24) OCCURRENCE CODE: 0 3 (28) REPORT TYPE: L (30) REVISION NO.: 0 (32)
ACTION TAKE: C (18) FUTURE ACTION: Z (19) EFFECT ON PLANT: Z (20) SHUTDOWN METHOD: Z (21) HOURS: 0 0 0 0 (22) ATTACHMENT SUBMITTED: N (23) NPRO-4 FORM SUB.: Y (24) PRIME COMP. SUPPLIER: A (25) COMPONENT MANUFACTURER: P 3 4 0 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)
1 0 | THE HENRY PRATT 16 INCH BUTTERFLY VALVE HAD BEEN INSTALLED ON 6-23-82. THE VALVE
1 1 | FAILED BECAUSE THE ELASTOMER SEAT HAD PULLED LOOSE FROM THE VALVE BODY. A
1 2 | MANUFACTURER REPRESENTATIVE INSPECTED THE DEFECTIVE VALVE AND INDICATED THAT THE
1 3 | VALVE SEAT WAS IMPROPERLY BONDED TO THE BODY DURING MANUFACTURE. ALL VALVES FROM
1 4 | THE DEFECTIVE LOT HAVE BEEN REMOVED AND WILL BE RETURNED TO THE MANUFACTURER.

1 5 | FACILITY STATUS: C (28) % POWER: 0 8 0 (29) OTHER STATUS: NA (30) METHOD OF DISCOVERY: A (31) DISCOVERY DESCRIPTION: OPERATOR OBSERVATION (32)

1 6 | ACTIVITY CONTENT: Z (33) Z (34) AMOUNT OF ACTIVITY: NA (35) LOCATION OF RELEASE: NA (36)

1 7 | PERSONNEL EXPOSURES: 0 0 0 (37) Z (38) DESCRIPTION: NA (39)

1 8 | PERSONNEL INJURIES: 0 0 0 (40) DESCRIPTION: NA (41)

1 9 | LOSS OF OR DAMAGE TO FACILITY: Z (42) DESCRIPTION: NA (43)

2 0 | PUBLICITY: N (44) DESCRIPTION: NA (45)

2 1 | NAME OF PREPARER: DWAYNE ROBINSON PHONE: 616-465-5901

8211120341 821105
PDR ADOCK 05000315
S PDR

NRC USE ONLY