

APPENDIX A
NOTICE OF VIOLATION

Duquesne Light Company
Beaver Valley Power Station, Unit 2

Docket No. 50-412
License No. CPPR-105

As a result of the inspection conducted on October 5-7, 1982 and in accordance with the NRC Enforcement Policy, 10 CFR 2, Appendix C, 47FR9987 (March 9, 1982) the following violation was identified:

10 CFR 50, Appendix B, Criterion V, requires that instructions, procedures or drawings shall include appropriate acceptance criteria to assure that important requirements have been satisfactorily accomplished. The BVPS-2 PSAR states that the Quality Assurance Program utilizes the guidance of WASH 1309, Guidance on Quality Assurance Requirements During the Construction Phase of Nuclear Power Plants. ANSI N45.2.2, endorsed by Regulatory Guide 1.38 and WASH 1309, requires instrumentation equipment to be stored under Level B conditions (as defined therein) and requires measures to be established to protect the equipment from the effects of airborne contamination. Further, BVPS-2 Specification 2BVS-981, Requirements during Storage, assigns Level B storage conditions to instrument and control cabinets and requires that measures be implemented for equipment protection from physical damage and airborne contamination.

Contrary to the above, on October 6, 1982, the Primary Process Racks and Cabinets, Motor Control Centers and the Main Control Board and Emergency Shutdown Panels, located in plant level B storage areas, were not protected from airborne contamination. Penetration caps protecting the cabinets had been removed and protective plugs were missing from the electronic equipment installed in the equipment cabinets.

This is a Severity Level IV violation (Supplement II).

Pursuant to the provisions of 10 CFR 2.201, Duquesne Light Company is hereby required to submit to this office within thirty days of the date of this Notice, a written statement or explanation in reply, including: (1) the corrective steps which have been taken and the results achieved; (2) corrective steps which will be taken to avoid further violations; and, (3) the date when full compliance will be achieved. Where good cause is shown, consideration will be given to extending the response time.

OFFICIAL RECORD COPY