

January 10, 1991

P137

Mr. Wade Green
Institute of Nuclear Power Operations
Suite 1500, 1100 Circle 75 Parkway
Atlanta, Georgia 30339-3064

Dear Mr. Green:

Enclosed for your information is our biweekly listing of generic communications being considered or under development by the NRC staff. These include Bulletins (type coded BL on the list), Information Notices (IN) and Generic Letters (GL). Temporary instructions, that cover the special NRC inspection effort resulting from certain generic communications, are listed with the type code TI. This listing includes all proposed generic communications that had been reported to us by January 8, 1991. The dates given are the ending dates for the quarter during which we expect the listings to be issued.

Generic communications that have been issued or cancelled are retained on the list for one biweekly cycle. Those issues to be dropped from the list are identified by a notation in brackets giving the status change.

Sincerely,

Original Signed By
Carl H. Berlinger

Carl H. Berlinger, Chief
Generic Communications Branch
Division of Operational Events Assessment
Office of Nuclear Reactor Regulation

Enclosure:
As stated

DISTRIBUTION w/enclosure:
All NRC Division Directors
All NRC Branch Chiefs
WTRussell, NRR
CERossi, NRR
CHBerlinger, NRR
OGCB Members
TMendiola, NRR
RFrale, ACRS
JLieberman, OE
PDR
Central files
DCB
DOEA R/F
OGCB R/F
DKirkpatrick R/
SRichardson, DOE
RBarber, DOE
ENowstrup, DOE

Document Name: LETTER TO GREEN
OGCB:DOEA:NRR C/OGCB:DOEA:NRR
DKirkpatrick CHBerlinger
01/9/91 OCK 01/9/91

Q-FEB
RD-25
INPO

9101170200 910110
PDR ORG NRRB
PDR

NRC FILE CENTER COPY

PROPOSED GENERIC COMMUNICATIONS
IN PREPARATION WITHIN THE NRC

TP ORIGINATING OFFICE	SUBJECT	CONTACT	PHONE	EST DATE QTR END
IN NRR/DRIS RVIB	[ISSUANCE UNDER REEVALUATION] ENVIRONMENTAL QUALIFICATION OF LIMITORQUE MOV ACTUATOR & MARATHON 1600 TERMINAL BLOCKS	Steve Alexander	(301) 492-0995	03/31/91
GL NRR/DEST ESGB	NRR RECOMMENDATION ON ISI OF MARK I & II STEEL CONTAINMENTS, REFUELING CAVITIES & ASSOCIATED DRAINAGE SYSTEMS	Chen P. Tan	(301) 492-3315	06/30/91
GL NRR/DEST SELB	RESOLUTION OF GI B-56, DIESEL RELIABILITY	Om P. Chopra	(301) 492-0781	03/31/91
TI NRR/DEST EMEB	INSPECTION OF IMPLEMENTATION OF GENERIC LETTER 89-10: "SAFETY RELATED MOTOR OPERATED VALVE TESTING AND SURVEILLANCE"	Tom Scarborough	(301) 492-0794	06/30/91
GL NRR/DEST SPLB	CONTROL ROOM HABITABILITY SYSTEMS	Charles Nichols	(301) 492-0856	03/31/91
IN NRR/DOEA OGCB	DIESEL GENERATOR FUEL OIL OXIDATION	Vernon Hodge	(301) 492-1861	06/30/91
TI NRR/DEST EMEB	INSPECTION OF IMPLEMENTATION OF GL 89-04: "GUIDANCE ON DEVELOPING ACCEPTABLE INSERVICE TESTING PROGRAMS"	Ted Sullivan	(301) 492-3270	03/31/91
GL RES/DSIR EIB	POTENTIAL CONCERNS REGARDING PWR REACTOR VESSEL DESIGN ADEQUACY UNDER NATURAL CONVECTION COOLDOWN TRANSIENT CONDITIONS	Joel Page	(301) 492-3941	06/30/91
BL NRR/DRIS RVIB	NONCONFORMING MATERIALS SUPPLIED BY MEREDITH CORPORATION, (PRESSURE VESSEL NUCLEAR) OF HILLSIDE NEW JERSEY	R. Cilimberg	(301) 492-0945	03/31/91
GL RES/DSIR EIB	RESOLUTION OF GI-29, BOLTING DEGRADATION OR FAILURE IN NUCLEAR POWER PLANTS	T. Y. Chang	(301) 492-3922	03/31/91
GL RES/DSIR EIB	RESOLUTION OF GI A-30, ADEQUACY OF SAFETY-RELATED DC POWER SUPPLIES	Dale Thatcher	(301) 492-3935	03/31/91

PROPOSED GENERIC COMMUNICATIONS
IN PREPARATION WITHIN THE NRC

TP ORIGINATING OFFICE	SUBJECT	CONTACT	PHONE	EST DATE QTR END
GL RES/DSIR EIB	RESOLUTION OF GI 48, LCOS FOR CLASS 1E VITAL INSTRUMENT BUS AND GI 49 INTERLOCKS AND LCO FOR CLASS 1E TIE BREAKERS	Dale Thatcher	(301) 492-3935	03/31/91
GL NRR/DOEA OTSB	LINE ITEM TECH SPEC IMPROVEMENT: CHANGING TECHNICAL SPECIFICATION SURVEILLANCE INTERVALS FROM 18 TO 24 MONTHS	Tom Dunning	(301) 492-1189	03/31/91
GL NRR/DOEA OTSB	[ISSUANCE UNDER REEVALUATION] LINE-ITEM TECH SPEC IMPROVEMENT - DIESEL GENERATOR TESTING	Ed Tomlinson	(301) 492-3150	03/31/91
IN NRR/DRIS VIB	INADEQUATE VENDOR ESTABLISHMENT AND IMPLEMENTATION OF 10CFR PART 21 PROCEDURES	Joe Petrosino	(301) 492-0979	03/31/91
IN NRR/DRIS RVIB	COUNTERFEITING OF CRANE VALVES	Steven H. Matthews	(301) 492-3191	03/31/91
BL NRR/DRIS RVIB	[ISSUANCE UNDER REEVALUATION] MALFUNCTION OF BORG-WARNER BOLTED BONNET CHECK VALVES CAUSED BY FAILURE OF THE SWING ARM	Robert Pettis Jr.	(301) 492-3214	03/31/91
IN NRR/DEST SPLB	[ISSUED 12/18/90 AS IN 90-78] PREVIOUSLY UNIDENTIFIED RELEASE PATH FROM BOILING WATER REACTOR CONTROL ROD HYDRAULIC UNITS	Charles R. Nichols	(301) 492-0854	12/18/90
IN NRR/DOEA OFAB	INADEQUATE SEPARATION OF NON-CLASS-1E UV/UF CIRCUITRY FROM REACTOR PROTECTION CIRCUITRY AT TROJAN	Walton Jensen	(301) 492-1157	03/31/91
BL NRR/DET EMCB	STEAM GENERATOR TUBE EXPANSION TRANSITION CRACKING	Emmett Murphy	(301) 492-0710	06/30/91
IN NRR/DST SICB	INSTALLATION OF DIGITAL MICROPROCESSORS INTO SAFETY SYSTEMS VIA 10 CFR 50.59	James Stewart	(301) 492-0824	03/31/91
IN NRR/DST SICB	MISAPPLICATION OF TEMPERATURE CONTROLLER LEADS TO TECHNICAL SPECIFICATION ACTION AT NUCLEAR POWER PLANT	Jerry Mauck	(301) 492-3248	03/31/91

PROPOSED GENERIC COMMUNICATIONS
IN PREPARATION WITHIN THE NRC

TP ORIGINATING OFFICE	SUBJECT	CONTACT	PHONE	EST DATE QTR END
IN AEOD	OPERATIONAL EXPERIENCE ON BUS TRANSFER	Subinoy Mazundar	(301) 492-4308	03/31/91
GL NRR/DEST SELB	GROUNDS IN DIRECT CURRENT DISTRIBUTION SYSTEMS	F. Burrows	(301) 492-3260	03/31/91
IN NRR\DRIS RSGB	BACKGROUND INVESTIGATION FOR GRANTING UNESCORTED ACCESS	Nancy Ervin	(301) 492-0946	03/31/91
GL NRR\DRIS RSGB	REPORTING OF SAFEGUARDS EVENTS	Nancy Ervin	(301) 492-0946	03/31/91
IN REGION II	SEIMENS-ITE MOLDED CASE CIRCUIT BREAKER FAILURES	Steve Alexander	(301) 492-0995	03/31/91
IN NRR/DRSP PD5	[ISSUANCE UNDER REEVALUATION] INSERVICE INSPECTION OF PAINTED REACTOR COOLANT PUMP FLYWHEELS	Roby B. Bevan	(301) 492-1361	03/31/91
IN NRR/DOEA OEAB	[ISSUED 12/20/90 AS IN 90-79] FAILURES OF MAIN STEAM ISOLATION CHECK VALVES RESULTING IN DISC SEPARATION	Angie P. Young	(301) 492-1167	12/20/90
IN NRR/DET EMCB	STRESS CORROSION CRACKING OF STEAM GENERATOR MECHANICAL PLUGS SUPPLIED BY WESTINGHOUSE	Emmett Murphy	(301) 492-0710	03/31/91
IN AEOD	SUPPLEMENT 1 TO IN 89-32: TESTING POWER OPERATED RELIEF VALVES WITH ALTERNATE PNEUMATIC SUPPLY	Vern Hodge	(301) 492-1861	03/31/91
IN NRR/DET EMEB	[ISSUED 12/21/90 AS IN 90-80] SAND INTRUSION RESULTING IN TWO DIESEL GENERATORS BECOMING INOPERABLE	J. Rajam	(301) 492-0788	12/21/90
IN AEOD	SUPPLEMENT 1 TO IN 89-90: ADDITIONAL FACTORS AFFECTING THE SET POINT OF SAFETY RELIEF VALVES	L. Mark Padovan	(301) 492-4445	03/31/91
IN NRR/DOEA OGCB	CANCELLATION OF MOV USERS GROUP SPONSORED MOV DIAGNOSTIC SYSTEM VALIDATION TESTING	R. J. Kiessel	(301) 492-0840	03/31/91
IN NMSS/IMNS	[ISSUED 1/7/91 AS IN 91-02] BRACHYTHERAPY SOURCE MANAGEMENT	Sally Merchant	(301) 492-0637	01/07/91

PROPOSED GENERIC COMMUNICATIONS
IN PREPARATION WITHIN THE NRC

TP ORIGINATING OFFICE	SUBJECT	CONTACT	PHONE	EST DATE QTR END
IN DREP/PRAB	POTENTIAL FOR INTERSYSTEM LOSS OF COOLANT ACCIDENT OUTSIDE OF THE CONTAINMENT	Sammy Diab	(301) 492-1078	03/31/91
IN NMSS/SGTR TB	[ISSUED 12/31/90 AS IN 90-82] REQMTS FOR USE OF NRC APPROVED TRANSPORT PKGS FOR SHPMNT OF TP A QUANTITIES OF RADIOACTIVE MATLS	Earl P. Easton	(301) 492-0462	12/31/90
IN REGION I	EMERGENCY DIESEL GENERATOR TESTING DEFICIENCIES	C. H. Woodward	(215) 337-5261	03/31/91
IN NRR/DRIS VIB	MAINTENANCE DEFICIENCY ASSOCIATED WITH GE CUSTOM 8000 HORIZONTAL INDUCTION MOTORS	Kamal Naidu	(301) 492-0980	03/31/91
IN AEOD/ROAB	REACTOR SCRAM AT LOW POWER FOLLOWING ERRONEOUS CONTROL ROD WITHDRAWAL	E. Trager	(301) 492-4496	03/31/91
IN NMSS/SGTR SGOB	[ISSUED 12/24/90 AS IN 90-81] FITNESS FOR DUTY	P. A. Dwyer	(301) 492-0478	12/24/90
IN NRR/DRIS RVIB	SUPPLEMENT 1 TO IN 90-43: MECHANICAL INTERFERENCE WITH THERMAL TRIP FUNCTION IN GE MOULDED-CASE CIRCUIT BREAKERS	Steve Alexander	(301) 492-0995	03/31/91
IN NRR/DRIS RVIB	[NEW] PROBLEMS WITH GE AK2 CIRCUIT BREAKERS EXPERIENCED AT ST LUCIE AND MAIN YANKEE	Steve Alexander	(301) 492-0995	03/31/91
GL NMSS	[NEW] REPORTING MISHAPS INVOLVING LOW LEVEL WASTE FORMS PREPARED FOR DISPOSAL	Michael Tokar	(301) 492-0590	03/31/91
GL NRR/DST SRXB	[NEW] SUPPLEMENT 1 TO GENERIC LETTER 88-17: LOSS OF DECAY HEAT REMOVAL	Warren Lyon	(301) 492-0892	03/31/91
IN REGION II	[NEW] INTERGRANULAR STRESS CORROSION CRACKING IN PRESSURIZED WATER REACTOR SAFETY INJECTION ACCUMULATOR NOZZLES	James L. Coley	(404) 331-5584	03/31/91