

NOV 4 1982

Docket No. 50-249

Commonwealth Edison Company
ATTN: Mr. Cordell Reed
Vice President
Post Office Box 767
Chicago, IL 60690

Gentlemen:

Thank you for your letter dated September 13, 1982, informing us of the steps you have taken to correct the items of noncompliance which we brought to your attention in Inspection Report No. 50-249/82-08 forwarded by our letter dated July 29, 1982. We will examine these matters during a subsequent inspection.

We have reviewed your request to withdraw the first item of noncompliance. None of the information in your letter changes our findings that you were using a procedure, DTS 1600-7, Revision 4, which was inadequate for the short duration test that you were trying to run. Our findings indicate that it was at our inspectors insistence that you subsequently ran a 24 hour test for which the procedure was adequate. We therefore, see no reason for withdrawing the noncompliance.

We have reviewed your request to withdraw the second item of noncompliance and have concluded that if the proper calibration records were received prior to containment integrity being required by the technical specifications, we will then withdraw the item of noncompliance.

Your cooperation with us is appreciated.

Sincerely,

"Original Signed by C.E. Norelius"

C. E. Norelius, Director
Division of Engineering and
Technical Programs

cc: Louis O. DelGeorge, Director
of Nuclear Licensing
D. J. Scott, Station
Superintendent

cc w/ltr dtd 9/13/82:
DMB/Document Control Desk (RIDS)
Resident Inspector, RIII
Karen Borgstadt, Office of
Assistant Attorney General

RIII
AM
Maura/sv
10/16/82

RIII
DLR
Robinson
8211120397 821104
PDR ADOCK 05000249
G PDR

RIII
TNT
Jackiw

RIII
R.D.W.
Walker

RIII
Little
Little

RIII
for Norelius
Norelius

1E01