PRELIMINARY NOTIFICATION OF EVENT OR UNUSUAL OCCURRENCE -- PNO-III-82-124 Date: November 8, 1982

This preliminary notification constitutes EARLY notice of events of POSSIBLE safety or public interest significance. The information is as initially received without verification or evaluation, and is basically all that is known by the staff on this date.

Facility: Iowa Electric Light & Power Co.

Duane Arnold Energy Center

Docket No. 50-331 Palo, IA 52324

Licensee Emergency Classification: Notification of Unusual Event

Alert

Site Area Emergency General Emergency xx Not Applicable

Subject: OUTAGE GREATER THAN 48 HOURS

The unit will be down until Friday, November 12, 1982, while workmen seal weld a bodyto-bonnet leak on the 1B Recirculation Pump Discharge Valve. The leak was discovered after workmen entered the drywell on November 7, 1982 to check conflicting control room position indications on a manual valve in the B Core Spray Injection System. The unit was running at less than 65 percent power when the conflicting position indications were determined. The unit was brought down to 20 percent and then manually tripped November 6. It is now in cold shutdown.

Neither the licensee nor Region III (Chicago) plans a news release. Media interest is not expected. The Resident Inspectors will monitor the licensee's repair efforts.

The State of Iowa will be notified.

Region III was notified of the event by the Headquarters Duty Officer at 2:05 a.m. (CST), November 6, 1982. This information is current as of 1 p.m. (CST) November 8, 1982.

8211120436 821108 PNO-III-82-124 PDR

DISTRIBUTION:

H. St. 332 MNBB Phillips ?? Chairman Palladino EDO Comm. Gilinsky PA Comm. Ahearne MPA Comm. Roberts ELD Air Rights 33 Comm. Asselstine SP

E/W 93/ IE OIA

Willste 31 NMSS RES

AEOD

NSAC

INPO

MAIL: ADM: DMB

DOT: Trans Only

SECY ACRS CA

Regions 1346, II 348, IV 357, V352 Licensee (Corporate Office) 354 PDR