

OCT 20 1982

yellow

Mississippi Power and Light Company
ATTN: Mr. D. C. Lutkin, President
P. O. Box 1640
Jackson, MS 39205

Gentlemen:

Subject: Confirmation of Action - Grand Gulf 1
Docket No. 50-416

This refers to the meeting held on October 14, 1982, with Mr. Norris Stampley, Senior Vice President, and other members of your staff and myself. This also refers to the telephone conversation between Mr. J. P. McGaughy and Mr. R. C. Lewis of my staff held on October 19, 1982 concerning special measures you will accomplish as a result of problems we observed in the conduct of NRC inspections. The problems are associated with the surveillance test requirements specified in the facility technical specifications.

With regard to matters discussed, it is our understanding that Mississippi Power and Light Company (MP&L) has taken or will take the following actions prior to the achievement of the next reactor criticality.

1. Ensure all surveillance procedures are technically adequate and establish an effective program to incorporate, control and implement regulatory requirements. These actions are to include technical specification surveillance, ASME Section XI Code and 10 CFR 50 Appendix J requirements.
2. Prepare and submit license amendment requests to the NRC, where necessary, to correct administrative and technical deficiencies in your technical specifications.
3. Conduct formal training of operating and staff personnel on the proper implementation of technical specification requirements, including procedure compliance.
4. Establish a formal Quality Assurance audit program to assure compliance with the above regulatory requirements.

It is our further understanding that the off-site Safety Review Committee will review the adequacy of actions described above to assure compliance with regulatory requirements. MP&L will formally notify this office when all actions have been completed.

8211150128 821020
PDR ADOCK 05000416
P PDR

IE31

OCT 20 1982

Mississippi Power and Light Company 2

Please inform this office immediately if your understanding of this matter is different from that stated above.

Sincerely,

JSI

James P. O'Reilly
Regional Administrator

CAL-416/82-01

cc: F. W. Lewis, President
Middle South Energy, Inc.
C. K. McCoy, Plant Manager

bcc: J. Olshinski, ETP
Document Management Branch
State of Mississippi
NRC Resident Inspector

[Signature]
RJI
AGWagner:gr
10/20/82

RJI *[Signature]*
FSCantrell
10/20/82

RJI *[Signature]*
DMVerrelli
10/20/82

RJI *[Signature]*
JOlshinski
10/20/82

RJI *[Signature]*
RCLewis
10/20/82

RJI *[Signature]*
CEAlderson
10/21/82