

LICENSEE EVENT REPORT

CONTROL BLOCK: _____ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 | M | A | P | P | S | 1 | 0 | 0 | - | 0 | 0 | 0 | 0 | 0 | - | 0 | 0 | 3 | 4 | 1 | 1 | 1 | 1 | 4 | 5
7 8 9 14 15 25 26 30 57 CAT 58

CON'T
0 1 | L | 0 | 5 | 0 | - | 0 | 2 | 9 | 3 | 1 | 0 | 0 | 8 | 8 | 2 | 3 | 1 | 1 | 0 | 3 | 8 | 2 | 9
7 8 60 61 68 69 74 75 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | On October 8, 1982 a water leak was observed on the 74' elevation of the reactor
0 3 | building in the RWCU Holding Pump Room. Its origin was a socket weld crack in a
0 4 | 3/4" stainless steel vent line on the RWCU System. The leak was immediately isolated
0 5 | and MR 82-13-34 issued for its repair. The vent line was replaced, tested and the
0 6 | isolated line returned to service at approximately 0015 hours on October 19, 1982.
0 7 | This event did not threaten the health and welfare of the public.

0 8 | _____ 80

0 9 | SYSTEM CODE: C G (11); CAUSE CODE: B (12); CAUSE SUBCODE: B (13); COMPONENT CODE: P I P E X X (14); COMP. SUBCODE: A (15); VALVE SUBCODE: Z (16)
17 | LER/RO REPORT NUMBER: 8 2 (21); SEQUENTIAL REPORT NO.: 0 4 7 (24); OCCURRENCE CODE: 0 3 (28); REPORT TYPE: L (30); REVISION NO.: 0 (32)
ACTION TAKEN: C (33); FUTURE ACTION: Z (34); EFFECT ON PLANT: Z (35); SHUTDOWN METHOD: Z (36); HOURS: 0 0 0 0 (37); ATTACHMENT SUBMITTED: N (41); NRPD-4 FORM SUB.: N (42); PRIME COMP. SUPPLIER: A (43); COMPONENT MANUFACTURER: Z 9 9 9 (44)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 | Dye penetrant examination revealed other socket weld cracks in the vent assembly. A
1 1 | new assembly was fabricated and installed. Examination of the removed sections
1 2 | revealed that socket connections were bottomed out; however, additional examinations
1 3 | are being scheduled. The root cause of this event has been tentatively attributed to
1 4 | improper fabrication during original construction.

1 5 | FACILITY STATUS: E (28); % POWER: 0 8 5 (29); OTHER STATUS: NA (30); METHOD OF DISCOVERY: A (31); DISCOVERY DESCRIPTION: Operational Event (32)

1 6 | ACTIVITY CONTENT RELEASED OF RELEASE: Z (33); AMOUNT OF ACTIVITY: NA (35); LOCATION OF RELEASE: NA (36)

1 7 | PERSONNEL EXPOSURES NUMBER: 0 0 0 (37); TYPE: Z (38); DESCRIPTION: NA (39)

1 8 | PERSONNEL INJURIES NUMBER: 0 0 0 (40); DESCRIPTION: NA (41)

1 9 | LOSS OF OR DAMAGE TO F TYPE: Z (42); DESCRIPTION: NA (43)

2 0 | PUBLICITY ISSUED: N (44); DESCRIPTION: NA (45)

8211150131 821103
PDR ADOCK 05000293
S PDR

NAME OF PREPARER M. Thomas McLoughlin

PHONE: 617-746-7900

NRC USE ONLY

GPO 917-952