

CATAWBA NUCLEAR STATION
MONTHLY OPERATING STATUS REPORT

November 1990

1. Personnel Exposure -

For the month of November, no individual(s) exceeded 10 percent of their allowable annual radiation dose limit.

2. The total station liquid release for November has been compared with the Technical Specifications maximum annual dose commitment and was less than 10 percent of this limit.

The total station gaseous release for November has been compared with the Technical Specifications maximum annual dose commitment and was less than 10 percent of this list.

9101180303 910115
PDR ADOCK 05000413
R PDR