NRC FORM 366 (12-81) APPROVED BY OMB 3150-0011 EXPIRES 4-30-82 U.S. NUCLEAR REGULATORY COMMISSION LICENSEE EVENT REPORT (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION) CONTROL BLOCK: 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 SE (2) 0 0 0 1 A CON'T REPORT L 6 0 5 0 0 0 3 8 7 7 1 0 0 4 8 2 8 1 1 0 3 8 2 SOURCE L 6 0 5 0 0 0 3 8 7 7 1 0 0 4 8 2 8 1 1 0 3 8 2 0 1 EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10) During startup testing the Reactor Building Special Particulate Iodine Noble 0 2 Gas Monitor was removed from service to work on the pump. Remote sampling was 0 3 0 4 initiated to comply with the action statement. However, sampling was dis-0 5 continued prior to complete sign-off of the Work Authorization and declaring 0 the SPING operable. This is reportable per 6.9.1.9.c. 0 7 0 8 80 CODE COMP. CAUSE CAUSE VALVE COMPONENT CODE (16) B (13) RU X Z 0 9 M C S T A SEQUENTIAL REVISION NO. OCCURRENCE REPORT CODE LER/RO REPORT NUMBER 3 8 0 (17) 0 0 8 31 32 ATTACHMENT RIME COMP. EFFECT SHUTDOWN NPRD-4 COMPONENT ER (26) ACTION (22) HOURS sua. MANUFACTUR METHOD TAKEN ACTION N 23 N 24 A (25) Z 20 Z (21) 18 H 19 00 0 E 0 7 0 X 0 CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27) Sampling was discontinued based on information received by Chemistry from 1 0 the Control Room. The SPING was physically operable, however, the paperwork had not been completed. An Operating Instruction will be written to prevent anyone but the Shift Supervisor from discontinuing samplings being performed to comply with action statements. 4 METHOD OF FACILITY (30) DISCOVERY DESCRIPTION POWER OTHER STATUS (32)B (28) 0 0 0 29 A (31) operator observation n/a 12 10 ACTIVITY CONTENT (35) LOCATION OF RELEASE (36) AMOUNT OF ACTIVITY n/a 6 Z 33 Z 34 1 n/a 1.1 PERSONNEL EXPOSURES UMBER 00037Z38 1 n/a 11 12 80 PERSONNEL INJURIES 0 0 0 0 2 8 n/a 8211150163 821103 PDR ADOCK 05000387 12 11 LOSS OF OR DAMAGE TO FACILITY PDR S Z (42) n/a 9 ISSUED DESCRIPTION 45 NRC USE ONLY Z 44 0 n/a 2 NAME OF PREPARER D.G. Mitchell PHONE: (717) 542-2181 X524