ADM: DMB

DOT: Trans Only

Applicable State

## PRELIMINARY NOTIFICATION OF EVENT OR UNUSUAL OCCURRENCE PNO-II-82-118

This preliminary notification constitutes EARLY notice of events of POSSIBLE safety or public interest significance. The information is as initially received without verification or evaluation, and is basically all that is known by the Region II staff on this date.

FACILITY:	Alabama Power Company	Licensee Emergency Classification:
	Farley Unit 2	Notification of Unusual Event
	Docket No. 50-364	Alert
	Dothan, Alabama	Site Area Emergency
		General Emergency
		X Not Applicable

## SUBJECT: LOCKED CONTAINMENT SPRAY VALVES

The licensee found the Farley Unit 2 containment spray maintenance valves locked closed at 10:30 a.m. on October 28. The unit is out of service for refueling and maintenance and has been in cold shutdown since October 24.

Containment spray valves on Unit 1, which was operating, were checked and found to be locked open as required.

The licensee is now investigating to determine whether the Unit 2 valve were closed after shutdown of the reactor or were closed during reactor operations.

Media interest has occurred. The licensee issued a press release over the weekend. The NRC does not plan a news release.

The State Alabama has been informed.

Region II (Atlanta) was notified of this occurrence at 11:30 a.m. on October 28. This information is current as of 10 a.m. on November 1.

Contact: D. M. Verrelli, RII 242-5581

DISTRIBUTION: MNBB/0 40Phillips 1036E/W 1030 Willste / MAIL: H. Street Chairman Palladino EDO NRR NMSS Comm. Gilinsky PA OIA RES Comm. Ahearne MPA AEOD Comm. Roberts ELD Comm. Asselstine Air Rights 1:10 INPO SECY NSAC ACRS CA PDR

Regions: Licensee: 11:55 (Reactor Licensees) Applicable Resident Site //: 40

8211150186 821101 PDR I&E PNO-II-82-118 PDI PDR