

APPENDIX A  
NOTICE OF VIOLATION

Connecticut Yankee Atomic Power Company  
Hartford, Connecticut

Docket No. 50-213  
License No. DPR-61

As a result of the inspection conducted from October 1 to October 5, 1990, and subsequent staff review through December 14, 1990, and in accordance with the "General Statement of Policy and Procedure for NRC Enforcement Actions," 10 CFR Part 2, Appendix C (Enforcement Policy) (1990), the following violation was identified:

10 CFR 50.49 Paragraph f requires that electric equipment important to safety be environmentally qualified by type testing, analysis, or a combination of both.

The auxiliary feedwater flow instruments and the containment pressure transmitters are classified by the licensee as Type A variable instruments for RG 1.97 implementation. Type A variable instruments (RG 1.97 Category 1 instruments) are considered electric equipment important to safety as specified in Paragraph b.2 of 10 CFR 50.49.

Contrary to the above, on October 5, 1990, all four auxiliary feedwater flow transmitters and the associated terminal blocks, and the containment pressure transmitters, were not environmentally qualified.

This is a Severity Level IV Violation (Supplement 1).

Pursuant to the provisions of 10 CFR 2.201, Connecticut Yankee Atomic Power Company is hereby required to submit to this office within thirty days of the date of the letter which transmitted this Notice, a written statement or explanation in reply, including: (1) the corrective steps which have been taken and the results achieved; (2) corrective steps which will be taken to avoid further violations; and (3) the date when full compliance will be achieved. Where good cause is shown, consideration will be given to extending this response time.

OFFICIAL RECORD COPY

IR HADDAM NECK 90-16 - 0003.0.0  
01/08/91

9101220071 910110  
PDR ADDCK 05000213  
Q PDR