

January 16, 1991

Docket Nos: 50-321 and 50-366  
50-424 and 50-425

DISTRIBUTION

<u>Docket File</u>	OGC
NRC PDR	EJordan
Local PDR	ACRS (10)
JPartlow	PDII-3 R/F
GLainas	Hatch R/F
RIngram	Vogtle R/F
KJabbour	H Berkow
DHood	D Miller

Mr. W. G. Hairston III  
Senior Vice President - Nuclear Operations  
Georgia Power Company  
P.O. Box 1295  
Birmingham, Alabama 35201

Dear Mr. Hairston:

SUBJECT: UNIMPLEMENTED GENERIC SAFETY ISSUES AT THE EDWIN I. HATCH NUCLEAR PLANT AND THE VOGTLE ELECTRIC GENERATING PLANT

On April 25, 1990, the staff issued Generic Letter 90-04 which requested information concerning the implementation status of certain generic safety issues (GSIs) at your facilities. Based on your June 25, 1990, responses to this Generic Letter, our own records and discussions with your staff, we have updated our database on GSI implementation status. The results of this effort were presented to the Commission at a meeting on October 25, 1990.

The two enclosures to this letter summarize the staff's understanding of the current status of those GSIs which remain unimplemented at the Hatch and Vogtle facilities. We appreciate the assistance you provided in responding to Generic Letter 90-04, and we encourage your timely completion of those GSIs listed in the enclosures.

Please contact me or the respective Project Manager if you have any questions or comments about the enclosed information.

Sincerely,

*DM*  
David B. Matthews, Director  
Project Directorate II-3  
Division of Reactor Projects I/II  
Office of Nuclear Reactor Regulation

Enclosures:  
As stated

cc w/enclosures:  
See next page

OFC	:LA:PDII-3	: <i>MP/50</i>	:PM:PDII-3	:O:PDII-3	:	:
NAME	:RIngram/rst	:KJabbour	:DHood <i>DSH</i>	:DMatthews	:	:
DATE	: 1/10/91	: 1/10/91	: 1/10/91	: 1/10/91	:	:

OFFICIAL RECORD COPY  
Document Name: GSI SAMPLE LETTER

9101220093 910116  
PDR ADOCK 05000321 PDR  
P

*DF01  
111*

Mr. W. G. Hairston, III Edwin I. Hatch Nuclear Plant  
Georgia Power Company Vogtle Electric Generating Plant

cc:

Shaw, Pittman, Potts and Trowbridge  
2300 N Street, N.W.  
Washington, D.C. 20037

Mr. J. T. Beckham  
Vice President - Plant Hatch  
Georgia Power Company  
P. O. Box 1295  
Birmingham, Alabama 35201

Mr. S. J. Bethay  
Manager Licensing - Hatch  
Georgia Power Company  
P.O. Box 1295  
Birmingham, Alabama 35201

Mr. H. C. Nix  
General Manager, Nuclear Plant  
Georgia Power Company  
Route 1, Box 439  
Baxley, Georgia 31513

Resident Inspector  
U.S. Nuclear Regulatory Commission  
Route 1, Box 725  
Baxley, Georgia 31513

Regional Administrator, Region II  
U.S. Nuclear Regulatory Commission  
101 Marietta Street, Suite 2900  
Atlanta, Georgia 30323

Mr. Charles H. Badger  
Office Planning and Budget  
Room 610  
270 Washington Street, S.W.  
Atlanta, Georgia 30334

Mr. J. Leonard Ledbetter, Director  
Environmental Protection Division  
Department of Natural Resources  
205 Butler Street, S.E., Suite 1252  
Atlanta, Georgia 30334

Chairman  
Applying County Commissioners  
County Courthouse  
Baxley, Georgia 31513

Mr. R. P. McDonald  
Executive Vice President -  
Nuclear Operations  
Georgia Power Company  
P. O. Box 1295  
Birmingham, Alabama 35201

Mr. Alan R. Herdt, Chief  
Project Branch #3  
U.S. Nuclear Regulatory Commission  
101 Marietta Street, NW, Suite 2900  
Atlanta, Georgia 30323

J. A. Bailey  
Manager - Licensing  
Georgia Power Company  
P.O. Box 1295  
Birmingham, Alabama 35201

Mr. G. Bockhold, Jr.  
General Manager, Vogtle Electric  
Generating Plant  
P.O. Box 1600  
Waynesboro, Georgia 30830

Office of the County Commissioner  
Burke County Commission  
Waynesboro, Georgia 30830

Office of Planning and Budget  
Room 615B  
270 Washington Street, S.W.  
Atlanta, Georgia 30334

Mr. C. K. McCoy  
Vice President - Nuclear,  
Vogtle Project  
Georgia Power Company  
P.O. Box 1295  
Birmingham, Alabama 35201

Resident Inspector  
Nuclear Regulatory Commission  
P.O. Box 572  
Waynesboro, Georgia 30830

Attorney General  
Law Department  
132 Judicial Building  
Atlanta, Georgia 30323

cc:

Mr. Dan Smith  
Program Director of Power Production  
Oglethorpe Power Corporation  
100 Crescent Centre  
Tucker, Georgia 30085

Charles A. Patrizia, Esq.  
Paul, Hastings, Janofsky & Walker  
12th Floor  
1050 Connecticut Avenue, N.W.  
Washington, D.C. 20036

Enclosure 1

UNIMPLEMENTED GSIs AT EDWIN I. HATCH NUCLEAR PLANT

<u>GS1 NO.</u>	<u>TITLE</u>	<u>PROJECTED IMPLEMENTATION DATE</u>	<u>REMARKS</u>
51	Improving the Reliability of Open-Cycle Service Water Systems	Fall 1991	Final report to be submitted following Unit 1 Fall 1991 outage
67.3.3	Improved Accident Monitoring	No Sched Estab	Licensee to evaluate installation of improved instrumentation
75	Salem ATWS Item 2.2.2. Vendor Interface for Safety-Related Components	GPC responded 9/24/90	Under NRC staff review

## Enclosure 2

## UNIMPLEMENTED GSIs AT VOGTLE ELECTRIC GENERATING PLANT

<u>GSI NO.</u>	<u>TITLE</u>	<u>PROJECTED IMPLEMENTATION DATE</u>	<u>REMARKS</u>
51	Improving the Reliability of Open-Cycle Service Water Systems	Fall 1991	Final report to be submitted following Unit 1 Fall 1991 outage
	RCS/RHR Suction Line Valve Interlocks on PWRs (GL 88-17)	Fall 1991 Refueling Outage - Unit 1	Re-modify permanent RCS level indication.
67.3.3	Improved Accident Monitoring	No Sched Established	NRC staff generic review of accum level instrumentation qualification is ongoing.
75	Salem ATWS Item 2.2.2, Vendor Interface for Safety-Related Components	GPC responded 9/28/90	GPC's exception to GL 90-03 is under review.