

AVERAGE DAILY UNIT POWER LEVEL

BUCKET NO 50-368
 UNIT 2
 DATE 9/14/81
 COMPLETED BY L. J. Bravette
 TELE. NO. 501-912-2519

MONTH August

DAY	AVERAGE DAILY POWER LEVEL (Gross Net)
1	880 880
2	883 883
3	885 885
4	881 881
5	879 879
6	878
7	877
8	191
9	195
10	848
11	557
12	513
13	849 849
14	497
15	77
16	377

DAY	AVERAGE DAILY POWER LEVEL (Gross Net)
17	852
18	854
19	854
20	397
21	0
22	410
23	874
24	872
25	816
26	858
27	849
28	836
29	838
30	830
31	826

Arkansas 2 operated routinely during August.

INSTRUCTIONS

On this form, list the average daily unit power level in Net (Net) for each day in the reporting month. Compute to the nearest whole megawatt.

PM71

COPY

IE37

UNIT SHUTDOWNS AND POWER REDUCTIONS

REPORT MONTH August

DOCKET NO. 50-368
 UNIT NAME 197-01-11
 DATE 8-31-81
 COMPLETED BY A. S. S. S. S. S.
 TELEPHONE 1-501-2-34454

Date	Time	Duration (Hours)	Reason	Method of Starting (When Reason)	License Plan Report #	Shift Code	Component Code	Cause & Corrective Action to Prevent Recurrence
810008	F	9.9	B	3	81-031	M	XXXX	Fallen overspeed trip signal during a surveillance test.
810008	F	1.8	A	3	81-031 81-031	RB	C'DRVE	PLCA #22 dropped.
810009	F	7.3 7.3	A	1	81-031 81-031	B	C'DRVE	PLCA #22 dropped/T.S. 3.1.3.1. MFW
810011	F	12.3 24.5	B	2	81-031	B	XXXX	Inadvertent load of MFW pump lube oil.
810014	F	8.6	B	3	81-031	B	XXXX	Inadvertent MSIV ^A closure.
810015	F	8.6	A	2	81-031	HF	C'KTBK	Loss of condenser vacuum.
810020	F	41.0	A	2	81-031	EP	C'RTXX PIPEXX PIPEXX	MSIV closure on loss of valve operator air supply. ON LOSS

Force
 Included

Reason:
 A-Equipment Failure (Explain)
 B-Maintenance of Test
 C-Reforling
 D-Regulatory Restriction
 E-Operator Training & License Examination
 F-Administrative
 G-Operational Error (Explain)
 H-Other (Explain)

Method:
 1-Manual
 2-Manual Screen
 3-Automatic Screen
 4-Continuation
 5-Load Reduction
 9-Other

Exhibit C - Instructions
 for Preparation of Data
 Entry Sheets for License
 Event Report - LER1 Form (NUREG-
 0161)

Exhibit I - Same Source