

APPENDIX A

NOTICE OF VIOLATION

Virginia Electric & Power  
North Anna 1 and 2

Docket Nos. 50-338 & 50-339  
License Nos. NPF-4 & NPF-7

As a result of the inspection conducted on August 6 - September 5, 1982, and in accordance with the NRC Enforcement Policy, 47 FR 9987 (March 9, 1982), the following violation was identified.

Technical Specification 4.7.8.1.c requires as a surveillance on the safeguards area ventilation system, that after every 720 hours of charcoal absorber operation a laboratory analysis of a representative carbon sample be obtained.

Contrary to the above, as of August 27, 1982, a representative carbon sample had not been taken after 720 hours of operation on the charcoal absorbers. Both trains of the system had been in operation for over 2800 hours since the last test.

This is a Severity Level IV Violation (Supplement I.).

Pursuant to the provisions of 10 CFR 2.201, you are hereby required to submit to this office within thirty days of the date of this Notice, a written statement or explanation in reply, including: (1) admission or denial of the alleged violation; (2) the reasons for the violation if admitted; (3) the corrective steps which have been taken and the results achieved; (4) corrective steps which will be taken to avoid further violations; and (5) the date when full compliance will be achieved. Consideration may be given to extending your response time for good cause shown.

Date: OCT 4 1982