

January 10, 1991

Docket No. 50-219

Mr. E. E. Fitzpatrick
Vice President and Director
Oyster Creek Nuclear Generating Station
Post Office Box 388
Forked River, New Jersey 08731

DISTRIBUTION

Docket File EJordan
NRC & L PDRs GHill (4)
PDI-4 File Wanda Jones
ADromerick JCalvo
SNorris ACRS (10)
SVarga GPA/PA
OGC OC/LFMB
DHagan

Dear Mr. Fitzpatrick:

SUBJECT: ISSUANCE OF AMENDMENT (TAC NO. 76132)

The Commission has issued the enclosed Amendment No.144 to Provisional Operating License No. DPR-16 for the Oyster Creek Nuclear Generating Station, in response to your application dated March 2, 1990 as supplemented November 29, and December 21, 1990.

The amendment revises Technical Specification (TS) 1.12, "Refueling Outage" to specify that refueling outage tests or surveillances shall be performed at least once per 24 months. The revised Technical Specification affects surveillance tests of several systems and components.

The amendment also revises several Technical Specification surveillance requirements on a refueling outage basis that have not been completely evaluated for extension from 20 months to 24 months.

Your request to amend License Condition 2.C.7 is addressed in Amendment No. 143 of Provisional Operating License DPR-16. Additionally TS Table 4.1.1, Item 15, TS Table 4.1.1, Items 28a and 28b, TS 4.2.3, TS 4.5.E, TS 4.7.A.2 and A3, and TS 6.15 were addressed in Amendment No. 141 to Provisional Operating License DPR-16.

A copy of the related Safety Evaluation is also enclosed. Also enclosed is the Notice of Issuance which has been forwarded to the Office of the Federal Register for Publication.

Sincerely,

Alexander W. Dromerick, Senior Project Manager
Project Directorate I-4
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Enclosures:

- 1. Amendment No.144 to DPR-16
- 2. Safety Evaluation
- 3. Notice

9101220244 910110
PDR ADOCK 05000219
P PDR

cc w/enclosures:

See next page

Document Name: AMEND 76132

*SEE PREVIOUS CONCURRENCE

OFC	:PDI-4:LA	:PDI-4:PM*	:PDI-4:D*	:OGC*	:
NAME	:SNorris	:ADromerick/Bah	:JStolz	:	:
DATE	: 11/7/91	:12/17/90	:12/19/90	:12/27/90	:

180051

January 10, 1991

Docket No. 50-219

Mr. E. E. Fitzpatrick
Vice President and Director
Oyster Creek Nuclear Generating Station
Post Office Box 388
Forked River, New Jersey 08731

DISTRIBUTION

Docket file EJordan
NRC & L PDRs GH111 (4)
PDI-4 File Wanda Jones
ADromerick JCaivo
SNorris ACRS (10)
SVarga GPA/PA
OGC OC/LFMB
DHagan

Dear Mr. Fitzpatrick:

SUBJECT: ISSUANCE OF AMENDMENT (TAC NO. 76132)

The Commission has issued the enclosed Amendment No. to Provisional Operating License No. DPR-16 for the Oyster Creek Nuclear Generating Station, in response to your application dated March 2, 1990 as supplemented November 29, 1990.

The amendment revises Technical Specification (TS) 1.12, "Refueling Outage" to specify that refueling outage tests or surveillances shall be performed at least once per 24 months. The revised Technical Specification affects surveillance tests of several systems and components.

The amendment also revises several Technical Specification surveillance requirements on a refueling outage basis that have not been completely evaluated for extension from 20 months to 24 months.

Your request to amend License Condition 2.C.7 is addressed in Amendment of Provisional Operating License DPR-16. Additionally TS Table 4.1.1, Item 15, TS Table 4.1.1, Items 28a and 28b, TS 4.2.3, TS 4.5.E, TS 4.7.A.2 and A3, and TS 6.15 were addressed in Amendment 141 to Provisional Operating License DPR-16.

A copy of the related Safety Evaluation is also enclosed. Also enclosed is the Notice of Issuance which has been forwarded to the Office of the Federal Register for Publication.

Sincerely,

Alexander W. Dromerick, Senior Project Manager
Project Directorate I-4
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Enclosures:

- 1. Amendment No. to DPR-16
- 2. Safety Evaluation
- 3. Notice

cc w/enclosures:
See next page

Document Name: AMEND 76132

under subject to correction of

numbers notice TYPED

*12/19/90
with enclosure
initials*

OFC	: PDI-4:LA	: PDI-4:PM	: PDI-4:D	: OGC	:
NAME	: SNorris	: ADromerick/Bah	: JStolz	: B.W.B	:
DATE	:	: 12-17-90	: 12-19-90	: 12-27-90	:

Mr. E. E. Fitzpatrick
Oyster Creek Nuclear Generating Station

Oyster Creek Nuclear
Generating Station

cc:

Ernest L. Blake, Jr.
Shaw, Pittman, Potts and Trowbridge
2300 N Street, NW
Washington, D.C. 20037

Resident Inspector
c/o U.S. NRC
Post Office Box 445
Forked River, New Jersey 08731

I. H. Jolles, Executive Vice President
GPU Service Corporation
100 Interpace Parkway
Parsippany, New Jersey 07054

Commissioner
New Jersey Department of Energy
101 Commerce Street
Newark, New Jersey 07102

Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, Pennsylvania 19406

Kent Tosch, Chief
New Jersey Department of Environmental
Protection
Bureau of Nuclear Engineering
CN 415
Trenton, New Jersey 08625

BWR Licensing Manager
GPU Nuclear Corporation
1 Upper Pond Road
Parsippany, New Jersey 07054

Mayor
Lacey Township
818 West Lacey Road
Forked River, New Jersey 08731

Licensing Manager
Oyster Creek Nuclear Generating Station
Mail Stop: Site Emergency Bldg.
P. O. Box 388
Forked River, New Jersey 08731