

4 SURVEILLANCE REQUIREMENTS

4.0 APPLICABILITY

SURVEILLANCE REQUIREMENTS

4.0.1 Surveillance Requirements shall be applicable during the RECOVERY MODE or other conditions specified for individual Limiting Conditions for Operation unless otherwise stated in an individual Surveillance Requirement or exempted in a procedure approved pursuant to Technical Specification 6.8.2. The Surveillance Requirements shall be performed to demonstrate compliance with the OPERABILITY requirements of the Limiting Conditions for Operations and in accordance with the RECOVERY OPERATIONS PLAN; however, the RECOVERY OPERATIONS PLAN shall not be considered a part of these technical specifications. Changes to the RECOVERY OPERATIONS PLAN shall be approved by the NRC prior to implementation.

4.0.2 Each Surveillance Requirements shall be performed within the specified time interval with:

- a. A maximum allowable extension not to exceed 25% of the surveillance interval, and
- b. A total maximum combined interval time of any 4 consecutive tests not to exceed 3.25 times the specified surveillance interval.

4.0.3 Performance of a Surveillance Requirement within the specified time interval shall constitute compliance with OPERABILITY requirements for a Limiting Condition for Operation and associated ACTION statements unless otherwise required by the specification.