

LICENSEE EVENT REPORT

CONTROL BLOCK: _____ (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 | G | A | E | I | H | 2 | 2 | 0 | 0 | - | 0 | 0 | 0 | 0 | 0 | - | 0 | 0 | 3 | 4 | 1 | 1 | 1 | 1 | 4 | 5
7 8 9 14 15 25 26 30 57 CAT 58

CON'T
0 1 | L | 6 | 0 | 5 | 0 | 0 | 0 | 3 | 6 | 6 | 7 | 0 | 1 | 0 | 3 | 7 | 9 | 8 | 1 | 1 | 0 | 9 | 8 | 2 | 9
7 8 60 61 68 69 74 75 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | With the unit in cold shutdown while performing the "RPS MG SET OVERVOL-
0 3 | TAGE, UNDER FREQUENCY, & UNDERVOLTAGE FT&C" procedure, the undervoltage
0 4 | trip on RPS M-G set "A" was found at 59.1 VAC. The expected setpoint per
0 5 | procedure is 110 VAC +/- 1 VAC. The Tech. Specs. limit is >= 108 VAC
0 6 | (T.S. 4.8.2.7.b.2). The health and safety of the public were not
0 7 | affected by this non-repetitive event.

0 8 | _____ 80

0 9 | SYSTEM CODE: I F (11) CAUSE CODE: B (12) CAUSE SUBCODE: A (13) COMPONENT CODE: R E L A Y X (14) COMP. SUBCODE: D (15) VALVE SUBCODE: Z (16)
17 | LER/RO REPORT NUMBER: 7 9 (17) EVENT YEAR: 7 9 (21) SEQUENTIAL REPORT NO.: 0 0 7 (24) OCCURRENCE CODE: 0 3 (28) REPORT TYPE: X (30) REVISION NO.: 1 (32)
ACTION TAKEN: F (18) FUTURE ACTION: Z (19) EFFECT ON PLANT: Z (20) SHUTDOWN METHOD: Z (21) HOURS: 0 0 0 0 (22) ATTACHMENT SUBMITTED: N (23) NPRD-4 FORM SUB.: N (24) PRIME COMP. SUPPLIER: N (25) COMPONENT MANUFACTURER: G 0 8 0 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 | The undervoltage setpoint was too low because the breaker is designed to
1 1 | trip at 30% to 60% of rated voltage (120 VAC); therefore, it is not cap-
1 2 | able of meeting Tech. Specs. requirements. A design change involving the
1 3 | addition of a breaker capable of de-energizing the Reactor Protection
1 4 | System within Tech. Specs. limits was completed on April 9, 1982.

1 5 | FACILITY STATUS: G (28) % POWER: 0 0 0 0 (29) OTHER STATUS: NA (30) METHOD OF DISCOVERY: B (31) DISCOVERY DESCRIPTION: Surveillance Test (32)

1 6 | ACTIVITY RELEASED: Z (33) CONTENT OF RELEASE: Z (34) AMOUNT OF ACTIVITY: NA (35) LOCATION OF RELEASE: NA (36)

1 7 | PERSONNEL EXPOSURES: NUMBER: 0 0 0 (37) TYPE: Z (38) DESCRIPTION: NA (39)

1 8 | PERSONNEL INJURIES: NUMBER: 0 0 0 (40) DESCRIPTION: NA (41)

1 9 | LOSS OF OR DAMAGE TO FACILITY: TYPE: Z (42) DESCRIPTION: NA (43) 8211170281 821109 PDR ADOCK 05000366 S PDR

2 0 | PUBLICITY ISSUED: N (44) DESCRIPTION: NA (45) NRC USE ONLY
NAME OF PREPARER: S. B. Tipps PHONE: (912) 367-7851