

RTI Inc.

108 LAKE DENMARK ROAD, ROCKAWAY, NJ 07866
(201) 625-8400 • FAX (201) 625-7820

August 30, 1989

Mr. Malcolm R. Knapp, Director
United States
Nuclear Regulatory Commission
Region 1
475 Allendale Road
King of Prussia, PA 19406

Subject: Enforcement Conference Report No. 030-07022/89-002

Dear Mr. Knapp:

Reference is made to your letter and enclosure of August 22, 1989, in which you included a copy of the above-referenced Enforcement Conference Report. As you indicated in your letter, no reply to your letter is required. We note that the Enforcement Conference Report summarizes the Conference which took place on April 26, 1989. We understand that such reports must be in summary fashion, however, we believe that certain sections of the report, from our standpoint, require supplementation or clarification. Accordingly, we request that this letter be filed with the Enforcement Conference Report for that purpose.

I.

The third and fourth sentences on page 3, of the report, state as follows: "Once the problem was reported to the Radiation Safety Office, he took immediate action to repair it. The licensee contends that the door was never opened without the use of the required key and that no one gained access to the irradiator cell without using the required key to open the door."

RTI believes that a more complete summary of the Conference would state as follows. The first two sentences of the paragraph would remain the same. The following sentence, beginning with the phrase "The licensee contends" should be changed to read: The Licensee contended that inadvertent access through the door to the irradiator cell could not occur. The licensee noted that the door has two interlocks, the door latch and the limit switch both of which were fully functional at all times. During the routine audit of February 13, 1989, the doorknob was vigorously twisted with the use of excessive force to intentionally test the interlock system. As a result of this test the door opened, the source immediately dropped to the shielded position as required. Operations were suspended pending corrective action.

9101220384 900913
PDR FOIA
JONES90-334 PDR

B/41

AUG 31 1989

Page 2
August 30, 1989
Mr. Malcolm R. Knapp

The following statement on page 3 of the Inspection Report was also discussed:

"During the March 21 and 23, 1989, inspection, the inspector learned that, on March 9, 1989, the licensee removed the 90 second start-up time delay (cell start-up key switch) and installed a toggle switch for the purpose of continuing irradiator operations."

There is an apparent misunderstanding that the 90 second start up time delay was removed. This is in fact, incorrect, in that only the mechanism for activating this time delay was changed from the key switch to a toggle switch.


The following statement on page 4 of the Inspection Report was also discussed:

"During the week of February 5, 1989 the operator again experienced problems with the personnel access door lock mechanism which affected the interlock. In this case, the lock mechanism malfunctioned such that it no longer provided a positive lock to prevent inadvertent personnel access to the irradiator cell. This condition was such that an individual could have opened the access door without the irradiator key. The operator notified the RSO and the Plant Superintendent of the problem."


The Vice-President of Operations and Engineering stated that he had spoken with the operator in question, and that he was not sure of whether the operator was "telling him what he wanted to hear" but the operator indicated he had read the Inspection Report and disagreed with the implications found therein. Marlene Taylor, NRC Inspector, stated that although she had talked to other operators, she did not have an opportunity to talk with the other operators about the personnel access door matter.

Your cooperation with regard to this matter is appreciated.


Sincerely,



John N. Scandalios
President

JNS:jk




**TI
APERTURE
CARD**





卷之三

National Curriculum Framework



MEMORANDUM

TO: John Scandalios
FROM: John D.Schlecht/ Plant Manager NJPTI
SUBJECT: System Problems on 8/12/89 and 8/13/89
DATE: August 14, 1989

On August 12, 1989 I received a phone call from Dave Smith, the shift supervisor, at 8:00 PM. He informed me that he could not get the system running and that he did not know what the problem was. I arrived at 9:15 PM and assessed the situation. The computer was not allowing access through the keyboard. A message was displaying "Unable to Complete Operation". I reset the system using the MCR (Master Control Relay) over the PLC. The system rebooted. The display now indicated the system was at the seventh index rather than the fourth index as displayed before resetting. We confirmed that the new display was correct by examining the carriers in the cell.

When we attempted to restart we continued to get an alarm indicating CIA travel timed out. We attempted to fix the problem but to no avail. We now continued to get "Carrier Missing at CIA" messages. I aborted the run at 10:11 PM. The system continued to display the "Carrier Missing at CIA+" message. We tried many methods to fix the situation. I cancelled third shift at 1:30 AM.

Myself and Mr. Singleton resumed corrective action at 6:00 AM on 8-13-89. We removed all carriers from the cell and I manually stroked the cylinders to their correct positions. Startup was still not allowed due to "Carrier Missing at CIA+" alarm. We tested the microswitches at CIA and ClB using a voltmeter. All switches tested O.K.. In order to further test the system I forced out this alarm through output C143 in the Logic. This allowed us to raise the source in a static mode. This step did not compromise safety because the carrier missing switches are not applicable to static runs.

We topped off [REDACTED] using static dwells and manually moving the carriers after tr. source dropped. All dosimetry from Osteonics was acceptable.

MEM was run the evening of 8-13-89 in a static mode.

At 6:00 AM 8-14-89 myself and Mr. Singleton continued to work on the problem. All limit switches for cylinders CIA and ClB were replaced. I removed the "force" on output C143 ("Carrier Missing at CIA+") of the program. All now appeared normal.

We ran the system in an "Auto Test" Mode to ensure proper functioning of the cylinders. All functioned properly. We then went up on an SIT and resumed normal operations at 7:49 AM.

B/29

The changing of the limit switches appears to have solved the problem. The initial problem that Mr. Smith encountered involved C1B, so this is logical. The loss of 3 indexes in the computer printout could have occurred if the printer was inadvertently shut off.

All pertinent logs and printouts are attached for inspection.

J. D. Schlecht
John D. Schlecht
Plant Manager

cc: M. Buring
P. Skipro

IRRADIATOR LOG

START STOP	DATE DATE	START STOP	TIME TIME	BATCH NUMBER	DWELL	RUN CLOCK	REMARKS
8/12/89	8/12/89	0935	1107	1452-1-1	9 min	5309.8	not
8/12/89	8/12/89	1122	1231-11	1293-450	15 min		
8/13/89	8/13/89	1252	1352	1414-10-1	51 sec	5311.2	and
8/13/89	8/13/89	1405	1242	1404-10-1	6 sec	5313.6	not
8/13/89	8/13/89	1502	1502	0822-450	15 min	5312.3	not
8/13/89	8/13/89	1204	1330	0943-450	2 min	5319.7	not
8/13/89	8/13/89	1412	1412	0942-450	6 sec		
8/13/89	8/13/89	1636	2116	1442-450	1 min	5320.0	
8/14/89	8/14/89	0749	1419-10-2	1419-10-2 (SIT)	24 min 6 sec	5320.8 Q	

Source Hover Log

SIT (Safety Interlock Test)
 SOR (Start Of Run)
 EOR (End Of Run)

PS (Place Static)
 TS (Turn Static)
 RS (Remove Static)

	TIME UP	REASON	INITIAL	TIME DOWN	REASON	INITIAL
1/6/89	1405	SOR	<i>Y</i>	1742	EOR	<i>Y</i>
1/6/89	1402	SOR	<i>Y</i>	1744	missin C1B	<i>Y</i>
1/6/89	1407	process	<i>Y</i>			
1/6/89	1122	System test	<i>Y</i>	1107	end of test	<i>Y</i>
1/6/89	1122	Continue Run / SIT	<i>Y</i>	1126	SIT	<i>Y</i>
1/6/89	1128	SIT	<i>Y</i>	1129	TS	<i>Y</i>
1/6/89	1133	continuous run	<i>Y</i>	1145		<i>Y</i>
1/6/89	1146	continuous run	<i>Y</i>	1204	EOR	<i>Y</i>
1/6/89	1330	continuous run	<i>Y</i>	1333	more cameras	<i>Y</i>
1/6/89	1335	continuous run	<i>Y</i>	1338	more cameras	<i>Y</i>
1/6/89	1340	continuous run	<i>Y</i>	1343	more cameras	<i>Y</i>
1/6/89	1345	continuous run	<i>Y</i>	1347	more cameras	<i>Y</i>
1/6/89	1350	continuous run	<i>Y</i>	1352	Noise cameras	<i>Y</i>
1/6/89	1354	continuous run	<i>Y</i>	1357	more cameras	<i>Y</i>
1/6/89	1400	continuous run	<i>Y</i>	1402	more cameras	<i>Y</i>
1/6/89	1404	continuous run	<i>Y</i>			

TEST: ALL STATIC CODES MUST BE FOLLOWED BY STATIC NUMBER
 ALL HALFUNCTIONS MUST INDICATE COMPONENT PROBLEM

Source Move Log

YES: SIT (Safety Interlock Test)
 SOR (Start of Run)
 EOR (End of Run)

PSS (Place Static)
 TS (Turn Static)
 RS (Remove Static)

TIME UP	TIME DOWN	REASON	INITIAL	REASON
5-13-89 1405	1407	Continue Run	1408	Move Conv.
5-13-89 1907	1912	Continuous Run	1908	E.O.R.
5/13/89 1636	1638	Process	1639	TS Turn Static
5/13/89 1692	1694	Process	1695	RS Remove Static
5/13/89 1651	1653	Process	1654	TS Turn Static
5/13/89 1657	1659	Process	1660	RS Remove Static
5/13/89 1704	1706	Process	1707	TS Turn Static
5/13/89 1710	1712	Process	1713	RS Remove Static
5/13/89 1720	1723	Process	1724	TS Turn Static
5/13/89 1727	1729	Process	1730	RS Remove Static
5/13/89 1734	1735	Process	1736	TS Turn Static
5/13/89 1739	1741	Process	1742	RS Remove Static
5/13/89 1857	1859	Process	1860	TS Turn Static
5/13/89 1902	1904	Process	1905	RS Remove Static
5/13/89 1909	1911	Process	1912	TS Turn Static

OTES: ALL STATIC CODES MUST BE FOLLOWED BY STATIC NUMBER
 ALL HALFFUNCTIONS MUST INDICATE COMPONENT PROBLEM

S : SIT (Safety Interlock Test)
 SOR (Start Of Run)
 EOR (End Of Run)

Source Nov. Jet Log

PS (Place Static)
 TS (Turn Static)
 RS (Remove Static)

Time	Time Up	Reason	Initial	Time Down	Reason	Initial
13/84	1944	Process		15/84	TS	
13/87	1926	Process		14/88	TS	
13/89	1931	Process		1933	RS	
13/89	1938	Process		1940	TS	
13/89	1944	Process		1945	RS	
13/89	1952	Process		1953	TS	
13/89	2047	Process		2049	RS	
13/89	2054	Process		2056	TS	
13/89	2100	Process		2101	RS	
13/89	2105	Process		2110	TS	
13/89	2113	Process		2114	RS	
14/89	0749	SOR - SIT		0749	SIT	
14/89	0751	SIT		0752	SIT	
14/89	0757	SIT		0757	SIT	
14/89	0804	Continue Run		0804	Run	

ALL STATIC CODES MUST BE FOLLOWED BY STATIC NUMBER
 ALL HAL FUNCTIONS MUST INDICATE COMPONENT PROBLEM

ES :


8/12/89

2nd

Personnel - David Smith
Rich Stout
Paul Grellicki

Received Shift From Mike Ayres. Cell was running normal until approx. 9:00 PM when a carrier door opened while cycling causing system to malfunction. After clearing jam up I noticed the screen was frozen on page 4, (would not take any entries). John Singleton and John Schlecht was Inter. John Schlecht arrived at 9:40 PM for assistance. Aborted run, but having problems with computer validating entries. Still down at 0030. Shift turned over to Rob Keim.

QUALITY BAKERY PRODUCTS CHICAGO

SIGNATURE			DATE	WITNESS	DATE
DISCLOSED TO AND UNDERSTOOD BY	DATE				8/12/89

8-13-89

1st Shift

BOOK NO.

0700 - 1630

Personnel

John Schlecht
John Singleton

Continued working on system. Replaced microswitches at C1A, C1B, T1A + T1B + L4. Input C143 CIA+ forced to enable completion of run number 0943-450 and static jobs. Performed SIT. Operations turned over to Dave Smith @ 1600. Can perform static dwells only. Frob System troubleshooting will resume in AM 8-14-89

ACETATE, BANDERY PRODUCTS DIVISION

SIGNATURE

J. Singleton
m. benn

DISCLOSED TO AND UNDERSTOOD BY

DATE
8-14-89

WITNESS

DATE
8-14-89

DATE

8/13/89

Personnel - David Smith

Rich Stout

Paul Grellicki

Received Shift from John Singleton
Completed Job # 1042-99-4-15 (STATIC)
Completed Radiological Survey of DI System
Read Farewell Dosimeters, mopped floor,
Stamped Cartus of Glass. Shift Turned
over to Rob Keim.

SCIENTIFIC ANESTHESY PRODUCTS DIVISION

SIGNATURE

David Smith

DATE

8/13/89

DISCLOSED TO AND UNDERSTOOD BY

MDC II

DATE

8-14-89

WITNESS

DATE

8/14/89

66

TITLE

14 AUG 84

3rd

BOOK NO.


6001-

Prepared - Bob Kean
Joe Cimicola
Dennis Louraga

Received shift turnover from Dave Smith & Late entry; Did not write entry for 8/13/84, shift installed as per J. S. shift, due to system overwrites w/ computer.

System still down this shift, no processing to do. Worked on PMS, continued restumping 20 lbs of glass (2 oz). Swept walkways, ash, mold, stained control room, swept truck area. Walkabout door was found unlocked during shift. Completed restumping 2 oz. pallets of glass. Reorganized walkover + 3 bldy C2.

SCIENTIFIC INSTRUMENT PRODUCTS CHICAGO

SIGNATURE 	DATE 8-14-89	WITNESS M. Rose	DATE 8/14/89
DISCLOSED TO AND UNDERSTOOD BY	DATE		DATE

Personnel : MIKE ROSA
JOE GIANCOLA UNTIL 0800
DENNIS LARENGA UNTIL 0800
GILBERT LORENZO
LOUIS CARRERA
JOHN SINGLETON.

Received shift turn over from Bob Klein. Mr. Singleton, Schlect, Rosa working on Cell 7D repa problem see pages 63, 64, 66. Replaced (3) micro switches in Cell. Received start up, SIT complete at 0749 hrs, all safety interlocks functioning as normal, Cell up and processing @ 0749 hrs. Note Jack Masino not in today, illness in family. Material handles re-palletized Lmt #3 of 140 lot HIK as it was palletized wrong. Several malfunctions of TIA. Shift turned over to Bob Klein.

08-12-89 02117 CARRIER MISSING AT CIA+
09-12-89 22119 CYL. CIA TRAVEL TIMED OUT
CVUS000 PRINTER #1 08-12-89 22124
08-12-89 22125 SOURCE DOWN
08-12-89 22126 CYL. CIA TRAVEL TIMED OUT
08-12-89 22126 CONSOLE KEY SWITCH OFF
08-12-89 22142 CONSOLE OVERHEAT ALARM

08-12-89 22143 CYL. CIA TRAVEL TIMED OUT
08-12-89 22143 CARRIER MISSING AT CIA+
08-12-89 22143 CYL. CIA TRAVEL TIMED OUT

CARRIER MISSING

SMOKE DETECTOR ACTIVATED
TEMPERATURE SENSORS ACTIVATED

NOTE DATES 08-89
11-89 + 12-89 RELAY FAILURE
NO DATES IN 11-89 + 12-89

CELL POOL X-HIGH EMERGENCY STOP OFF

LOW AIR PRESSURE

CARRIER LOCKS NOT IN PLACE

CARRIER MISSING AT CIA+

CELL EXHAUST AIR OFF
CELL EXHAUST FAN OFF
CELL POOL WATER X-LOW
CONSOLE EMERGENCY STOP
RADIATION MONITOR FAILURE
ALARM POWER CIRCUIT BREAKER "OFF"
CARRIER HIT COLLISION DEVICE
CELL POOL WATER X-HIGH
HIGH CELL RADIATION/SOURCE DOWN
CELL FULL GAUGE ACTIVATED
CYL. CIA TRAVEL TIMED OUT
CYL. C1B TRAVEL TIMED OUT
CYL. T1A TRAVEL TIMED OUT
CYL. T1B TRAVEL TIMED OUT
SOURCE-UP TRAVEL TIMED OUT
SOURCE-DOWN TRAVEL TIMED OUT

CARRIER MISSING AT C1B+
CYLINDERS NOT IN HOME POSITION
5200 CPU OVER TEMPERATURE
I/O MODULE FAILURE
ZERO DWELL TIME

THE CIRCUIT BREAKER IS A PROTECTIVE DEVICE WHICH IS DESIGNED TO OPEN THE CIRCUIT IN AN ELECTRICAL SYSTEM WHEN THE CURRENT EXCEEDS A PRE-SELECTED AMOUNT. IT IS USED IN POWER SYSTEMS TO PROTECT EQUIPMENT FROM OVERCURRENT. THE CIRCUIT BREAKER IS A RELIABLE AND DURABLE DEVICE WHICH CAN BE USED FOR FREQUENTLY OPERATED CIRCUITS. IT IS ALSO USED AS A CONTROL DEVICE FOR MOTOR STARTERS AND OTHER INDUSTRIAL EQUIPMENTS. THE CIRCUIT BREAKER IS A VERSATILE DEVICE WHICH CAN BE USED IN VARIOUS WAYS DEPENDING UPON THE REQUIREMENTS OF THE SYSTEM.

INDUCTIVE PROBE ACTIVATED
 INDUCTIVE PROBE SENSOR ACTIVATED
 INDUCTIVE PLUG LIMIT-SWITCH OPEN
 CELL, INDUCTIVE SENSORS OPEN
 CELL, INDUCTIVE SENSORS OPEN
 CONNECTOR PLATE WATER X-LOW
 RADIATION MONITOR HIGH
 ALARM BELL CIRCUIT HIGH
 DARKING BELL CIRCUIT HIGH
 CELL, INDUCTIVE SENSORS OPEN
 CELL, INDUCTIVE SENSORS OPEN
 CELL, INDUCTIVE SENSORS OPEN
 CYL. TRAVEL TIMED OUT
 CYL. TRAVEL TIMED OUT
 CYL. TRAVEL TIMED OUT
 CYL. TRAVEL TIMED OUT
 SOURCE-UP TRAVEL TIMED OUT
 SOURCE-DOWN TRAVEL TIMED OUT

1961-1962 - 1962-1963 - 1963-1964 - 1964-1965 - 1965-1966 - 1966-1967 - 1967-1968 - 1968-1969 - 1969-1970 - 1970-1971

100 200 300 400 500 600 700 800 900 1000

三、在本行的右端，列有各項的英譯，以便於對照。

INPUT PRODUCT RUN TIME, PRECISI
ON MINUTES:00 SECONDS:11.50

```
0124  KEY2  DATA, 21H,0  INDEX=0  C  12  
0125  KEY2  DATA, 21H,0  INDEX+1  C  12  
0126  KEY2  DATA, 21H,0  INDEX+2  C  12  
0127  KEY2  DATA, 21H,0  INDEX+3  C  12
```

PRODUCT RUN VALID INDEX=0
08108-09 08104 CYL. TIE TRAVEL TIMED OUT
08108-09 08111 CYL. TIE TRAVEL TIMED OUT
08108-09 08116 RUN ABORDED

NORTH JEFFERY PROCESS TECHNOLOGY
108 LAKE DENMARK ROAD
ROCKAWAY, N.J. 07866

从1990年到1995年，中国GDP增长了1.5倍，而同期美国GDP仅增长了0.5倍。

08-18-89 14:03 STATIC-A , TURN/ROTATE
08-18-89 14:03 SOURCE DOWN
08-18-89 14:03 CONSOLE KEY-SWITCH OFF
08-18-89 14:04 START-UP IN PROGRESS
08-18-89 14:05 SOURCE UP

08-13-09 14107 STATIC-A TURN/ROTATE
 08-13-09 14107 SOURCE DOWN
 08-13-09 14107 CONSOLE KEY-SWITCH ON
 08-13-09 14108 STATIC-A 22 00000000000000000000000000000000
 08-13-09 14109 STATIC-A 22 00000000000000000000000000000000

