



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

November 12, 1982

JAMES P. McGAUGHY, JR.
ASSISTANT VICE PRESIDENT

Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 3100
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File 0260/L-835.0
Fire Detector Alarms ~~Due~~ to
Dust Accumulation
Reference: LER 82-104/03 L-0
AECM-82/546

NOV 15 1982
REGION II
ATLANTA, GEORGIA

On October 14, 1982, with no fire or smoke present, smoke detection zone 1-11 and 2-01 alarmed and would not reset. The zones were deactivated on the Fire/Security Computer and a fire watch established in accordance with T.S.3.3.7.9. This is being reported pursuant to T.S.6.9.1.13.b. Attached is LER 82-104/03 L-0.

Yours truly,

J.P. McGaughey, Jr.
FOR J.P. McGaughey, JR.

JPM:sap
Attachment

- cc: Mr. N. L. Stampley (w/a)
Mr. R. B. McGehee (w/o)
Mr. T. B. Conner (w/o)
Mr. G. B. Taylor (w/o)

Mr. Richard C. DeYoung, Director (w/a)
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Document Control Desk (w/a)
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

8211170317 821112
PDR ADOCK 05000416
S PDR

OFFICIAL COPY
IE 22