NRC FORM 366 (7-77)

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK: | | | | | | | (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

Line	Field	Value
0 1	LICENSEE CODE (2)	G A E I H 2
	LICENSE NUMBER (3)	0 0 - 0 0 0 0 0 - 0 0
	LICENSE TYPE (4)	4 1 1 1 1
	CAT (5)	
0 1 (CON'T)	REPORT SOURCE (6)	L
	DOCKET NUMBER (7)	0 5 0 0 0 3 6 6
	EVENT DATE (8)	1 0 0 9 8 2
	REPORT DATE (9)	1 1 0 4 8 2

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 On October 9, 1982, with Unit 2 in run at 1375 MWt, the "RHR SERVICE
0 3 WATER PUMP OPERABILITY" procedure was being performed on the "A" RHRSW
0 4 pump as per Tech. Specs. 4.7.1.1.b. It was noted that the "C" discharge
0 5 check valve was sticking open. The "C" pump was declared inoperable and
0 6 a 30-day LCO was initiated as per Tech. Specs. 3.7.1.1, Action a.1. The
0 7 health and safety of the public were not affected by this non-repetitive
0 8 event.

Line	Field	Value
0 9	SYSTEM CODE (11)	W A
	CAUSE CODE (12)	E
	CAUSE SUBCODE (13)	B
	COMPONENT CODE (14)	V A L V E X
	COMP. SUBCODE (15)	C
	VALVE SUBCODE (16)	A
(17) LER/RO REPORT NUMBER	EVENT YEAR	8 2
		—
	SEQUENTIAL REPORT NO.	1 1 3
		/
	OCCURRENCE CODE	0 3
	REPORT TYPE	L
		—
	REVISION NO.	0
	ACTION TAKEN (18)	B
	FUTURE ACTION (19)	Z
	EFFECT ON PLANT (20)	Z
	SHUTDOWN METHOD (21)	Z
	HOURS (22)	0 0 0 0
	ATTACHMENT SUBMITTED (23)	N
	NPRD-4 FORM SUB. (24)	N
	PRIME COMP. SUPPLIER (25)	A
	COMPONENT MANUFACTURER (26)	W 0 3 0

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 The cause of the "C" discharge check valve sticking open was due to a
1 1 corroded flapper shaft. The check valve was rebuilt and successfully
1 2 tested during performance of the "RHR SERVICE WATER PUMP OPERABILITY"
1 3 test performed on the "C" pump. The pump was then returned to service on
1 4 October 12, 1982.

Line	Field	Value
1 5	FACILITY STATUS (28)	E
	% POWER (29)	0 5 6
	OTHER STATUS (30)	NA
	METHOD OF DISCOVERY (31)	B
	DISCOVERY DESCRIPTION (32)	Inservice Inspection/Surveillance
1 6	ACTIVITY RELEASED (33)	Z
	CONTENT OF RELEASE (34)	Z
	AMOUNT OF ACTIVITY (35)	NA
	LOCATION OF RELEASE (36)	NA
1 7	PERSONNEL EXPOSURES NUMBER (37)	0 0 0
	TYPE (38)	Z
	DESCRIPTION (39)	NA
1 8	PERSONNEL INJURIES NUMBER (40)	0 0 0
	DESCRIPTION (41)	NA
1 9	LOSS OF OR DAMAGE TO FACILITY TYPE (42)	Z
	DESCRIPTION (43)	NA
2 0	PUBLICITY ISSUED (44)	N
	DESCRIPTION (45)	NA
	NRC USE ONLY	

8211170334 821104
PDR ADOCK 05000366
S PDR

NAME OF PREPARER S. B. Tipps PHONE: (912) 367-7851

GPO 917-926