NRC FORM 366 (12-81)	LICENSEE EVENT REPORT	APPROVED BY OMB 3150-0011 EXPIRES 4-30-82
CONTROL BLOCK: (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)		
0 1 S C V C S 1 2 0 0	-   0   0   0   0   -   0   0   3   4   1   1   1   1   1   1   1   1   1	0 0 0 4 57 GAT 58
CON'T    0   1   REPORT     6   0   5   0   0   0   3   9   5   7   1   0   1   1   8   2   8   1   1   1   0   8   2   9		
EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (1)  O 2   While performing surveillance testing on Steam Line Safety Valves, it was		
discovered that Valve 2806P was stuck closed. In the process of trying to free		
o 4 the valve, it fully opened. Steam Line pressure dropped to 940 psig at which		
o   time the valve reseated. There were no probable adverse consequences as the		
O 6 Plant was in Mode 3 and had not achieved initial criticality.		
0 7		
08		**
SYSTEM CAUSE CAUSE COMPONENT CODE SUBCODE SUBCODE		
C C (1) E (12)	B (13) V A L V E X (14) X  12 13 OCCURRENCE REPO	(15) B (16)
TO LER/RO EVENT YEAR REPORT NO.  17 REPORT NUMBER 2		
ACTION FUTURE EFFECT SHUTDOWN HOURS 22 ATTACHMENT NPRO-4 PRIME COMP. COMPONENT (26)    E   18   Z   19   Z   20   Z   21   0   0   0   0   Y   23   N   24   A   25   D   2   4   5     33   34   35   36   37   40   41   42   43   43   44   47		
CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)  The cause of the event was that Safety Valve 2608P inadvertantly lifted after		
being freed from a stuck closed position. Corrective action was to reset the		
Power Range Neutron Flux High Setpoint to 87%, and to reset and retest the		
safety valve.		
1 4		
7 FACILITY STATUS SPOWER OTHER 1 5 B 28 0 0 0 29 N/A	STATUS 30 METHOD OF DISCOVERY DISCOVERY Z 31 Surveillance T	esting
7 6 9 10 12 13 ACTIVITY CONTENT RELEASED OF RELEASE AMOUNT OF ACT  1 6   Z   33   Z   34   N/A	1VITY (35) LOCATION	OF RELEASE 36
7 8 9 10 11  PERSONNEL EXPOSURES  NUMBER TYPE DESCRIPTION	44 45	80
1 7 0 0 0 37 Z 38 N/A		80
NUMBER DESCRIPTION (41)  1 8 0 0 0 40 N/A	200 001110	80
LOSS OF OR DAMAGE TO FACILITY 43  TYPE DESCRIPTION N//	8211170429 821110 PDR ADDCK 05000395 PDR	
7 8 9 10 PUBLICITY ISSUED DESCRIPTION 45		NRC USE ONLY
2 0 N 44 N/A	DV1	68 69 80
NAME OF PREPARER A.	R. Koon, Jr	(803) 345-5209