



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

VIRGINIA ELECTRIC AND POWER COMPANY

DOCKET NO. 50-338

NORTH ANNA POWER STATION, UNIT NO. 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 44
License No. NPF-4

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Virginia Electric and Power Company (the licensee) dated November 8, 1982 complies with the standards and requirements of the Atomic Energy of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.


2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.D(2) of Facility Operating License No. NPF-4 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 44, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Robert A. Clark, Chief
Operating Reactors Branch #3
Division of Licensing

Attachment:
Changes to the Technical
Specifications

Date of Issuance: November 9, 1982

ATTACHMENT TO LICENSE AMENDMENT

AMENDMENT NO. 44 TO FACILITY OPERATING LICENSE NO. NPF-4

DOCKET NO. 50-338

Replace the following page of the Appendix "A" Technical Specifications with the enclosed page as indicated. The revised page is identified by Amendment number and contains vertical lines indicating the area of change. The corresponding overleaf page is also provided to maintain document completeness.

Page

3/4 6-20

TABLE 3.6-1 (Cont.)

<u>VALVE NUMBER</u>	<u>FUNCTION</u>	<u>ISOLATION TIME (SEC.)</u>
35. TV-LM100A	Reactor Containment Leakage Monitoring Lines to Open Pressure Taps	60
36. TV-LM100B	Reactor Containment Leakage Monitoring Lines to Open Pressure Taps	60
37. TV-LM100C	Reactor Containment Leakage Monitoring Lines to Open Pressure Taps	60
38. TV-LM100D	Reactor Containment Leakage Monitoring Lines to Open Pressure Taps	60
39. TV-LM100E	Reactor Containment Leakage Monitoring Lines to Open Pressure Taps	60
40. TV-LM100F	Reactor Containment Leakage Monitoring Lines to Open Pressure Taps	60
41. TV-LM100G	Reactor Containment Leakage Monitoring Lines to Open Pressure Taps	60
42. TV-LM100H	Reactor Containment Leakage Monitoring Lines to Open Pressure Taps	60
43. TV-SS101A	Pressurizer Vapor Space Sample	60
44. TV-SS101B	Pressurizer Vapor Space Sample	60
45. TV-SV102-1	Condenser Air Ejector Vent	60
46. TV-SV103	Condenser Air Ejector Vent	60
47. TV-CV150A	Containment Vacuum Pump Suction	60
48. TV-CV150B	Containment Vacuum Pump Suction	60
49. TV-CV150C	Containment Vacuum Pump Suction	60

NORTH ANNA - UNIT 1

3/4 6-19

Amendment No. 43

TABLE 3.6-1 (Cont.)

<u>VALVE NUMBER</u>	<u>FUNCTION</u>	<u>ISOLATION TIME (SEC.)</u>
50. TV-CV150D	Containment Vacuum Pump Suction	60
51. TV-SS103A	Residual Heat Removal System Sample Lines	60
52. TV-SS103B	Residual Heat Removal System Sample Lines	60
53. TV-LM101A	Reactor Containment Leakage Monitoring Lines to Reference System	60
54. TV-LM101B	Reactor Containment Leakage Monitoring Lines to Reference System	60
55. TV-LM101C	Reactor Containment Leakage Monitoring Lines to Reference System	60
56. TV-LM101D	Reactor Containment Leakage Monitoring Lines to Reference System	60
57. TV-1859	Safety Injection Test Line	60
58. TV-1842	Safety Injection Test Line	60
59. TV-SS112A	Steam Generator Surface Sample	60
60. TV-SS112B	Steam Generator Surface Sample	60
61. TV-MS109#	Main Steam Drains to Condenser	60
62. TV-MS110#	Main Steam to Blowdown	60
63. TV-SV102-2#	Condenser Air Ejector Vent	60
64. FCV-AS100A#	Condenser Air Ejector Steam Supply	60
65. FCV-AS100B#	Condenser Air Ejector Steam Supply	60
66. TV-DA103A	Post Accident Sample System Containment Return Line	60
67. TV-DA103B	Post Accident Sample System Containment Return Line	60

NORTH ANNA - UNIT 1

3/4 6-20

Amendment No. 48, 44