

Attachment 1

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50-219
 UNIT NAME Cyster Creek
 DATE February, 1990
 COMPLETED BY R. Baran
 TELEPHONE 971-4640

REPORT MONTH January, 1990

NO.	DATE	TYPE		DURATION (Hours)	REASON (1)	METHOD OF SHUTTING DOWN THE REACTOR OR REDUCING POWER (2)	CORRECTIVE ACTIONS/COMMENTS
		F: Forced	S: Scheduled				
91	900123	F		0	A	4	A load reduction to 412 MWe was required to remove the "C" Feedwater string from service to facilitate repairs to a leak on a drain nipple on "C" Rx Feedwater Pump. Average load during the repair time period was 443 MWe.

Summary :

(1) REASON

- a. Equipment Failure (Explain)
- b. Maintenance or Test
- c. Refueling
- d. Regulatory Restriction

- e. Operator Training & License Exam
- f. Administrative
- g. Operational Error (Explain)
- h. Other (Explain)

(2) METHOD

- 1. Manual
- 2. Manual Scram
- 3. Automatic Scram
- 4. Other (Explain)

9101230277 910115
 PDR ADDCK 05000219
 PDR