

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50-219
 UNIT NAME Oyster Creek
 DATE April, 1990
 COMPLETED BY R. Baran
 TELEPHONE 971-4640

REPORT MONTH March, 1990

NO.	DATE	TYPE F: Forced S: Scheduled	DURATION (Hours)	REASON (1)	METHOD OF SHUTTING DOWN THE REACTOR OR REDUCING POWER (2)	CORRECTIVE ACTIONS/COMMENTS
94	900309	F	0	A	4	Load reduction to 57% Rx power (315 MWe) due to vacuum problems.
95	900326	S	120.4	B	1	12-U-J Maintenance Outage

9101230280 910115
 PDR ADCK 05000219
 PDR

Summary :

(1) REASON

- a. Equipment Failure (Explain)
- b. Maintenance or Test
- c. Refueling
- d. Regulatory Restriction

- e. Operator Training & License Exam
- f. Administrative
- g. Operational Error (Explain)
- h. Other (Explain)

(2) METHOD

- 1. Manual
- 2. Manual Scram
- 3. Automatic Scram
- 4. Other (Explain)