

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50-219
 UNIT NAME Oyster Creek
 DATE May, 1990
 COMPLETED BY R. Baran
 TELEPHONE 971-4640

REPORT MONTH April, 1990

| NO. | DATE | TYPE | | DURATION (Hours) | REASON (1) | METHOD OF SHUTTING DOWN THE REACTOR OR REDUCING POWER (2) | CORRECTIVE ACTIONS/COMMENTS |
|-----|--------|-----------|--------------|---------------------|------------|---|---|
| | | F: Forced | S: Scheduled | | | | |
| 95 | 900326 | | S | 219.8 | B | 1 | 12-U-J Maintenance Outage |
| 96 | 900421 | F | | 243.8 | A | 2 | Loss of unit sub-station 1B2 (Outage 12-U-K). Commenced a normal shutdown until the generator was removed from service. A manual scram was then inserted to expedite the shutdown. |

Summary :

(1) REASON

- a. Equipment Failure (Explain)
- b. Maintenance or Test
- c. Refueling
- d. Regulatory Restriction

- e. Operator Training & License Exam
- f. Administrative
- g. Operational Error (Explain)
- h. Other (Explain)

(2) METHOD

- 1. Manual
- 2. Manual Scram
- 3. Automatic Scram
- 4. Other (Explain)

9101230282 910115
 PDR ADDCK 05000219
 PDR