

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50-219  
 UNIT NAME Oyster Creek  
 DATE June, 1990  
 COMPLETED BY R. Baran  
 TELEPHONE 971-4640

REPORT MONTH May, 1990

NO.	DATE	TYPE		DURATION (Hours)	REASON (1)	METHOD OF SHUTTING DOWN THE REACTOR OR REDUCING POWER (2)	CORRECTIVE ACTIONS/COMMENTS
		F: Forced	S: Scheduled				
96	900421	F		342.8	A	2	Loss of Unit substation 1B2 (Outage 12-U-K). Commenced a normal shutdown until the generator was removed from service. A manual scram was then inserted to expedite the shutdown.
97	900527	F		0	A	4	Load reduction due to a tube leak in "C" south main condenser. Leaking tubes in the condenser half were successfully plugged.

Summary :

(1) REASON

- a. Equipment Failure (Explain)
- b. Maintenance or Test
- c. Refueling
- d. Regulatory Restriction

- e. Operator Training & License Exam
- f. Administrative
- g. Operational Error (Explain)
- h. Other (Explain)

(2) METHOD

- 1. Manual
- 2. Manual Scram
- 3. Automatic Scram
- 4. Other (Explain)

9101230283 910115  
 PDR ADDOCK 05000219  
 PDR