



UNITED STATES
ATOMIC ENERGY COMMISSION
WASHINGTON 25, D.C.

IN REPLY REFER TO:

LA:JJL
70-115 and 70-350

Spencer Chemical Company
Research Center
9009 West 67th Street
Kerrison, Kansas

We
do a survey
prior to the
termination
of license
DEC 18 1962

Attention: Mr. E. A. Greenlee

Enclosures:

This refers to your letter of November 20, 1962, informing us of your action to terminate license 70-15h.

At least fifteen days prior to vacating this facility, or using it for any purpose other than authorized under your license you are requested to submit to us a report indicating the levels of fixed and removable uranium contamination existing in the facilities. We believe the following levels should not be exceeded:

1. For alpha radioactivity
 - a. 25,000 d/ μ r/100cm 2 peak
 - b. 5,000 d/ μ r/100cm 2 average
 - c. 1,000 d/ μ r/100cm 2 maximum removable by wiping the area with a dry filter or soft absorbent paper.
2. Beta and gamma
 - a. 1.0 millirad per hour maximum at one centimeter from any contaminated surface measured with a beta-gamma survey meter through a tissue equivalent absorber of not more than 7 mg/cm 2 .
 - b. 0.2 millirad per hour average, measured as above.
 - c. 1,000 d/ μ r/100cm 2 maximum removable by wiping the area with a dry filter paper or soft-absorbent paper.

Consideration will be given to cancellation of license 70-15h on receipt of your report of contamination levels. Please note that pipes, columns, ducts or other areas difficult to survey for built-up contamination must be treated as containing special nuclear material and should be disposed of prior to termination of the special nuclear material license.

1 PWD/AM 11-1

J - Hdqrs.

Spencer Chemical Company

- 2 -

DEC 18 1962

In connection with the expiration of License SMI-329 you are requested to submit at least fifteen days prior to vacating the facility under License SMI-329 or using it for any purpose other than previously authorized under your license a report indicating the levels of fixed and removable uranium contamination existing in the facility. We believe that the levels outlined in items 1 and 2 above should not be exceeded and similar consideration, as previously mentioned, should be given to those areas of equipment which are difficult to survey for built-up contamination.

FOR THE ATOMIC ENERGY COMMISSION

Donald A. Kuehne, Chief
Source and Special Nuclear Materials Branch
Division of Licensing and Regulation

Distribution:

Compliance Hdqrs (2) w/2c ltr dtd 11/20/62

124AIC