

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50-219  
 UNIT NAME Oyster Creek  
 DATE October, 1990  
 COMPLETED BY R. Baran  
 TELEPHONE 971-4640

REPORT MONTH September, 1990

NO.	DATE	TYPE F: Forced S: Scheduled	DURATION (Hours)	REASON (1)	METHOD OF SHUTTING DOWN THE REACTOR OR REDUCING POWER (2)	CORRECTIVE ACTIONS/COMMENTS
100	900921	S	0	B	4	Load reduction to 280 MW to isolate and clean "C" North Main Condenser.

9101230286 910115  
 PDR ADDCK 05000219  
 PDR

Summary :

(1) REASON

- a. Equipment Failure (Explain)
- b. Maintenance or Test
- c. Refueling
- d. Regulatory Restriction

- e. Operator Training & License Exam
- f. Administrative
- g. Operational Error (Explain)
- h. Other (Explain)

METHOD

- 1. Manual
- 2. Manual Scram
- 3. Automatic Scram
- 4. Other (Explain)