

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50-219
 UNIT NAME Oyster Creek
 DATE December, 1990
 COMPLETED BY R. Baran
 TELEPHONE 971-4640

REPORT MONTH November, 1990

NO.	DATE	TYPE		DURATION (Hours)	REASON (1)	METHOD OF SHUTTING DOWN THE REACTOR OR REDUCING POWER (2)	CORRECTIVE ACTIONS/COMMENTS
		F: Forced	S: Scheduled				
101	901103	F		0	A	4	Reduce plant load to 380 MWe to remove "A" Feedwater String from service due to pin hole leak on "A" Feedwater Minimum Flow Valve.
102	901113	S		0	A	4	Reduced plant load to 295 MWe due to ALARA concerns during the NDE inspection of feedwater minimum flow lines in the condenser bay.

Summary :

(1) REASON

- a. Equipment Failure (Explain)
- b. Maintenance or Test
- c. Refueling
- d. Regulatory Restriction

- e. Operator Training & License Exam
- f. Administrative
- g. Operational Error (Explain)
- h. Other (Explain)

(2) METHOD

- 1. Manual
- 2. Manual Scram
- 3. Automatic Scram
- 4. Other (Explain)

9101230290 910115
 PDR ADOCK 05000219
 PER