

ATTACHMENT
CORE OPERATING LIMITS REPORT
FOR
QUAD CITIES UNIT 1 CYCLE 12

9101230298 910121
PDR ADOCK 05000254
P PDR

Core Operating Limits Report
for
Quad Cities Nuclear Power Station
Unit 1, Reload 11 (Cycle 12)

TABLE OF CONTENTS

	<u>Page</u>
REFERENCES	iii
LIST OF FIGURES	iv
1.0 CONTROL ROD WITHDRAWAL BLOCK INSTRUMENTATION (3.2/4.2) ...	1-1
1.1 Technical Specification Reference	1-1
1.2 Description	1-1
2.0 AVERAGE PLANAR LINEAR HEAT GENERATION RATE (3.5/4.5)	2-1
2.1 Technical Specification Reference	2-1
2.2 Description	2-1
3.0 LINEAR HEAT GENERATION RATE (3.5/4.5)	3-1
3.1 Technical Specification Reference	3-1
3.2 Description	3-1
4.0 MINIMUM CRITICAL POWER RATIO (3.5/4.5)	4-1
4.1 Technical Specification Reference	4-1
4.2 Description	4-1

REFERENCES

1. Commonwealth Edison Company and Iowa-Illinois Gas and Electric Company Docket No. 50-254, Quad Cities Station, Unit 1 Facility Operating License, License No. DRP-29.
2. Letter from D. M. Crutchfield to All Power Reactor Licenses and Applicants, Generic Letter 88-16; Concerning the Removal of Cycle-Specific Parameter Limits from Technical Specifications.
3. Supplemental Reload License Submittal for Quad Cities Nuclear Power Station, Unit 1, Reload 11 (Cycle 12), 23A5989, Rev. 0, Class I, August 1990.
4. Quad Cities Nuclear Power Station, Units 1 and 2, SAFER/GESTR-LOCA Loss-of-Coolant-Accident Analysis, NEDC-31345P, June 1987 (as amended).
5. General Electric Standard Application for Reactor Fuel (GESTAR), NEDE-24011-P-A-9, September 1988 (as amended).
6. Extended Operating Domain and Equipment Out-Of-Service (EOD/EOOS) for Quad Cities Nuclear Power Station, Units 1 and 2, H. X. Hoang, NEDC-31449, Class II, July 1987.

LIST OF FIGURES

<u>FIGURE</u>	<u>TITLE/DESCRIPTION</u>	<u>PAGE</u>
2-1	Maximum Average Planar Linear Heat Generation Rate (MAPLHGR) vs. Average Planar Exposure for Fuel Types P8DRB265H and BP8DRB265H.	2-2
2-2	Maximum Average Planar Linear Heat Generation Rate (MAPLHGR) vs. Average Planar Exposure for Fuel Type BP8DRB282.	2-3
2-3	Maximum Average Planar Linear Heat Generation Rate (MAPLHGR) vs. Average Planar Exposure for Fuel Type BP8DRB283H.	2-4
2-4	Maximum Average Planar Linear Heat Generation Rate (MAPLHGR) vs. Average Planar Exposure for Fuel Type BP8DRB299.	2-5
2-5	Maximum Average Planar Linear Heat Generation Rate (MAPLHGR) vs. Average Planar Exposure for Fuel Type BD300A.	2-6
2-6	Maximum Average Planar Linear Heat Generation Rate (MAPLHGR) vs. Average Planar Exposure for Fuel Type BD300B.	2-7
2-7	Maximum Average Planar Linear Heat Generation Rate (MAPLHGR) vs. Average Planar Exposure for Fuel Type BD301H.	2-8
2-8	Maximum Average Planar Linear Heat Generation Rate (MAPLHGR) vs. Average Planar Exposure for Fuel Type Barrier LTA.	2-9
2-9	Maximum Average Planar Linear Heat Generation Rate (MAPLHGR) vs. Average Planar Exposure for Fuel Type GE9B-P8DWB258-9GZ-80M-145-T.	2-10
2-10	Maximum Average Planar Linear Heat Generation Rate (MAPLHGR) vs. Average Planar Exposure for Fuel Type GE9B-P8DWB258-4G4.0/3C3.0-80M-145-T.	2-11
4-1	Kf Factor vs. Core Flow %.	4-2

1.0 CONTROL ROD WITHDRAWAL BLOCK INSTRUMENTATION (3.2/4.2)

1.1 TECHNICAL SPECIFICATION REFERENCE:

Technical Specification Table 3.2-3 and 3.6.H

1.2 DESCRIPTION:

The Rod Withdrawal Block Monitor Upscale Instrumentation Trip Setpoint for two recirculation loop operation is determined from the following relationship:

$$\leq (0.65)Wd + 43\%^{**}$$

** Clamped, with an allowable value not to exceed the allowable value for recirculation loop flow (Wd) of 100%.

Wd is the percent of drive flow required to produce a rated core flow of 98 million lb/hr. Trip level setting is in percent of rated power (2511 MWth).

Core Operating Limits Report

2.0 AVERAGE PLANAR LINEAR HEAT GENERATION RATE (APLHGR) (3.5/4.5)

2.1 TECHNICAL SPECIFICATION REFERENCE:

Technical Specification 3.5.I

2.2 DESCRIPTION:

The Maximum Average Planar Linear Heat Generation Rates (MAPLHGR) versus Average Planar Exposure for fuel types P8DRB265H and BP8DRB265H are determined from Figure 2-1.

The Maximum Average Planar Linear Heat Generation Rates (MAPLHGR) versus Average Planar Exposure for fuel type BP8DRB282 is determined from Figure 2-2.

The Maximum Average Planar Linear Heat Generation Rates (MAPLHGR) versus Average Planar Exposure for fuel type BP8DRB283H is determined from Figure 2-3.

The Maximum Average Planar Linear Heat Generation Rates (MAPLHGR) versus Average Planar Exposure for fuel type BP8DRB299 is determined from Figure 2-4.

The Maximum Average Planar Linear Heat Generation Rates (MAPLHGR) versus Average Planar Exposure for fuel type BD300A is determined from Figure 2-5.

The Maximum Average Planar Linear Heat Generation Rates (MAPLHGR) versus Average Planar Exposure for fuel type BD300B is determined from Figure 2-6.

The Maximum Average Planar Linear Heat Generation Rates (MAPLHGR) versus Average Planar Exposure for fuel type BD301H is determined from Figure 2-7.

The Maximum Average Planar Linear Heat Generation Rates (MAPLHGR) versus Average Planar Exposure for fuel type Barrier LTA is determined from Figure 2-8.

The Maximum Average Planar Linear Heat Generation Rates (MAPLHGR) versus Average Planar Exposure for fuel type GE9B-P8DWB258-9GZ-80M-145-T is determined from Figure 2-9.

The Maximum Average Planar Linear Heat Generation Rates (MAPLHGR) versus Average Planar Exposure for fuel type GE9B-P8DWB258-4G4.0/3G3.0-80M-145-T is determined from Figure 2-10.

**Maximum Average Planar Linear Heat Generation Rate (MAPLHGR)
vs Average Planar Exposure for Fuel Types P8DRB265H and BP8DRB265H**




Figure 2-1

Maximum Average Planar Linear Heat Generation Rate (MAPLHGR) vs Average Planar Exposure for Fuel Type BP8DRB282




Figure 2-2

Maximum Average Planar Linear Heat Generation Rate (MAPLHGR) vs Average Planar Exposure for Fuel Type BP8DRB283II




Figure 2-3

Maximum Average Planar Linear Heat Generation Rate (MAPLHGR) vs Average Planar Exposure for Fuel Type BP8DRB299





Figure 2-4

Maximum Average Planar Linear Heat Generation Rate (MAPLIHGR) vs Average Planar Exposure for Fuel Type BD300A

Quad Cities - Unit 1

Core Operating Limits Report

p. 2-6



Cycle 12

Figure 2-5

Maximum Average Planar Linear Heat Generation Rate (MAPLHGR) vs Average Planar Exposure for Fuel Type BD300B




Figure 2-6

Maximum Average Planar Linear Heat Generation Rate (MAPLHGR) vs Average Planar Exposure for Fuel Type BD301H




Figure 2-7

Maximum Average Planar Linear Heat Generation Rate (MAPLHGR) vs Average Planar Exposure for Fuel Type Barrier LTA




Figure 2-8

**Maximum Average Planar Linear Heat Generation Rate (MAPLHGR)
vs Average Planar Exposure for Fuel Type
GE9B-P8DWB258-9GZ-80M-145-T**




Figure 2-9

Maximum Average Planar Linear Heat Generation Rate (MAPLHGR) vs Average Planar Exposure for Fuel Type GE9B-P8DWB258-4G4.0/3G3.0-80 M-145-T



Figure 2-10

Core Operating Limits Report

3.0 LINEAR HEAT GENERATION RATE (LHGR) (3.5/4.5)

3.1 TECHNICAL SPECIFICATION REFERENCE:

Technical Specification 3.5.J

3.2 DESCRIPTION:

a. The LHGR limit is 13.4 kw/ft for fuel types:

1. EP8DRE265H
2. EP8DRE283H
3. EP8DRE282
4. EP8DRE299
5. Barrier LTA

b. The LHGR limit is 14.4 kw/ft for fuel types:

1. BD300A
2. BD300B
3. BD301H
4. GE9B-P8DWE258-3GZ-80M-145-T
5. GE9B-P8DWE258-4G4.0/3G3.0-80M-145-T

Core Operating Limits Report

4.0 MINIMUM CRITICAL POWER RATIO (MCPR) (3.5/4.5)

4.1 TECHNICAL SPECIFICATION REFERENCE:

Technical Specification 3.5.K and 3.6.H

4.2 DESCRIPTION:

During steady-state operation at rated core flow, the MCPR limit (OLMCPR) shall be greater than or equal:

1.30 for $t_{ave} \leq 0.68$ sec.

1.35 for $t_{ave} \geq 0.86$ sec.

$(0.278)t_{ave} + 1.111$ for 0.68 sec. $< t_{ave} < 0.86$ sec.

where t_{ave} = mean 20% scram insertion time for all surveillance data from Tech. Spec. 4.3.C which has been generated in the current cycle.

For core flows other than rated, these nominal values of MCPR shall be increased by a factor of K_f where K_f is as shown in Figure 4-1.

When operating with a Feedwater Heater Out-of-Service (FWHOOS), the Operating Limit MCPR (OLMCPR), calculated using the above information, shall be increased by 0.02. This event, which conservatively bounds the requirements detailed within the EOD/EOOS document (Reference 6), goes beyond all operating conditions which can be expected during normal operation as set forth in the SRLS (Reference 3).

K_f FACTOR

Core Operating Limits Report

Quad Cities - Unit 1

p. 4-2




Figure 4-1

Cycle 12