## Southern California Edison Company

SAN ONOFRE NUCLEAR GENERATING STATION P.O. BCY 128 SAN CLEMENTE, C/LIFORNIA 92672

H. B. RAY STATION MANAGER

November 10, 1982

TELEPHONE

(714) 492-7700

IE-22 82-397

U. S. Nuclear Regulatory Commission Office of Inspection and Enforcement Region V 1450 Maria Lane, Suite 210 Walnut Creek, California 94596-5368

Attention: Mr. R. H. Engelken, Regional Administrator

Dear Sir:

Subject: Docket No. 50-361 Prompt Report Licensee Event Report No. 82-138 San Onofre Nuclear Generating Station, Unit 2

Pursuant to Appendix A Technical Specification 6.9.1.12g to Operating License NPF-10 for San Onofre Unit 2, this submittal provides the required written confirmation of our prompt notification to the NRC on November 9, 1982 of a reportable occurrence involving a manual trip of the reactor and initiation of the Emergency Core Cooling System (ECCS).

Section 6.9.1.12g requires that conditions arising from natural or manmade events that, as a direct result of the event require unit shutdown, operation of safety systems, or other protective measures required by Technical Specifications, shall be reported within 24 hours with a written follow-up report within 14 days.

On November 9, 1982 while in Mode 1, momentary loss of power to the Feedwater Control System was experienced. As a precaution, the reactor was manually tripped and the ECCS was automatically initiated during the resulting cooldown.

A 14-day followup report with a copy of Licensee Event Report (LER) 82-138 will be submitted before November 23, 1982. A special Report per Limiting Condition for Operation (LCO) 3.5.2 will be submitted before February 8, 1983.

If there are any questions, please contact me.

Sincerely,

HBRay / Nimorty

8211190108 821110 PDR ADOCK 05000361 S PDR

cc: A. E. Chaffee (USNRC Resident Inspector, San Onofre Unit 2)