

LICENSEE EVENT REPORT

CONTROL BLOCK: _____ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 I L Z I S 1 2 0 0 - 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5
7 8 9 LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 31 CAT 58 32

CON'T
0 1 REPORT SOURCE L 6 0 5 0 0 0 2 9 7 1 1 0 1 9 8 2 3 1 1 1 2 8 2 9
7 8 9 DOCKET NUMBER 18 19 EVENT DATE 24 25 REPORT DATE 30 31

0 2 During normal power operation with Unit One at 49% power, steam gener-
0 3 ator 1A steam flow channel 1F-512 failed low with respect to redundant
0 4 steam flow channel 1F-513. This deviation is non-conservative for
0 5 steam/feed flow mismatch and Hi-steam flow Reactor trip interlocks.
0 6 The redundant steam flow channel was operable. The health and safety
0 7 of the public were not affected. Previous LER's: 50-304/82-23, 18.
0 8 _____

0 9 SYSTEM CODE I A 11 CAUSE CODE E 12 CAUSE SUBCODE E 13 COMPONENT CODE I N S T R U 14 COMP SUBCODE T 15 VALVE SUBCODE Z 16
7 8 9 10 11 12 13 14 15 16 17
17 LER/RO REPORT NUMBER 8 2 21 22 SHUTDOWN METHOD - 23 SEQUENTIAL REPORT NO. 0 3 6 24 OCCURRENCE CODE 0 3 27 REPORT TYPE L 30 REVISION NO. 0 32
ACTION TAKEN E 18 FUTURE ACTION X 19 EFFECT ON PLANT Z 20 HOURS 0 0 0 0 22 ATTACHMENT SUBMITTED N 23 NPRD-4 FORM SUB. Y 24 PRIME COMP. SUPPLIER N 25 COMPONENT MANUFACTURER F 1 2 0 26
33 34 35 36 37 38 39 40 41 42 43 44 45 46 47

1 0 The cause is a zero shift of transmitter 1FT-512 (Fischer/Porter
1 1 #10B2491VCBB-NS). The transmitter was recalibrated and put back in
1 2 service. These Fischer Porter transmitters are being evaluated for
1 3 replacement. These transmitter indications are checked shiftly for
1 4 drift. No further response is necessary

1 5 FACILITY STATUS E 28 % POWER 0 4 9 29 OTHER STATUS NA 30 METHOD OF DISCOVERY A 31 DISCOVERY DESCRIPTION Operator Observation 32
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50
1 6 ACTIVITY CONTENT Z 33 Z 34 AMOUNT OF ACTIVITY NA 35 LOCATION OF RELEASE NA 36
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50
1 7 PERSONNEL EXPOSURES 0 0 0 37 Z 38 NA 39
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50
1 8 PERSONNEL INJURIES 0 0 0 40 NA 41
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50
1 9 LOSS OF OR DAMAGE TO FACILITY Z 42 NA 43
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

2 0 PUBLICITY ISSUED N 44 8211190112 821112 PDR ADOCK 05000295 S PDR NRC USE ONLY
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50