

U.S. NUCLEAR REGULATORY COMMISSION

REGION III

Report No. 50-255/82-25(DETP)

Docket No. 50-255

License No. DPR-20

Safeguards Group IV

Licensee: Consumers Power Company  
212 West Michigan Avenue  
Jackson, MI 49201

Facility Name: Palisades Nuclear Plant

Inspection At: Palisades Site, Covert, MI

Inspection Conducted: October 13-15, and 18, 1982

Date of Last Physical Security Inspection: July 19-23, 1982

Type of Inspection: Unannounced, Special Physical Protection Inspection

Inspector: J. L. Belanger  
J. L. Belanger  
Physical Protection Specialist

Nov 1, 1982  
Date

Approved By: J. R. Creed  
J. R. Creed, Chief  
Safeguards Section

11/2/82

Inspection Summary

Inspection on October 13-15, and 18, 1982 (Report No. 50-255/82-25(DETP))  
Areas Inspected: Independent Inspection Effort. The inspection involved reviewing security related allegations contained in three anonymous letters received by the NRC Resident Inspector. The inspection involved 20 inspector-hours onsite and 2 hours in-office by one NRC inspector. The inspection began during the day shift period; two inspection hours were accomplished during the offshift periods.

Results: The licensee was found to be in compliance with NRC requirements within the scope of the inspection except for the following item:

Detection Aids - Protected Area: Failure to properly perform compensatory measures for an inactive alarm zone (Section 3)

(DETAILS - UNCLASSIFIED SAFEGUARDS INFORMATION)

Enclosure Contains  
SAFEGUARDS INFORMATION  
Upon Separation This  
Page is Decontrolled