

THE CINCINNATI GAS & ELECTRIC COMPANY



CINCINNATI, OHIO 45201  
November 8, 1982  
QA-2100

E. A. BORGMANN  
SENIOR VICE PRESIDENT

U. S. Nuclear Regulatory Commission  
Region III  
799 Roosevelt Road  
Glen Ellyn, IL 60137

Attention: Mr. J. G. Keppler  
Regional Administrator

RE: WM. H. ZIMMER NUCLEAR POWER STATION UNIT 1  
10CFR50.55(e)-ITEM M-54-LACK OF QUALIFICATION  
OF HYDRAULIC CONTROL UNITS, W.O.#57300,  
JOB E-5590, DOCKET NO.50-358, CONSTRUCTION  
PERMIT NO. CPPR-88, FILE NO. NRC-8, M-54

Gentlemen:

This letter constitutes an interim report concerning the subject condition, initially reported to the Commission on July 26, 1982, under the requirements of 10CFR50.55(e).


As stated in our previous report, QA-1945, dated August 17, 1982, the subject deficiency has been addressed for Zimmer by a dynamic requalification program which is a combination of analysis and limited scope testing covering both back-to-back and single row Hydraulic Control Unit configurations.

The structural analysis portion of this effort has been completed. A draft test specification has been completed and the test specimens are in the process of being purchased. The expected qualification test completion date is March 31, 1983, at which time a final report will be submitted.

We trust the above will be found acceptable as an interim report under 10CFR50.55(e).

Very truly yours,

THE CINCINNATI GAS & ELECTRIC COMPANY

By   
E. A. BORGMANN  
SENIOR VICE PRESIDENT

cc: NRC Office of Inspection & Enforcement  
Washington, D.C. 20555  
NRC Senior Resident Inspector  
Attn: W. F. Christianson  
Zimmer Project Inspector  
Region III

8211190155 821108  
PDR ADOCK 05000358  
S PDR

NOV 15 1982

IE27