

Southern California Edison Company

SAN ONOFRE NUCLEAR GENERATING STATION
P.O. BOX 128
SAN CLEMENTE, CALIFORNIA 92672

RECEIVED
NRC

1982 NOV -8 AM 10:55

SCE

REGION V

TELEPHONE
(714) 492-7700

H. B. RAY
STATION MANAGER

November 5, 1982

U. S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region V
1450 Maria Lane, Suite 210
Walnut Creek, California 94596-5368

Attention: Mr. R. H. Engelken, Regional Administrator

Dear Sir:

Subject: Docket No. 50-361
Prompt Report
Licensee Event Report No. 82-127
San Onofre Nuclear Generating Station, Unit 2

Pursuant to Appendix A Technical Specification 6.9.1.12b to Operating License NPF-10 for San Onofre Unit 2, this submittal provides the written confirmation of our prompt notification to the NRC on November 3, 1982 of a reportable occurrence involving the Iodine Removal System (IRS).

On November 3, 1982, an error was discovered in a temporary modification on low level cut-off controls made to the Spray Chemical Tank (T-105) on October 19, 1982. This error would have prevented the system from delivering the full required amount of NaOH solution into the Containment Spray System (CSS). The public health and safety was not affected by this occurrence since the CSS was operable at all times and the IRS was operable at a reduced efficiency, assuming a design basis event.

A 14-day follow up report and copy of Licensee Event Report (LER) 82-127 will be submitted by November 17, 1982.

If there are any questions, please contact me.

Sincerely,

HBRay / NRC

cc: A. E. Chaffee (USNRC Resident Inspector, San Onofre Unit 1)

8211190177 821105
PDR ADOCK 05000361
S PDR

IE-22
82-392