

APPENDIX A
NOTICE OF DEVIATION

Entergy Operations, Inc.
Arkansas Nuclear One, Unit 1

Docket No. 50-313
License No. DPR-51

During an NRC inspection conducted during the period November 26-30, and December 3-6, 1990, a deviation of your commitments to the NRC was identified. In accordance with the "General Statement of Policy and Procedure for NRC Enforcement Action," 10 CFR Part 2, Appendix C (1990), the deviation is listed below:

Letter OCAN078903, Arkansas Power & Light Company to NRC, "Response to Additional Questions Regarding Implementation of GL 88-17," dated July 6, 1989, contained the following statement in the second paragraph on page 4: "The AND procedure governing decay heat removal (DHR) and low temperature over pressure (LTOP) system control has been revised to require operator logging of independent CETs once per hour when the reactor coolant system level is below 390 feet."

In deviation from the above, Procedure 1015.002, Revision 11, "DHR and LTOP System Control," approved on November 24, 1990, stated in Step 5.5.1: "If reactor vessel head is removed, CETs data is not required." Consequently, core exit thermocouple (CET) data was not being logged hourly at all times the RCS level was below 390 feet.

Please provide to the Nuclear Regulatory Commission, ATTN: Document Control Desk, Washington, D.C. 20555, with a copy to the Regional Administrator, Region IV, and if applicable, a copy to the NRC Resident Inspector, in writing within 30 days of the date of this Notice, the reason for the deviation, the corrective steps which have been taken and the results achieved, the corrective steps which will be taken to avoid further deviations, and the date when your corrective action will be completed. Where good cause is shown, consideration will be given to extending the response time.

Dated at Arlington, Texas
this 4th day of January 1990